

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Port Hacking High School (8230)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

8230 - Port Hacking High School  
Site Plan (11233)



1:1,590

Printed: 01-May-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (20.23 SQM)	Office (5)	
B00A - R0008 - Administration - Clerical - (13.03 SQM)	Office (3)	
B00A - R0009 - Principal Office - (15.96 SQM)	Office (3)	
B00A - R0018 - Deputy Principal Office - (17.39 SQM)	Office (4)	
B00A - R0020 - Commonroom - (74.66 SQM)	Office (18)	
B00A - R0021 - Preparation - (21.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - General Learning Space - (38.23 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0026 - Preparation - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (17.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (20.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Staff Kitchen - (9.78 SQM)	Office (2)	
B00A - R0042 - Staff Study - (29.31 SQM)	Office (7)	
B00A - R0048 - General Learning Space - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0049 - Science Laboratory - (17.22 SQM)	Student Space (7)	
B00A - R0050 - General Learning Space - (61.61 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0051 - Science Laboratory - (12.98 SQM)	Student Space (6)	
B00A - R0052 - Movement - (236.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Pupil Entry - (19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Public Reception - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (49.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Public Reception - (13.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Staff Study - (16.05 SQM)	Office (4)	
B00A - R1003 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Interview/Office - Type 1 - (8.3 SQM)	Office (2)	
B00A - R1010 - Administration - Clerical - (11.36 SQM)	Office (2)	
B00A - R1011 - Performance Workspace - (90.16 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R1016 - Movement - (42.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - General Learning Space - (56.46 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1018 - General Learning Space - (56.13 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1019 - General Learning Space - (55.09 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1020 - General Learning Space - (57.75 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1021 - General Learning Space - (55.3 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1022 - General Learning Space - (58.21 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1023 - Staff Study - (19.03 SQM)	Office (4)	
B00A - R1024 - Staff Study - (39.88 SQM)	Office (9)	
B00A - R1031 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1033 - Movement - (251.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Student Canteen - (56.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R9008 - Student Canteen - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Movement - (291.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Movement - (142.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R9021 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R9026 - Movement - (21.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - General Learning Space - (60.74 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0003 - General Learning Space - (54.58 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0011 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (13.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Student Waiting - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Administration - Clerical - (20.43 SQM)	Office (5)	
B00B - R0018 - Deputy Principal Office - (19.17 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0019 - Leading Teacher - (9.97 SQM)	Office (2)	
B00B - R0020 - Movement - (36.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Deputy Principal Office - (17.62 SQM)	Office (4)	
B00B - R1002 - General Learning Space - (59.16 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1003 - General Learning Space - (54.51 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1004 - General Learning Space - (54.74 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1010 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Movement - (61 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R9003 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R9009 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R9011 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R9013 - Movement - (22.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R9016 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R9018 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Computer Learning Space - (50.43 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0017 - Staff Study - (16.56 SQM)	Office (4)	
B00C - R0020 - Food Technology L.S. - (80.8 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R0021 - Preparation - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Food Technology L.S. - (75.28 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0023 - Food Technology L.S. - (75.2 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0025 - Movement - (171.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Staff Study - (14.53 SQM)	Office (3)	
B00C - R1006 - Staff Study - (7.27 SQM)	Office (1)	
B00C - R1007 - General Learning Space - (67.49 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1010 - General Learning Space - (66.46 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1011 - Design L.S. - (67.37 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1014 - Design L.S. - (50.36 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1016 - General Learning Space - (55.2 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1017 - Staff Study - (16.72 SQM)	Office (4)	
B00C - R1020 - Movement - (170.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R9002 - Staff Study - (16.6 SQM)	Office (4)	
B00C - R9005 - Staff Study - (22 SQM)	Office (5)	
B00C - R9006 - Darkroom Space - (31.13 SQM)	Office (7)	
B00C - R9009 - Practice/Seminar - (32.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R9012 - Music Learning Space - (66.68 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R9013 - Practice/Seminar - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R9014 - Art Learning Space - (48.39 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R9015 - Art Learning Space - (50.01 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R9017 - Staff Kitchen - (11.22 SQM)	Office (2)	
B00C - R9020 - Study Space - (28.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R9021 - Study Space - (13.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R9026 - Movement - (187.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Movement - (59.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0004 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - General Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Interview/Office - Type 1 - (18.46 SQM)	Office (4)	
B00D - R0007 - Interview/Office - Type 1 - (23.86 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0008 - General Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0009 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Design/Technology L.S. - (76.27 SQM) - Teaching Space: 1	● Student Space (35)	
B00E - R0006 - Welding Area - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Materials Technology L.S. - (76.36 SQM) - Teaching Space: 1	● Student Space (35)	
B00E - R0009 - Staff Study - (31 SQM)	● Office (7)	
B00E - R0012 - Computer Learning Space - (68.53 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0013 - Design L.S. - (63.69 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0014 - Materials Technology L.S. - (75.43 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R0026 - Movement - (14.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Wood Technology Bay - (132 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Wood Technology Bay - (132.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Movement - (75.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R9005 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R9009 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - General Assistants - (7.95 SQM)	● Office (1)	
B00F - R0005 - Multi-Purpose Space - (365.45 SQM)	● Student Space (169)	
B00F - R0007 - Movement - (17.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (13.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R1011 - Science Laboratory - (54.04 SQM)	● Student Space (25)	
B00F - R1012 - General Learning Space - (39.69 SQM) - Teaching Space: 1	● Student Space (18)	
B00F - R1013 - Preparation - Science - (40.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R1014 - Science Laboratory - (50.89 SQM)	● Student Space (23)	
B00F - R1015 - General Learning Space - (41.43 SQM) - Teaching Space: 1	● Student Space (19)	
B00F - R1016 - Movement - (145.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R2003 - Movement - (17.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R2008 - Workroom - (9.48 SQM)	● Office (2)	
B00F - R2009 - General Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R2015 - Movement - (74.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R2017 - Staff Study - (35.35 SQM)	● Office (8)	
B00F - R2018 - General Learning Space - (42.66 SQM) - Teaching Space: 1	● Student Space (19)	
B00F - R2019 - General Learning Space - (51.58 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R2020 - General Learning Space - (51.59 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R2021 - Movement - (43.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Preparation - (29.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Preparation - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Staff Study - (26.71 SQM)	● Office (6)	
B00G - R0015 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0017 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (23.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (72.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Science Laboratory - (93.14 SQM)	● Student Space (43)	
B00G - R0028 - Science Laboratory - (92.19 SQM)	● Student Space (42)	
B00G - R1002 - General Learning Space - (57.58 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1004 - General Learning Space - (62.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1005 - General Learning Space - (62.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1011 - Administration - Clerical - (19.37 SQM)	● Office (4)	
B00G - R1012 - Staff Study - (28.01 SQM)	● Office (7)	
B00G - R1013 - General Learning Space - (54.34 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1017 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R1018 - Movement - (34.88 SQM)	Not Applicable	Circulation or storage space.
B00G - R1019 - Movement - (68.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R9001 - Music Learning Space - (54.18 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R9003 - Art Learning Space - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R9005 - Art Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R9013 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R9014 - Movement - (73.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Stage - (123.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (8.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Staff Kitchen - (9.97 SQM)	● Office (2)	
B00H - R0015 - Multi-Purpose Space - (458.72 SQM)	● Student Space (212)	
B00J - R0014 - Lecture Space - (60.61 SQM) - Teaching Space: 2	● Student Space (28)	
B00J - R0016 - Seminar - (13.95 SQM)	● Office (3)	
B00J - R0018 - Pupil Entry - (29.12 SQM)	Not Applicable	Circulation or storage space.
B00J - R0020 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Study Space - (335.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - Seminar - (14.19 SQM)	● Office (3)	
B00J - R0025 - Seminar - (13.85 SQM)	● Office (3)	
B00J - R0028 - Movement - (9.75 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Performance Workshop - (102.17 SQM)	● Student Space (47)	
B00L - R0001 - Gymnasium - (619.03 SQM)	● Student Space (287)	
B00L - R0003 - Teachers Aides - (18.3 SQM)	● Office (4)	
B00L - R0008 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Dark Room - (99.21 SQM)	● Office (24)	
B00L - R0011 - Music Learning Space - (99.29 SQM) - Teaching Space: 1	● Student Space (46)	
B00L - R0012 - Movement Studio - (120.45 SQM)	Not Applicable	Circulation or storage space.
OS 520 12023 - OS 520 12023 - Staff Study - (57 SQM)	● Office (14)	
OS 600 10928 - OS 600 10928 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11454 - OS 600 11454 - Learning Unit - Small - (76 SQM)	● Student Space (35)	
OS 600 18332 - OS 600 18332 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 13369 - OS 601 13369 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	