

VENTILATION AUDIT REPORT

SCHOOL:	Port Kembla Public School (2896)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wollongong
LOCAL GOVERNMENT AREA:	Wollongong

2896 - Port Kembla Public School
Site Plan (14633)



1:1,206

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (20.53 SQM)	Student Space (9)	
B00A - R0002 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0004 - Withdrawal Space - 1hb - (11.28 SQM)	Student Space (5)	
B00A - R0005 - Practical Activities - 1hb - (18.95 SQM)	Student Space (8)	
B00A - R0006 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1001 - Practical Activities - 1hb - (21.76 SQM)	Student Space (10)	
B00A - R1002 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1004 - Withdrawal Space - 1hb - (11.98 SQM)	Student Space (5)	
B00A - R1005 - Practical Activities - 1hb - (21.24 SQM)	Student Space (9)	
B00A - R1006 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1009 - Practical Activities - 1hb - (21.49 SQM)	Student Space (9)	
B00A - R1010 - Home Base - (58.82 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1012 - Withdrawal Space - 1hb - (12.01 SQM)	Student Space (5)	
B00A - R1013 - Practical Activities - 1hb - (21.37 SQM)	Student Space (9)	
B00A - R1014 - Home Base - (59.14 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1017 - Practical Activities - 1hb - (21.46 SQM)	Student Space (9)	
B00A - R1018 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1020 - Withdrawal Space - 1hb - (11.98 SQM)	Student Space (5)	
B00A - R1021 - Practical Activities - 1hb - (21.78 SQM)	Student Space (10)	
B00A - R1022 - Home Base - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0001 - Entry Vestibule - (22.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Clerical Office - (17.69 SQM)	Office (4)	
B00B - R0003 - Duplicating Workroom - (19.92 SQM)	Office (4)	
B00B - R0004 - Sick Bay - (8.3 SQM)	Student Space (3)	
B00B - R0006 - Interview - (12.44 SQM)	Office (3)	
B00B - R0007 - Principal - (18.34 SQM)	Office (4)	
B00B - R0010 - Deputy Principal - (13.19 SQM)	Office (3)	
B00B - R0014 - Deputy Principal - (13.19 SQM)	Office (3)	
B00B - R0016 - Staff Room - (45.29 SQM)	Office (11)	
B00B - R0017 - Staff Room Annexe - (19.71 SQM)	Office (4)	
B00B - R0018 - Movement - (35.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Canteen - (24.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Reading Area - (167.85 SQM)	Student Space (77)	
B00B - R1004 - Seminar/Study - (38.44 SQM)	Office (9)	
B00C - R0001 - Communal Space - (138.91 SQM)	Student Space (64)	
B00C - R0002 - Raised Platform - (47.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (12.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (12.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (60.41 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0003 - Practical Activities - 1hb - (19.07 SQM)	Student Space (8)	
B00D - R0004 - Withdrawal Space - 2hb - (11.69 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (60.81 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0007 - Practical Activities - 1hb - (19.08 SQM)	Student Space (8)	
OS 602 14495 - OS 602 14495 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	