


VENTILATION AUDIT REPORT

SCHOOL:	Port Macquarie Public School (2899)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

2899 - Port Macquarie Public School
Site Plan (12843)


























1:746

Printed: 05-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Practical Activities - 1hb - (22.46 SQM)	Student Space (10)	
B00A - R0004 - Home Base - (49.4 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - Home Base - (49.71 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0006 - Practical Activities - 1hb - (22.46 SQM)	Student Space (10)	
B00A - R0007 - Practical Activities - 1hb - (22.21 SQM)	Student Space (10)	
B00A - R0008 - Home Base - (48.94 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1001 - Practical Activities - 1hb - (19.79 SQM)	Student Space (9)	
B00A - R1002 - Home Base - (47.95 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - Home Base - (47.95 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1004 - Practical Activities - 1hb - (19.18 SQM)	Student Space (8)	
B00A - R1005 - Practical Activities - M - 1hb - (19.79 SQM)	Student Space (9)	
B00A - R1006 - Home Base - M - (47.19 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0001 - Staff Room - (91.92 SQM)	Office (22)	
B00B - R0002 - Staff Kitchen - (23.53 SQM)	Office (5)	
B00B - R0003 - Principal - (22.08 SQM)	Office (5)	
B00B - R0004 - Clerical Office/Workroom - (21.03 SQM)	Office (5)	
B00B - R0005 - Entry Vestibule - (9.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Sick Bay - (12.62 SQM)	Student Space (5)	
B00B - R0009 - Duplicating Workroom - (15.68 SQM)	Office (3)	
B00B - R0011 - Deputy Principal - (14.27 SQM)	Office (3)	
B00B - R0012 - Deputy Principal - (13.7 SQM)	Office (3)	
B00B - R0013 - Teachers Aide Special Ed - (12.23 SQM)	Office (3)	
B00B - R0014 - Movement - (50.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Reading Area - (223.97 SQM)	Student Space (103)	
B00B - R1010 - Movement - (9.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Communal Space - (258.83 SQM)	Student Space (120)	
B00C - R0003 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Canteen - (50.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Raised Platform - (82.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R9003 - Movement - (27.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Practical Activities - 1hb - (27.93 SQM)	Student Space (12)	
B00D - R0004 - Home Base - (65.61 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0005 - Home Base - (65.62 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0006 - Practical Activities - 1hb - (27.94 SQM)	Student Space (12)	
B00D - R0008 - Movement - (83.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (21.09 SQM)	Student Space (9)	
B00F - R0002 - Home Base - (48.82 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0004 - Home Base - (48.82 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0005 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00F - R0006 - Practical Activities - 1hb - (20.3 SQM)	Student Space (9)	
B00F - R0007 - Home Base - (48.82 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1001 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00F - R1002 - Home Base - (49.99 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1004 - Home Base - (49.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1005 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00F - R1006 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00F - R1007 - Home Base - (49.21 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1008 - Home Base - (49.21 SQM) - Teaching Space: 1	 Student Space (22)	
B00F - R1009 - Practical Activities - 1hb - (20.31 SQM)	 Student Space (9)	
B00G - R0002 - Home Base - (65.7 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R0003 - Staff Room Annexe - (21.06 SQM)	 Office (5)	
B00G - R0004 - Movement - (80 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (61.71 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0008 - Interview - (13.01 SQM)	 Office (3)	
B00G - R0011 - Home Base - (51.55 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0012 - Home Base - (51.51 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0013 - Practical Activities - 1hb - (22.64 SQM)	 Student Space (10)	
B00H - R0002 - Staff Room Annexe - (16.75 SQM)	 Office (4)	
B00H - R0004 - Movement - (8.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Home Base - (57.46 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0008 - Home Base - (57.54 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0010 - Movement - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Home Base - (57.75 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R0002 - Home Base - M - (68.09 SQM) - Teaching Space: 1	 Student Space (31)	
B00J - R0008 - Practical Activities - M - 2hb - (38.47 SQM)	 Student Space (17)	
B00J - R0010 - Home Base - M - (68.05 SQM) - Teaching Space: 1	 Student Space (31)	
B00K - R0003 - Entry Vestibule - (18.18 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Clerical Office - (18.02 SQM)	 Office (4)	
B00K - R0006 - Staff Room - (27.48 SQM)	 Office (6)	
B00K - R0009 - Practical Activities/Movement - 1hb - (18.57 SQM)	 Student Space (8)	
B00K - R0011 - Home Base - (61.09 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0012 - Withdrawal Space - 2hb - (11.76 SQM)	 Student Space (5)	
B00K - R0013 - Home Base - (60.53 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0015 - Practical Activities/Movement - 1hb - (20.2 SQM)	 Student Space (9)	