


VENTILATION AUDIT REPORT

SCHOOL:	Pottsville Beach Public School (3578)
AMU REGION:	North Coast
STATE ELECTORATE:	Tweed
LOCAL GOVERNMENT AREA:	Tweed

3578 - Pottsville Beach Public School
Site Plan (13599)



1:1,148








Printed: 14-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0032 - Reading Area - (216.77 SQM)	Student Space (100)	
B00B - R0007 - Practical Activities - 1hb - (26.95 SQM)	Student Space (12)	
B00B - R0009 - Withdrawal Space - 1hb - (5.71 SQM)	Student Space (2)	
B00B - R0010 - Home Base - (50.13 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0011 - Home Base - (50.27 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0012 - Withdrawal Space - 1hb - (5.61 SQM)	Student Space (2)	
B00B - R0015 - Practical Activities - 1hb - (27.85 SQM)	Student Space (12)	
B00B - R0016 - Practical Activities - 1hb - (27.89 SQM)	Student Space (12)	
B00B - R0018 - Withdrawal Space - 1hb - (5.64 SQM)	Student Space (2)	
B00B - R0019 - Home Base - (50.41 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0020 - Home Base - (50.13 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0022 - Withdrawal Space - 1hb - (5.63 SQM)	Student Space (2)	
B00B - R0024 - Practical Activities - 1hb - (26.92 SQM)	Student Space (12)	
B00C - R0002 - Special Programs Room - (32.44 SQM)	Student Space (15)	
B00C - R0012 - Practical Activities - 1hb - (27.88 SQM)	Student Space (12)	
B00C - R0014 - Withdrawal Space - 1hb - (5.76 SQM)	Student Space (2)	
B00C - R0015 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0016 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0017 - Withdrawal Space - 1hb - (5.69 SQM)	Student Space (2)	
B00C - R0020 - Practical Activities - 1hb - (26.92 SQM)	Student Space (12)	
B00C - R0023 - Practical Activities - 1hb - (20.84 SQM)	Student Space (9)	
B00C - R0024 - Home Base - (61.43 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0025 - Practical Activities - 1hb - (24.55 SQM)	Student Space (11)	
B00C - R0026 - Home Base - (60.7 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0027 - Withdrawal Space - 1hb - (8.36 SQM)	Student Space (3)	
B00C - R0028 - Withdrawal Space - 1hb - (9.07 SQM)	Student Space (4)	
B00D - R0007 - Practical Activities - 1hb - (23.69 SQM)	Student Space (10)	
B00D - R0009 - Home Base - (54.81 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0010 - Home Base - (54.6 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0011 - Withdrawal Space - 1hb - (10.59 SQM)	Student Space (4)	
B00D - R0012 - Practical Activities - 1hb - (24.24 SQM)	Student Space (11)	
B00D - R0016 - Practical Activities - 1hb - (24.19 SQM)	Student Space (11)	
B00D - R0017 - Home Base - (54.67 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0018 - Home Base - (54.68 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0019 - Withdrawal Space - 1hb - (10.62 SQM)	Student Space (4)	
B00D - R0023 - Practical Activities - 1hb - (23.72 SQM)	Student Space (11)	
B00E - R0008 - Movement - (13.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Raised Platform - (58.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (13.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Communal Space - (139.84 SQM)	Student Space (64)	
B00F - R0004 - Canteen - (42.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.46 SQM)	Student Space (9)	
B00G - R0004 - Home Base - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.38 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.45 SQM)	Student Space (9)	
B00K - R0001 - Practical Activities - 1hb - (18.52 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0003 - Home Base - (60.83 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0004 - Withdrawal Space - 2hb - (11.41 SQM)	● Student Space (5)	
B00K - R0005 - Home Base - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0007 - Practical Activities - 1hb - (17.71 SQM)	● Student Space (8)	
B00K - R0009 - Withdrawal Space - 1hb - (8.87 SQM)	● Student Space (4)	
B00K - R0018 - Home Base - (70.73 SQM) - Teaching Space: 1	● Student Space (32)	
B00K - R0019 - Practical Activities - 1hb - (7.68 SQM)	● Student Space (3)	
B00K - R1001 - Practical Activities - 1hb - (18.45 SQM)	● Student Space (8)	
B00K - R1003 - Home Base - (60.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1004 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00K - R1005 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1006 - Practical Activities - 1hb - (17.65 SQM)	● Student Space (8)	
B00K - R1008 - Practical Activities - 1hb - (18.45 SQM)	● Student Space (8)	
B00K - R1009 - Withdrawal Space - 1hb - (8.86 SQM)	● Student Space (4)	
B00K - R1011 - Special Programs Room - (59.12 SQM)	● Student Space (27)	
B00L - R0001 - Movement - (23.67 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Staff Room - (53.01 SQM)	● Office (13)	
B00M - R0002 - Staff Room Annexe - (39.4 SQM)	● Office (9)	
B00M - R0003 - Interview - (13.07 SQM)	● Office (3)	
B00M - R0005 - Special Programs Room - (25.35 SQM)	● Student Space (11)	
B00M - R0012 - Entry Vestibule - (15.5 SQM)	Not Applicable	Circulation or storage space.
B00M - R0014 - Interview - (16.51 SQM)	● Office (4)	
B00M - R0015 - Sick Bay - (9.09 SQM)	● Student Space (4)	
B00M - R0018 - Deputy Principal - (12.9 SQM)	● Office (3)	
B00M - R0019 - Deputy Principal - (13.39 SQM)	● Office (3)	
B00M - R0021 - Principal - (16.87 SQM)	● Office (4)	
B00M - R0023 - Clerical Office - (18.93 SQM)	● Office (4)	
B00M - R0024 - Practical Activities - 4hb - (19.41 SQM)	● Student Space (9)	
B00M - R0025 - Home Base - (69.4 SQM) - Teaching Space: 1	● Student Space (32)	
B00M - R0026 - Withdrawal Space - 2hb - (13.48 SQM)	● Student Space (6)	
B00M - R0027 - Practical Activities - 2hb - (18.28 SQM)	● Student Space (8)	
B00M - R0028 - Home Base - (72.86 SQM) - Teaching Space: 1	● Student Space (33)	
B00M - R0029 - Movement - (22.35 SQM)	Not Applicable	Circulation or storage space.
B00M - R0030 - Practical Activities - 2hb - (18.26 SQM)	● Student Space (8)	
B00M - R0031 - Home Base - (77.75 SQM) - Teaching Space: 1	● Student Space (36)	
B00M - R0041 - Staff Kitchen - (8.97 SQM)	● Office (2)	
B00M - R0042 - Staff Kitchen - (6.62 SQM)	● Office (1)	
B00M - R1005 - Practical Activities - 2hb - (18.73 SQM)	● Student Space (8)	
B00M - R1006 - Home Base - (72.03 SQM) - Teaching Space: 1	● Student Space (33)	
B00M - R1007 - Withdrawal Space - 2hb - (14.42 SQM)	● Student Space (6)	
B00M - R1009 - Home Base - (70.96 SQM) - Teaching Space: 1	● Student Space (32)	
B00M - R1010 - Practical Activities - 2hb - (25.27 SQM)	● Student Space (11)	
B00M - R1011 - Home Base - (67.14 SQM) - Teaching Space: 1	● Student Space (31)	
B00M - R1012 - Practical Activities - 2hb - (21.27 SQM)	● Student Space (9)	
B00M - R1013 - Withdrawal Space - 2hb - (12.13 SQM)	● Student Space (5)	
B00M - R1014 - Home Base - (67.48 SQM) - Teaching Space: 1	● Student Space (31)	
B00M - R1016 - Practical Activities - 2hb - (19.68 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R1017 - Practical Activities - 2hb - (19.04 SQM)	 Student Space (8)	
B00M - R1018 - Home Base - (70.14 SQM) - Teaching Space: 1	 Student Space (32)	
B00M - R1019 - Withdrawal Space - 2hb - (13.52 SQM)	 Student Space (6)	
B00M - R1020 - Practical Activities - 1hb - (18.12 SQM)	 Student Space (8)	
B00M - R1021 - Home Base - (72.74 SQM) - Teaching Space: 1	 Student Space (33)	
B00M - R1023 - Practical Activities - 1hb - (18.07 SQM)	 Student Space (8)	
B00M - R1024 - Home Base - (77.86 SQM) - Teaching Space: 1	 Student Space (36)	