


VENTILATION AUDIT REPORT

SCHOOL:	Prairievale Public School (4554)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Fairfield

4554 - Prairievale Public School
Site Plan (10833)



1.970

Printed: 30-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Interview - (12.59 SQM)	Office (3)	
B00A - R0007 - Deputy Principal - (11.82 SQM)	Office (2)	
B00A - R0008 - Entry Vestibule - (8.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Interview - (17.27 SQM)	Office (4)	
B00A - R0012 - Movement - (9.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Principal - (23.04 SQM)	Office (5)	
B00A - R0015 - Movement - (6.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Sick Bay - (10.31 SQM)	Student Space (4)	
B00A - R0019 - Clerical Office - (14.49 SQM)	Office (3)	
B00A - R0020 - Movement - (25.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Clerical Office - (12.82 SQM)	Office (3)	
B00A - R0023 - Duplicating Workroom - (33.31 SQM)	Office (8)	
B00A - R0024 - Staff Room Annexe - (26.99 SQM)	Office (6)	
B00A - R0025 - Staff Room - (61.24 SQM)	Office (15)	
B00A - R0026 - Movement - (49.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (39.91 SQM)	Student Space (18)	
B00B - R0003 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0005 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00B - R0006 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0011 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (9.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (39.78 SQM)	Student Space (18)	
B00C - R0002 - Home Base - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00C - R0005 - Home Base - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0010 - Movement - (7.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (39.91 SQM)	Student Space (18)	
B00D - R0002 - Home Base - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0004 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - Movement - (7.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (39.92 SQM)	Student Space (18)	
B00E - R0003 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Movement - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (39.77 SQM)	Student Space (18)	
B00F - R0003 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 1hb - (12.59 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Movement - (9.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Reading Area - (221.52 SQM)	Student Space (102)	
B00H - R0004 - Special Programs Room - (41.96 SQM)	Student Space (19)	
B00H - R0010 - Movement - (15.07 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0001 - Practical Activities - 1hb - (39.91 SQM)	● Student Space (18)	
B00J - R0003 - Home Base - (59.57 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 1hb - (12.59 SQM)	● Student Space (5)	
B00J - R0006 - Home Base - (59.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0011 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (9.47 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Special Programs Room - (39.9 SQM)	● Student Space (18)	
B00L - R0003 - Home Base - (59.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 1hb - (12.59 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Movement - (9.49 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Communal Space - (186.37 SQM)	● Student Space (86)	
B00N - R0005 - Raised Platform - (53.27 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00N - R0011 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00N - R0014 - Canteen - (43.39 SQM)	Not Applicable	Circulation or storage space.
B00N - R0019 - Movement - (31.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R0021 - Movement - (15.78 SQM)	Not Applicable	Circulation or storage space.
B00N - R0022 - Movement - (94.86 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Practical Activities - 1hb - (19.74 SQM)	● Student Space (9)	
B00O - R0002 - Home Base - (60.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0004 - Withdrawal Space - 2hb - (11.4 SQM)	● Student Space (5)	
B00O - R0005 - Practical Activities - 1hb - (19.63 SQM)	● Student Space (9)	
B00O - R0006 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0008 - Practical Activities - 1hb - (19.01 SQM)	● Student Space (8)	
B00O - R0009 - Home Base - (60.55 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0011 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00O - R0012 - Practical Activities - 1hb - (19.68 SQM)	● Student Space (9)	
B00O - R0013 - Home Base - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 10480 - OS 602 10480 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12050 - OS 602 12050 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 17690 - OS 602 17690 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 751 14901 - OS 751 14901 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	