

VENTILATION AUDIT REPORT

SCHOOL:	Prairiewood High School (8560)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Fairfield

8560 - Prairiewood High School
Site Plan (12845)



1:1,668

Printed: 19-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0001 - Staff Lounge - (19.9 SQM)	Office (4)	
B00D - R0005 - Laboratory L.S. - (79.84 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0006 - Preparation - Science - (33.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Laboratory L.S. - (78.21 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0010 - Laboratory L.S. - (79.15 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0011 - Seminar - (31.98 SQM)	Office (7)	
B00D - R0012 - Laboratory L.S. - (78.97 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0016 - Laboratory L.S. - (77 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0017 - Preparation - Science - (33.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Laboratory L.S. - (84.62 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0019 - Movement - (138.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Staff Study - (39.45 SQM)	Office (9)	
B00D - R1003 - Food Technology L.S. - (110.85 SQM) - Teaching Space: 1	Student Space (51)	
B00D - R1004 - Preparation - Materials - (18.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Food Technology L.S. - (111.82 SQM) - Teaching Space: 1	Student Space (51)	
B00D - R1007 - Textiles Technology L.S. - (69.08 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1009 - Computer Learning Space - (69.89 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1011 - Movement - (83.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Staff Study - (26.01 SQM)	Office (6)	
B00E - R0001 - Leading Teacher - (15.33 SQM)	Office (3)	
B00E - R0002 - Deputy Principal Office - (12.93 SQM)	Office (3)	
B00E - R0008 - Principal Office - (19.23 SQM)	Office (4)	
B00E - R0010 - Interview/Office - Type 1 - (12.6 SQM)	Office (3)	
B00E - R0011 - Administration - Clerical - (13.21 SQM)	Office (3)	
B00E - R0012 - Administration - Clerical - (40.56 SQM)	Office (10)	
B00E - R0015 - Movement - (68.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Deputy Principal Office - (13.95 SQM)	Office (3)	
B00E - R1007 - Movement - (27.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Interview/Office - Type 1 - (20.97 SQM)	Office (5)	
B00E - R1013 - Interview/Office - Type 1 - (25.01 SQM)	Office (6)	
B00E - R1014 - Interview/Office - Type 2 - (25.12 SQM)	Office (6)	
B00E - R1015 - Staff Kitchen - (48.77 SQM)	Office (12)	
B00E - R1016 - Commonroom - (54.02 SQM)	Office (13)	
B00F - R0001 - Multi Media Workshop - (64.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Multi Media Workshop - (22.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Art Learning Space - (59.63 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0006 - Workshop - (57.21 SQM)	Student Space (26)	
B00F - R0008 - Art Learning Space - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0010 - Art Learning Space - (65.61 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0016 - Staff Study - (17.64 SQM)	Office (4)	
B00F - R0017 - Movement - (18.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Workshop - (81.29 SQM)	Student Space (37)	
B00F - R1001 - Staff Study - (12.17 SQM)	Office (3)	
B00F - R1004 - Performance Workshop - (15.54 SQM)	Student Space (7)	
B00F - R1005 - Staff Study - (25.04 SQM)	Office (6)	
B00F - R1006 - Music Learning Space - (75.86 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R1007 - Music Learning Space - (60.57 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R1008 - Practice/Seminar - (26.12 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1014 - Movement - (42.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R1015 - Movement - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R1021 - Dark Room - (23.82 SQM)	Office (5)	
B00G - R0003 - Metal Technology L.S. - (92.96 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0004 - Metal Technology Bay - (30.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Metal Technology L.S. - (87.9 SQM) - Teaching Space: 1	Student Space (40)	
B00G - R0006 - Wood Technology L.S. - (87.84 SQM) - Teaching Space: 1	Student Space (40)	
B00G - R0007 - Wood Technology Bay - (28.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Wood Technology L.S. - (95.23 SQM) - Teaching Space: 1	Student Space (44)	
B00G - R0013 - Movement - (97.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R1004 - Computer Learning Space - (55.89 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R1005 - Movement - (19.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Staff Study - (23.01 SQM)	Office (5)	
B00G - R1009 - Design/Technology L.S. - (55.4 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0004 - Student Canteen - (58.71 SQM)	Not Applicable	Circulation or storage space.
B00J - M0001 - Movement - (188.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Assistants - (12.84 SQM)	Office (3)	
B00J - R0003 - Multi-Purpose Space - (612.04 SQM)	Student Space (283)	
B00J - R0005 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Stage - (103.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (7.72 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Movement - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Staff Kitchen - (14.21 SQM)	Office (3)	
B00J - R0016 - Movement - (19.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Movement - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Fitness Laboratory - (42.39 SQM)	Student Space (19)	
B00J - R0024 - Movement - (31.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0050 - Staff Study - (25.82 SQM)	Office (6)	
B00K - R0002 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement Studio - (185 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Science Laboratory - (13.45 SQM)	Student Space (6)	
BABC - R0033 - Main Area - (288.48 SQM)	Not Applicable	Circulation or storage space.
BABC - R0036 - Movement - (251.5 SQM)	Not Applicable	Circulation or storage space.
BABC - R0A01 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
BABC - R0A02 - General Learning Space - (49.5 SQM) - Teaching Space: 1	Student Space (22)	
BABC - R0A03 - General Learning Space - (49.75 SQM) - Teaching Space: 1	Student Space (23)	
BABC - R0A04 - General Learning Space - (50.26 SQM) - Teaching Space: 1	Student Space (23)	
BABC - R0A05 - General Learning Space - (49.69 SQM) - Teaching Space: 1	Student Space (23)	
BABC - R0A06 - General Learning Space - (47.74 SQM) - Teaching Space: 1	Student Space (22)	
BABC - R0A07 - General Learning Space - (39.66 SQM) - Teaching Space: 1	Student Space (18)	
BABC - R0A08 - General Learning Space - (48 SQM) - Teaching Space: 1	Student Space (22)	
BABC - R0A16 - Staff Study - (32.59 SQM)	Office (8)	
BABC - R0B03 - Staff Study - (14.63 SQM)	Office (3)	
BABC - R0B07 - Seminar - (11.91 SQM)	Office (2)	
BABC - R0B08 - Seminar - (11.91 SQM)	Office (2)	
BABC - R0B16 - Interview/Office - Type 1 - (13.65 SQM)	Office (3)	
BABC - R0B24 - Movement - (250.87 SQM)	Not Applicable	Circulation or storage space.
BABC - R0B27 - Movement - (59.7 SQM)	Not Applicable	Circulation or storage space.
BABC - R0B29 - Tiered Learning Area - (54.14 SQM)	Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BABC - R0B32 - Tea Room - (7.34 SQM)	Not Applicable	Circulation or storage space.
BABC - R0C01 - Special Learning Space - (49.86 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R0C02 - Special Learning Space - (41.19 SQM) - Teaching Space: 1	● Student Space (19)	
BABC - R0C03 - General Learning Space - (48.74 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R0C04 - General Learning Space - (49.13 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R0C05 - General Learning Space - (50.17 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R0C06 - General Learning Space - (49.83 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R0C07 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R0C08 - General Learning Space - (47.47 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R0C09 - Movement - (215.2 SQM)	Not Applicable	Circulation or storage space.
BABC - R0C12 - Senior Study - (50.46 SQM)	● Office (12)	
BABC - R0C19 - Movement - (14.54 SQM)	Not Applicable	Circulation or storage space.
BABC - R0C20 - Staff Study - (35.04 SQM)	● Office (8)	
BABC - R1003 - Movement - (224.8 SQM)	Not Applicable	Circulation or storage space.
BABC - R1A01 - General Learning Space - (48.29 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1A02 - General Learning Space - (49.84 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1A03 - General Learning Space - (49.98 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1A04 - General Learning Space - (50.91 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1A05 - General Learning Space - (49.87 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1A06 - General Learning Space - (48.22 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1A07 - General Learning Space - (40.36 SQM) - Teaching Space: 1	● Student Space (18)	
BABC - R1A08 - Computer Learning Space - (48.12 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1A14 - Staff Study - (35.24 SQM)	● Office (8)	
BABC - R1B04 - Movement - (145.5 SQM)	Not Applicable	Circulation or storage space.
BABC - R1B07 - Interview/Office - Type 1 - (14.57 SQM)	● Office (3)	
BABC - R1C01 - General Learning Space - (50.15 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1C02 - General Learning Space - (40.51 SQM) - Teaching Space: 1	● Student Space (18)	
BABC - R1C03 - General Learning Space - (48.77 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1C04 - Computer Learning Space - (48.49 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1C05 - General Learning Space - (50.77 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1C06 - General Learning Space - (49.88 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1C07 - General Learning Space - (49.6 SQM) - Teaching Space: 1	● Student Space (23)	
BABC - R1C08 - General Learning Space - (47.75 SQM) - Teaching Space: 1	● Student Space (22)	
BABC - R1C09 - Movement - (202.33 SQM)	Not Applicable	Circulation or storage space.
BABC - R1C15 - Interview/Office - Type 1 - (15.09 SQM)	● Office (3)	
BABC - R1C16 - Staff Study - (35.12 SQM)	● Office (8)	
OS 600 18279 - OS 600 18279 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10225 - OS 601 10225 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11792 - OS 601 11792 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13300 - OS 601 13300 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13678 - OS 601 13678 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14531 - OS 601 14531 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16629 - OS 601 16629 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19487 - OS 601 19487 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 11826 - OS 720 11826 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.