

VENTILATION AUDIT REPORT

SCHOOL:	Prestons Public School (2901)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Holsworthy
LOCAL GOVERNMENT AREA:	Liverpool

2901 - Prestons Public School
Site Plan (11664)



1:1,246






Printed: 04-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (22.26 SQM)	Office (5)	
B00A - R0005 - Principal - (16.9 SQM)	Office (4)	
B00A - R0009 - Interview - (13.49 SQM)	Office (3)	
B00A - R0010 - Deputy Principal - (13.35 SQM)	Office (3)	
B00A - R0011 - Deputy Principal - (15.73 SQM)	Office (3)	
B00A - R0013 - Sick Bay - (8.05 SQM)	Student Space (3)	
B00A - R0032 - Entry Vestibule - (22.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Interview - (16.53 SQM)	Office (4)	
B00A - R0035 - Interview - (10.75 SQM)	Office (2)	
B00A - R0036 - Clerical Office - (48.57 SQM)	Office (12)	
B00A - R0037 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Entry Vestibule - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (23.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Deputy Principal - (25.96 SQM)	Office (6)	
B00B - R0011 - Staff Kitchen - (16.05 SQM)	Office (4)	
B00B - R0012 - Staff Room - (95.44 SQM)	Office (23)	
B00B - R0014 - Staff Room Annexe - (32.55 SQM)	Office (8)	
B00E - R0002 - Practical Activities - 4hb - (62.47 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0007 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Home Base - (57.61 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Withdrawal Space - 1hb - (8.09 SQM)	Student Space (3)	
B00F - R0004 - Home Base - E - (65.7 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0005 - Practical Activities - E - (5.41 SQM)	Student Space (2)	
B00F - R0006 - Home Base - E - (64.18 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0007 - Practical Activities - E - (5.36 SQM)	Student Space (2)	
B00F - R0010 - Practical Activities - E - (6.55 SQM)	Student Space (3)	
B00F - R0012 - Home Base - E - (57.46 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0001 - Home Base - (57.3 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0003 - Practical Activities - 1hb - (6.57 SQM)	Student Space (3)	
B00G - R0005 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0008 - Practical Activities - 1hb - (9.24 SQM)	Student Space (4)	
B00G - R0012 - Home Base - (66.24 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0013 - Practical Activities - 1hb - (5.08 SQM)	Student Space (2)	
B00I - R0004 - Reading Area - (225.34 SQM)	Student Space (104)	
B00J - R0002 - Special Programs Room - (40.51 SQM)	Student Space (18)	
B00K - R0012 - Stage - (39.8 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Communal Space - (224.98 SQM)	Student Space (104)	
B00K - R0023 - Canteen - (47.58 SQM)	Not Applicable	Circulation or storage space.
B00K - R0024 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00K - R0029 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Raised Platform - (45.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0031 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B00K - R0032 - Communal Space - (281.35 SQM)	Student Space (130)	
B00L - R0002 - Practical Activities - 1hb - (19.1 SQM)	Student Space (8)	
B00L - R0004 - Home Base - (59.65 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0005 - Home Base - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0008 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0009 - Home Base - (60.18 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0013 - Practical Activities - 1hb - (19.11 SQM)	Student Space (8)	
B00L - R0014 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B00L - R0015 - Practical Activities - 1hb - (18.65 SQM)	Student Space (8)	
B00L - R0017 - Practical Activities - 1hb - (18.6 SQM)	Student Space (8)	
B00L - R0018 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00M - R0002 - Practical Activities - 1hb - (19.18 SQM)	Student Space (8)	
B00M - R0004 - Home Base - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0005 - Home Base - (59.88 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0008 - Home Base - (59.65 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0009 - Home Base - (59.98 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0013 - Practical Activities - 1hb - (19.13 SQM)	Student Space (8)	
B00M - R0014 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00M - R0015 - Practical Activities - 1hb - (18.76 SQM)	Student Space (8)	
B00M - R0017 - Practical Activities - 1hb - (18.73 SQM)	Student Space (8)	
B00M - R0018 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B00N - R0002 - Practical Activities - 1hb - (19.21 SQM)	Student Space (8)	
B00N - R0004 - Home Base - (61.18 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0005 - Withdrawal Space - 2hb - (11.44 SQM)	Student Space (5)	
B00N - R0006 - Home Base - (61.21 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0008 - Practical Activities - 1hb - (18.43 SQM)	Student Space (8)	
B00O - R0001 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Special Programs Room - (33.12 SQM)	Student Space (15)	
B00O - R0005 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00O - R0008 - Special Programs Room - (33.25 SQM)	Student Space (15)	
B00O - R0010 - Practical Activities - 1hb - (18.7 SQM)	Student Space (8)	
B00O - R0012 - Home Base - (61.25 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0013 - Home Base - (61.08 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0014 - Withdrawal Space - 2hb - (11.75 SQM)	Student Space (5)	
B00O - R0016 - Practical Activities - 1hb - (18.57 SQM)	Student Space (8)	
B00P - R0001 - Practical Activities - (86.22 SQM)	Student Space (40)	
B00P - R0002 - Tiered Learning Space - (64.19 SQM)	Student Space (29)	
B00P - R0003 - Home Base - (21.77 SQM) - Teaching Space: 1	Student Space (10)	
B00P - R0004 - Home Base/Practical Activities - (111.41 SQM) - Teaching Space: 1	Student Space (51)	
B00P - R0005 - Home Base - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R0006 - Special Programs Room - Type 1 - (24.75 SQM)	Student Space (11)	
B00P - R0007 - Home Base - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00P - R0008 - Home Base - (25.16 SQM) - Teaching Space: 1	Student Space (11)	
B00P - R0009 - Home Base - (65.16 SQM) - Teaching Space: 1	Student Space (30)	
B00P - R0010 - Withdrawal Space - 1hb - (9.87 SQM)	Student Space (4)	
B00P - R0011 - Home Base - (58.05 SQM) - Teaching Space: 1	Student Space (26)	
B00P - R0012 - Reading Area - (69.23 SQM)	Student Space (32)	
B00P - R0014 - Special Programs Room - (45.04 SQM)	Student Space (20)	
B00P - R0015 - Presentation Area - (91.29 SQM)	Not Applicable	Circulation or storage space.
B00P - R0016 - Home Base - (59.92 SQM) - Teaching Space: 1	Student Space (27)	
B00P - R0017 - Withdrawal Space - 1hb - (9.89 SQM)	Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0018 - Home Base - (68.01 SQM) - Teaching Space: 1	 Student Space (31)	
B00P - R0019 - Special Programs Room - (26.52 SQM)	 Student Space (12)	
B00P - R0020 - Home Base - (53.08 SQM) - Teaching Space: 1	 Student Space (24)	
B00P - R0021 - Practical Activities - (80.85 SQM)	 Student Space (37)	
B00P - R0048 - Seminar/Study - (46.56 SQM)	 Office (11)	
B00P - R0049 - Outdoor Learning Area - (137 SQM)	Not Applicable	Circulation or storage space.