

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Putney Public School (2913)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Lane Cove</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ryde</b>

2913 - Putney Public School  
Site Plan (10553)

























1:861

Printed: 05-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (8.27 SQM)	Student Space (3)	
B00A - R0003 - Home Base - (38.78 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0004 - Withdrawal Space - 1hb - (25.98 SQM)	Student Space (12)	
B00A - R0005 - Withdrawal Space - 1hb - (21.03 SQM)	Student Space (9)	
B00A - R0006 - Home Base - (35.07 SQM) - Teaching Space: 1	Student Space (16)	
B00A - R0007 - Practical Activities - 1hb - (8.04 SQM)	Student Space (3)	
B00A - R0009 - Home Base - (50.01 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0010 - Practical Activities - 1hb - (22.65 SQM)	Student Space (10)	
B00A - R0011 - Home Base - (48.63 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0012 - Practical Activities - 1hb - (22.02 SQM)	Student Space (10)	
B00A - R0013 - Home Base - (48.3 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0014 - Practical Activities - 1hb - (21.87 SQM)	Student Space (10)	
B00A - R0015 - Home Base - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0016 - Practical Activities - 1hb - (18.94 SQM)	Student Space (8)	
B00A - R0017 - Principal - (14.45 SQM)	Office (3)	
B00A - R0020 - Staff Room - (39.22 SQM)	Office (9)	
B00A - R0022 - Special Programs Room - (22.65 SQM)	Student Space (10)	
B00A - R0025 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (118.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0002 - Home Base - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0003 - Home Base - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0004 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Special Programs Room - (22.17 SQM)	Student Space (10)	
B00B - R0007 - Movement - (69.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Special Programs Room - (46.92 SQM)	Student Space (21)	
B00C - R0002 - Special Programs Room - (46.8 SQM)	Student Space (21)	
B00C - R0003 - Movement - (24.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Withdrawal Space - 1hb - (15.04 SQM)	Student Space (6)	
B00I - R0002 - Clerical Office/Workroom - (27.94 SQM)	Office (6)	
B00I - R0003 - Principal - (14.55 SQM)	Office (3)	
B00I - R0004 - Clerical Office - (11.2 SQM)	Office (2)	
B00I - R0006 - Entry Vestibule - (20.81 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Deputy Principal - (12.74 SQM)	Office (3)	
B00I - R0010 - Sick Bay - (6.94 SQM)	Student Space (3)	
B00I - R0013 - Movement - (15.73 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Movement - (39.34 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Movement - (26.91 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Canteen - (27.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R0021 - Movement - (15.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R0026 - Communal Space - (159.84 SQM)	Student Space (74)	
B00I - R0027 - Raised Platform - (26.55 SQM)	Not Applicable	Circulation or storage space.
B00I - R0029 - Movement - (28.42 SQM)	Not Applicable	Circulation or storage space.
B00I - R1031 - Movement - (28.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R1033 - Movement - (10.52 SQM)	Not Applicable	Circulation or storage space.
B00I - R1043 - Movement - (9.27 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R1044 - Reading Area - (167.1 SQM)	 Student Space (77)	
B00I - R1045 - Special Programs Room - (68.34 SQM)	 Student Space (31)	
B00J - R0001 - Home Base - (57.85 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R0002 - Home Base - (60.06 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0003 - Home Base - (60.15 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0004 - Practical Activities - 1hb - (20.93 SQM)	 Student Space (9)	
B00J - R0005 - Withdrawal Space - 1hb - (9.02 SQM)	 Student Space (4)	
B00J - R0008 - Practical Activities - 1hb - (19.08 SQM)	 Student Space (8)	
B00J - R0009 - Withdrawal Space - 2hb - (11.6 SQM)	 Student Space (5)	
B00J - R0010 - Practical Activities - 1hb - (19.08 SQM)	 Student Space (8)	
B00J - R1001 - Home Base - (57.93 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R1002 - Home Base - (60.31 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1003 - Home Base - (60.16 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R1004 - Practical Activities - 1hb - (20.9 SQM)	 Student Space (9)	
B00J - R1005 - Withdrawal Space - 1hb - (9.13 SQM)	 Student Space (4)	
B00J - R1008 - Practical Activities - 1hb - (18.96 SQM)	 Student Space (8)	
B00J - R1009 - Withdrawal Space - 2hb - (11.57 SQM)	 Student Space (5)	
B00J - R1010 - Practical Activities - 1hb - (18.96 SQM)	 Student Space (8)	
OS 602 15746 - OS 602 15746 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16187 - OS 602 16187 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 15213 - OS 603 15213 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 15499 - OS 603 15499 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	