

VENTILATION AUDIT REPORT

SCHOOL:	Pymble Public School (3777)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3777 - Pymble Public School
Site Plan (10583)
























1:761

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (20.32 SQM)	Office (5)	
B00A - R0005 - Principal - (15.82 SQM)	Office (3)	
B00A - R0012 - Deputy Principal - (12.93 SQM)	Office (3)	
B00A - R0014 - Sick Bay - (9.3 SQM)	Student Space (4)	
B00A - R0015 - Clerical Office - (14.4 SQM)	Office (3)	
B00A - R0016 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Entry Vestibule - (10 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Special Programs Room - (10.06 SQM)	Student Space (4)	
B00A - R0020 - Staff Room - (9.41 SQM)	Office (2)	
B00A - R0023 - Staff Room - (9.8 SQM)	Office (2)	
B00A - R0025 - Staff Room - (45.22 SQM)	Office (11)	
B00A - R0026 - Staff Kitchen - (12.71 SQM)	Office (3)	
B00D - R0001 - Home Base - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0004 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - (57.29 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0006 - Home Base - (65.07 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0007 - Home Base - (65.07 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0013 - Movement - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Special Programs Room - (17.51 SQM)	Student Space (8)	
B00E - R0020 - Home Base - (65.34 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0001 - Home Base - (83.7 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0002 - Withdrawal Space - 1hb - (20.52 SQM)	Student Space (9)	
B00F - R0003 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0007 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R9004 - Interview - (17.75 SQM)	Office (4)	
B00F - R9008 - Home Base - (55.18 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R9009 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R9015 - Special Programs Room - (5.42 SQM)	Student Space (2)	
B00F - R9017 - Movement - (19.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (56.83 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0006 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0009 - Movement - (15.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Home Base - (57.28 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0010 - Staff Kitchen - (9.9 SQM)	Office (2)	
B00I - R0001 - Canteen - (16.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Communal Space - (201.83 SQM)	Student Space (93)	
B00I - R0008 - Raised Platform - (52 SQM)	Not Applicable	Circulation or storage space.
B00I - R9005 - Movement - (35.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Home Base - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0003 - Home Base - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00L - R0001 - Clerical Office/Workroom - (23.84 SQM)	Office (5)	
B00L - R0003 - Special Programs Room - (34.33 SQM)	Student Space (15)	
B00L - R0006 - Reading Area - (131.28 SQM)	Student Space (60)	
B00L - R0007 - Special Programs Room - (27.77 SQM)	Student Space (12)	
B00O - R0001 - Home Base - (58.35 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0002 - Home Base - (61.19 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R0003 - Home Base - (61.34 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R0004 - Home Base - (61.3 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R0005 - Home Base - (61.32 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R0006 - Practical Activities - 1hb - (21.18 SQM)	 Student Space (9)	
B000 - R0007 - Withdrawal Space - 1hb - (9.33 SQM)	 Student Space (4)	
B000 - R0010 - Practical Activities - 1hb - (19.26 SQM)	 Student Space (8)	
B000 - R0011 - Withdrawal Space - 2hb - (11.78 SQM)	 Student Space (5)	
B000 - R0012 - Practical Activities - 1hb - (19.17 SQM)	 Student Space (8)	
B000 - R0015 - Practical Activities - 1hb - (19.24 SQM)	 Student Space (8)	
B000 - R0016 - Withdrawal Space - 2hb - (11.81 SQM)	 Student Space (5)	
B000 - R0017 - Practical Activities - 1hb - (19.14 SQM)	 Student Space (8)	
B00P - R0001 - Practical Activities - (22.47 SQM)	 Student Space (10)	
B00P - R0002 - Home Base - (59.55 SQM) - Teaching Space: 1	 Student Space (27)	
B00P - R0004 - Practical Activities - (22.44 SQM)	 Student Space (10)	
B00P - R0005 - Home Base - (60.54 SQM) - Teaching Space: 1	 Student Space (28)	
OS 602 10825 - OS 602 10825 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 10846 - OS 602 10846 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12596 - OS 602 12596 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13971 - OS 602 13971 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 14896 - OS 603 14896 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	