



VENTILATION AUDIT REPORT

SCHOOL:	Quakers Hill East Public School (4212)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Riverstone
LOCAL GOVERNMENT AREA:	Blacktown

4212 - Quakers Hill East Public School
Site Plan (13590)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Special Programs Room - (15.49 SQM)	Student Space (7)	
B0AA - R0005 - Deputy Principal - (13.58 SQM)	Office (3)	
B0AA - R0006 - Deputy Principal - (13.27 SQM)	Office (3)	
B0AA - R0007 - Interview - (13.19 SQM)	Office (3)	
B0AA - R0009 - Sick Bay - (8.21 SQM)	Student Space (3)	
B0AA - R0013 - Principal - (16.77 SQM)	Office (4)	
B0AA - R0020 - Interview - (16.28 SQM)	Office (4)	
B0AA - R0021 - Interview - (11.91 SQM)	Office (2)	
B0AA - R0022 - Entry Vestibule - (18.88 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0023 - Clerical/Printing - (30.35 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0024 - Clerical Office - (19.45 SQM)	Office (4)	
B0AA - R0025 - Movement - (53.2 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0026 - Deputy Principal - (28.47 SQM)	Office (7)	
B0AA - R0027 - Staff Room - (84.73 SQM)	Office (21)	
B0BB - R0007 - Communal Space - (202.21 SQM)	Student Space (93)	
B0BB - R0008 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B0BB - R0009 - Raised Platform - (53.13 SQM)	Not Applicable	Circulation or storage space.
B0BB - R0010 - Movement - (10.36 SQM)	Not Applicable	Circulation or storage space.
B0BB - R0021 - Canteen - (42.21 SQM)	Not Applicable	Circulation or storage space.
B0CC - R0003 - Practical Activities - 1hb - (20.32 SQM)	Student Space (9)	
B0CC - R0008 - Practical Activities - 1hb - (19.99 SQM)	Student Space (9)	
B0CC - R0010 - Home Base - (58.01 SQM) - Teaching Space: 1	Student Space (26)	
B0CC - R0011 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B0CC - R0012 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B0CC - R0013 - Practical Activities - 1hb - (20.29 SQM)	Student Space (9)	
B0CC - R0018 - Practical Activities - 1hb - (20.24 SQM)	Student Space (9)	
B0CC - R0019 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B0CC - R0020 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B0CC - R0021 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B0CC - R0022 - Practical Activities - 1hb - (20.26 SQM)	Student Space (9)	
B0CC - R0027 - Practical Activities - 1hb - (20.25 SQM)	Student Space (9)	
B0CC - R0028 - Home Base - (57.72 SQM) - Teaching Space: 1	Student Space (26)	
B0CC - R0029 - Withdrawal Space - 2hb - (11.58 SQM)	Student Space (5)	
B0CC - R0030 - Home Base - (57.87 SQM) - Teaching Space: 1	Student Space (26)	
B0DD - R0002 - Practical Activities - 1hb - (20.37 SQM)	Student Space (9)	
B0DD - R0005 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B0DD - R0006 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B0DD - R0007 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B0DD - R0008 - Practical Activities - 1hb - (20.27 SQM)	Student Space (9)	
B0DD - R0011 - Reading Area - (225.77 SQM)	Student Space (104)	
B0EE - R0002 - Practical Activities - 1hb - (20.51 SQM)	Student Space (9)	
B0EE - R0004 - Home Base - (57.63 SQM) - Teaching Space: 1	Student Space (26)	
B0EE - R0005 - Withdrawal Space - 2hb - (11.62 SQM)	Student Space (5)	
B0EE - R0006 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B0EE - R0007 - Practical Activities - 1hb - (20.21 SQM)	Student Space (9)	
B0EE - R0011 - Practical Activities - 1hb - (20.22 SQM)	Student Space (9)	
B0EE - R0012 - Home Base - (57.79 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOEE - R0013 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
BOEE - R0014 - Home Base - (57.79 SQM) - Teaching Space: 1	Student Space (26)	
BOEE - R0015 - Practical Activities - 1hb - (20.38 SQM)	Student Space (9)	
BOEE - R0022 - Practical Activities - 1hb - (20.16 SQM)	Student Space (9)	
BOEE - R0023 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
BOEE - R0024 - Withdrawal Space - 2hb - (11.62 SQM)	Student Space (5)	
BOEE - R0025 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (26)	
BOEE - R0026 - Practical Activities - 1hb - (20.38 SQM)	Student Space (9)	
BOFF - R0004 - Special Programs Room - (42.16 SQM)	Student Space (19)	
BOGG - R0002 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
BOGG - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
BOGG - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
BOGG - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
BOGG - R0008 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
BOHH - R0004 - Practical Activities - (18.68 SQM)	Student Space (8)	
BOHH - R0006 - Home Base - (60.4 SQM) - Teaching Space: 1	Student Space (28)	
BOHH - R0007 - Withdrawal Space - 2hb - (11.2 SQM)	Student Space (5)	
BOHH - R0008 - Home Base - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0010 - Practical Activities - (18.75 SQM)	Student Space (8)	
BOHH - R0011 - Practical Activities - (18.68 SQM)	Student Space (8)	
BOHH - R0013 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
BOHH - R0014 - Withdrawal Space - 2hb - (11.2 SQM)	Student Space (5)	
BOHH - R0015 - Home Base - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0017 - Practical Activities - (18.7 SQM)	Student Space (8)	
BOHH - R0018 - Practical Activities - (18.52 SQM)	Student Space (8)	
BOHH - R0019 - Home Base - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0021 - Withdrawal Space - 1hb - (7.78 SQM)	Student Space (3)	
BOII - R0001 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
BOII - R0002 - Movement - (38.74 SQM)	Not Applicable	Circulation or storage space.
BOII - R0003 - Practical Activities - 3hb - (62.64 SQM)	Student Space (29)	
BOII - R0004 - Special Programs Room - (20.07 SQM)	Student Space (9)	
BOII - R0005 - Presentation Home Base - (81.64 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
BOII - R0006 - Home Base - (55.03 SQM) - Teaching Space: 1	Student Space (25)	
BOII - R0007 - Home Base - (50.67 SQM) - Teaching Space: 1	Student Space (23)	
BOII - R0008 - Presentation Area - (61.62 SQM)	Not Applicable	Circulation or storage space.
BOII - R0009 - Withdrawal Space - 1hb - (9.57 SQM)	Student Space (4)	
BOII - R0016 - Home Base - (54.04 SQM) - Teaching Space: 1	Student Space (25)	
BOII - R0017 - Special Programs Room - Type 1 - (79.96 SQM)	Student Space (37)	
BOII - R0019 - Special Programs Room - Type 1 - (12.96 SQM)	Student Space (6)	
BOII - R0021 - Home Base - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
BOII - R0024 - Outdoor Learning Area - (90.23 SQM)	Not Applicable	Circulation or storage space.
BOII - R0029 - Outdoor Learning Area - (34.54 SQM)	Not Applicable	Circulation or storage space.
BOII - R1001 - Home Base - (58.27 SQM) - Teaching Space: 1	Student Space (27)	
BOII - R1002 - Presentation Home Base - (62.23 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
BOII - R1003 - Practical Activities - 3hb - (62.81 SQM)	Student Space (29)	
BOII - R1004 - Special Programs Room - (22.77 SQM)	Student Space (10)	
BOII - R1005 - Practical Activities - 2hb - (81.82 SQM)	Student Space (37)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0II - R1006 - Home Base - (55.7 SQM) - Teaching Space: 1	● Student Space (25)	
B0II - R1007 - Home Base - (51.43 SQM) - Teaching Space: 1	● Student Space (23)	
B0II - R1008 - Home Base - (64.69 SQM) - Teaching Space: 1	● Student Space (30)	
B0II - R1009 - Withdrawal Space - 1hb - (9.86 SQM)	● Student Space (4)	
B0II - R1016 - Home Base - (54.85 SQM) - Teaching Space: 1	● Student Space (25)	
B0II - R1017 - Special Programs Room - Type 1 - (43.77 SQM)	● Student Space (20)	
B0II - R1019 - Special Programs Room - Type 1 - (11.74 SQM)	● Student Space (5)	
B0II - R1020 - Special Programs Room - Type 1 - (21.56 SQM)	● Student Space (10)	
B0II - R1021 - Special Programs Room - Type 1 - (11.74 SQM)	● Student Space (5)	
B0II - R1023 - Movement - (38.54 SQM)	Not Applicable	Circulation or storage space.