

VENTILATION AUDIT REPORT

| | |
|-------------------------------|--|
| SCHOOL: | Quakers Hill Public School (2918) |
| AMU REGION: | Western Sydney |
| STATE ELECTORATE: | Blacktown |
| LOCAL GOVERNMENT AREA: | Blacktown |

2918 - Quakers Hill Public School
Site Plan (11663)



1:1,461




















Printed: 08-Oct-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Movement - (94.59 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0005 - Canteen - (42.26 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0006 - Communal Space - (186.09 SQM) | ● Student Space (86) | |
| B00A - R0011 - Movement - (6.41 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0012 - Movement - (16.71 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0013 - Raised Platform - (53.16 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0014 - Movement - (6.06 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0019 - Movement - (31.16 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0003 - Movement - (163.37 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0005 - Home Base - (61.41 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00B - R0006 - Practical Activities - 1hb - (49.15 SQM) | ● Student Space (22) | |
| B00B - R0007 - Home Base - (61.38 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00B - R0008 - Withdrawal Space - 1hb - (12.21 SQM) | ● Student Space (5) | |
| B00B - R0012 - Home Base - (61.38 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00B - R0013 - Practical Activities - 1hb - (49.45 SQM) | ● Student Space (22) | |
| B00B - R0014 - Home Base - (61.09 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00B - R0015 - Withdrawal Space - 1hb - (12.2 SQM) | ● Student Space (5) | |
| B00C - R0001 - Home Base - (61.52 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00C - R0002 - Withdrawal Space - 1hb - (12.12 SQM) | ● Student Space (5) | |
| B00C - R0005 - Practical Activities - 1hb - (49.01 SQM) | ● Student Space (22) | |
| B00C - R0006 - Home Base - (60.92 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00C - R0007 - Movement - (70.24 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Movement - (48.91 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0004 - Withdrawal Space - 1hb - (6.52 SQM) | ● Student Space (3) | |
| B00D - R0005 - Home Base - (60.32 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00D - R0006 - Practical Activities - 1hb - (20.83 SQM) | ● Student Space (9) | |
| B00D - R0007 - Practical Activities - 1hb - (20.43 SQM) | ● Student Space (9) | |
| B00D - R0008 - Home Base - (60.42 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00D - R0011 - Withdrawal Space - 1hb - (6.68 SQM) | ● Student Space (3) | |
| B00E - R0001 - Movement - (80.94 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0005 - Withdrawal Space - 1hb - (9.24 SQM) | ● Student Space (4) | |
| B00E - R0006 - Home Base - (60.24 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00E - R0007 - Practical Activities - 1hb - (20.31 SQM) | ● Student Space (9) | |
| B00E - R0008 - Practical Activities - 1hb - (20.42 SQM) | ● Student Space (9) | |
| B00E - R0009 - Home Base - (60.17 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00E - R0011 - Withdrawal Space - 1hb - (6.51 SQM) | ● Student Space (3) | |
| B00F - R0001 - Movement - (152.29 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0005 - Withdrawal Space - 1hb - (6.62 SQM) | ● Student Space (3) | |
| B00F - R0006 - Home Base - (60 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0007 - Practical Activities - 1hb - (21.07 SQM) | ● Student Space (9) | |
| B00F - R0008 - Practical Activities - 1hb - (21.07 SQM) | ● Student Space (9) | |
| B00F - R0009 - Home Base - (59.91 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0010 - Withdrawal Space - 1hb - (13.9 SQM) | ● Student Space (6) | |
| B00F - R0014 - Practical Activities - 1hb - (20.38 SQM) | ● Student Space (9) | |
| B00F - R0015 - Home Base - (59.91 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0016 - Home Base - (60.12 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B00F - R0017 - Practical Activities - 1hb - (20.42 SQM) | ● Student Space (9) | |
| B00F - R0018 - Withdrawal Space - 1hb - (5.77 SQM) | ● Student Space (2) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00F - R0025 - Movement - (7.82 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0009 - Staff Room - (15.72 SQM) | Office (3) | |
| B00H - R0010 - Movement - (11.45 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0016 - Practical Activities - (12.68 SQM) | Student Space (5) | |
| B00H - R0017 - Home Base - (40.66 SQM) - Teaching Space: 1 | Student Space (18) | |
| B00H - R0020 - Practical Activities - (12.86 SQM) | Student Space (5) | |
| B00H - R0021 - Home Base - (41.14 SQM) - Teaching Space: 1 | Student Space (19) | |
| B00I - R0003 - Movement - (19.82 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0005 - Home Base X2 - (90.02 SQM) - Teaching Space: 2 | Student Space (41) | |
| B00J - R0004 - Reading Area - (220.29 SQM) | Student Space (102) | |
| B00J - R0005 - Movement - (14.15 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0006 - Movement - (14.12 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0009 - Special Programs Room - (42.6 SQM) | Student Space (19) | |
| B00J - R0012 - Movement - (55.23 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0001 - Movement - (27.22 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0002 - Duplicating Workroom - (26.84 SQM) | Office (6) | |
| B00K - R0003 - Deputy Principal - (16.05 SQM) | Office (4) | |
| B00K - R0004 - Interview - (14.1 SQM) | Office (3) | |
| B00K - R0005 - Deputy Principal - (12.88 SQM) | Office (3) | |
| B00K - R0006 - Staff Room - (57.92 SQM) | Office (14) | |
| B00K - R0007 - Movement - (28.17 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0008 - Staff Room - (24.17 SQM) | Office (6) | |
| B00K - R0011 - Movement - (27.69 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0015 - Principal - (15.32 SQM) | Office (3) | |
| B00K - R0016 - Sick Bay - (9.18 SQM) | Student Space (4) | |
| B00K - R0017 - Clerical Office - (19.51 SQM) | Office (4) | |
| B00K - R0018 - Movement - (12.82 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0019 - Entry Vestibule - (12.46 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0020 - Movement - (21.74 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0021 - Movement - (43.85 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0001 - Movement - (38.49 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0002 - Practical Activities - 1hb - (19.41 SQM) | Student Space (9) | |
| B00L - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00L - R0005 - Withdrawal Space - 2hb - (11.36 SQM) | Student Space (5) | |
| B00L - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00L - R0008 - Practical Activities - 1hb - (19.41 SQM) | Student Space (9) | |
| B00M - R0001 - Practical Activities - 1hb - (18.91 SQM) | Student Space (8) | |
| B00M - R0003 - Withdrawal Space - 1hb - (11.55 SQM) | Student Space (5) | |
| B00M - R0004 - Practical Activities - 1hb - (18.9 SQM) | Student Space (8) | |
| B00M - R0006 - Home Base - (60.76 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00M - R0007 - Home Base - (60.7 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00N - R0001 - Practical Activities - 1hb - (18.87 SQM) | Student Space (8) | |
| B00N - R0003 - Withdrawal Space - 2hb - (11.51 SQM) | Student Space (5) | |
| B00N - R0004 - Practical Activities - 1hb - (18.81 SQM) | Student Space (8) | |
| B00N - R0006 - Practical Activities - 1hb - (18.93 SQM) | Student Space (8) | |
| B00N - R0008 - Withdrawal Space - 2hb - (11.58 SQM) | Student Space (5) | |
| B00N - R0009 - Practical Activities - 1hb - (18.89 SQM) | Student Space (8) | |
| B00N - R0011 - Home Base - (60.73 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00N - R0012 - Home Base - (60.74 SQM) - Teaching Space: 1 | Student Space (28) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|---------|
| B00N - R0013 - Home Base - (60.73 SQM) - Teaching Space: 1 |  Student Space (28) | |
| B00N - R0014 - Home Base - (60.72 SQM) - Teaching Space: 1 |  Student Space (28) | |
| B00P - R0002 - Home Base - (57.02 SQM) - Teaching Space: 1 |  Student Space (26) | |
| OS 602 11412 - OS 602 11412 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 12580 - OS 602 12580 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 12691 - OS 602 12691 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 12957 - OS 602 12957 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 14598 - OS 602 14598 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 14670 - OS 602 14670 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 14672 - OS 602 14672 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 14716 - OS 602 14716 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 14902 - OS 602 14902 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 15792 - OS 602 15792 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 15859 - OS 602 15859 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 16276 - OS 602 16276 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 602 16840 - OS 602 16840 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |
| OS 606 19009 - OS 606 19009 - Learning Unit - Standard With P.A.A A/C - (76 SQM) |  Student Space (35) | |
| OS 750 11211 - OS 750 11211 - Learning Unit - ESL - (38 SQM) |  Student Space (17) | |
| OS 750 15716 - OS 750 15716 - Learning Unit - ESL - (38 SQM) |  Student Space (17) | |