

VENTILATION AUDIT REPORT

SCHOOL:	Quandialla Public School (2920)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Weddin

2920 - Quandialla Public School
Site Plan (10735)



1:1,256

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (25.84 SQM)	● Student Space (11)	
B00A - R0003 - Reading Area - (83.5 SQM)	● Student Space (38)	
B00A - R0010 - Duplicating Workroom - (12.64 SQM)	● Office (3)	
B00A - R0011 - Principal - (18.38 SQM)	● Office (4)	
B00A - R0013 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Clerical Office - (31.82 SQM)	● Office (7)	
B00B - R0002 - Communal Space - (71.79 SQM)	● Student Space (33)	
B00B - R0003 - Raised Platform - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (67.07 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0005 - Home Base - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0002 - General Learning Space - (56.42 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0007 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0008 - Withdrawal Space - 1hb - (27.6 SQM)	● Student Space (12)	
B00E - R0001 - Staff Room - (39.07 SQM)	● Office (9)	
B00E - R0005 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Room Annexe - (20.63 SQM)	● Office (5)	
B00E - R0008 - Staff Room Annexe - (12.64 SQM)	● Office (3)	
B00E - R0009 - Preparation - (12.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Laboratory L.S. - (65.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0012 - Art Learning Space - (65.59 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0014 - Seminar/Study - (8.38 SQM)	● Office (2)	
B00E - R0017 - Food Technology L.S. - (65.82 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0018 - Canteen - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - General Learning Space - (46.36 SQM) - Teaching Space: 1	● Student Space (21)	
B00K - R0001 - Workshop Area - (62.81 SQM)	● Student Space (29)	
B00K - R0004 - Welding/Hot Metals Area - (11.8 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Gymnasium - (686.07 SQM)	● Student Space (318)	