

VENTILATION AUDIT REPORT

SCHOOL:	Queanbeyan East Public School (4371)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Queanbeyan-Palerang

4371 - Queanbeyan East Public School
Site Plan (11534)








1:1,054

Printed: 19-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (18.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (16.55 SQM)	Office (4)	
B00A - R0005 - Staff Room - (40.02 SQM)	Office (10)	
B00A - R0013 - Sick Bay - (8.8 SQM)	Student Space (4)	
B00A - R0016 - Interview - (8.85 SQM)	Office (2)	
B00A - R0018 - Staff Room Annexe - (11.41 SQM)	Office (2)	
B00A - R0019 - Staff Room Annexe - (11.7 SQM)	Office (2)	
B00A - R0020 - Principal - (17.51 SQM)	Office (4)	
B00A - R0028 - Movement - (138.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (21.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Clerical/Printing - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Sick Bay - (8.12 SQM)	Student Space (3)	
B00A - R0033 - Entry Vestibule - (22.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Reading Area - (126.26 SQM)	Student Space (58)	
B00B - R0004 - Movement - (56.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (44.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (88.44 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0010 - Home Base - (59.14 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Movement - (28.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R9003 - Communal Space - (123.89 SQM)	Student Space (57)	
B00F - R0001 - Communal Space - (143.99 SQM)	Student Space (66)	
B00F - R0002 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Raised Platform - (62.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Canteen - (25.79 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0002 - Home Base - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0003 - Special Programs Room - (13.84 SQM)	Student Space (6)	
B00G - R0005 - Entry Vestibule - (10.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Special Programs Room - (11.9 SQM)	Student Space (5)	
B00G - R0007 - Home Base - (59.73 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0008 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0009 - Home Base - (59.81 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0010 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0011 - Home Base - (59.12 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0012 - Home Base - (60 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0013 - Special Programs Room - (13.93 SQM)	Student Space (6)	
B00G - R0015 - Special Programs Room - (68.12 SQM)	Student Space (31)	
B00G - R0016 - Home Base - (61.13 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0017 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0018 - Home Base - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0023 - Practical Activities/Movement - 4hb - (102.78 SQM)	Student Space (47)	
B00G - R0024 - Withdrawal Space - 1hb - (10.67 SQM)	Student Space (4)	
B00G - R0026 - Tiered Learning Space - (44.55 SQM)	Student Space (20)	
B00G - R0027 - Movement - (93.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Practical Activities/Movement - 4hb - (172.27 SQM)	Student Space (79)	
B00G - R0029 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0035 - Special Programs Room - (11.41 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0036 - Special Programs Room - (11.34 SQM)	 Student Space (5)	
OS 603 12621 - OS 603 12621 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 14753 - OS 606 14753 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19056 - OS 606 19056 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19145 - OS 606 19145 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	