

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Queanbeyan Public School (2922)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Monaro</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Queanbeyan-Palerang</b>

2922 - Queanbeyan Public School  
Site Plan (11847)



1:1,035

Printed: 23-Feb-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (50.09 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Practical Activities - 1hb - (9.37 SQM)	● Student Space (4)	
B00A - R0003 - Movement - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (45.54 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0005 - Practical Activities - 1hb - (15.2 SQM)	● Student Space (7)	
B00A - R0006 - Staff Room Annexe - (10.99 SQM)	● Office (2)	
B00A - R0007 - Interview - (20.51 SQM)	● Office (5)	
B00A - R0009 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (60.89 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0011 - Practical Activities - 1hb - (24.99 SQM)	● Student Space (11)	
B00A - R0014 - Home Base - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0015 - Practical Activities - 1hb - (28.32 SQM)	● Student Space (13)	
B00B - R0006 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0020 - Home Base - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0021 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0024 - Movement - (187.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Practical Activities - (12.58 SQM)	● Student Space (5)	
B00B - R0026 - Practical Activities - (19.26 SQM)	● Student Space (8)	
B00B - R0027 - Practical Activities - (19.52 SQM)	● Student Space (9)	
B00B - R0028 - Home Base - (44.87 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0029 - Home Base - (66.82 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0030 - Home Base - (66.52 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0004 - Sick Bay - (12.1 SQM)	● Student Space (5)	
B00C - R0019 - Principal - (17.25 SQM)	● Office (4)	
B00C - R0020 - Deputy Principal - (12.63 SQM)	● Office (3)	
B00C - R0021 - Entry Vestibule - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (143.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Clerical Office - (25.37 SQM)	● Office (6)	
B00C - R0032 - Movement - (34.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Deputy Principal - (15.87 SQM)	● Office (3)	
B00C - R0035 - Staff Room - (18.17 SQM)	● Office (4)	
B00C - R0036 - Staff Room - (74.33 SQM)	● Office (18)	
B00C - R0037 - Staff Kitchen - (13.89 SQM)	● Office (3)	
B00C - R0039 - Duplicating Workroom - (28.3 SQM)	● Office (7)	
B00C - R0040 - Movement - (8.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Seminar/Study - (8.67 SQM)	● Office (2)	
B00D - R0005 - Seminar/Study - (8.73 SQM)	● Office (2)	
B00D - R0006 - Reading Area - (174.77 SQM)	● Student Space (81)	
B00D - R0009 - Movement - (10.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (123.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Withdrawal Space - 1hb - (12.12 SQM)	● Student Space (5)	
B00E - R0003 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (24.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (22.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Home Base - (47.04 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0019 - Home Base - (47.02 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0020 - Movement - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Home Base - (54.62 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0024 - Movement - (22.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Home Base - (47.1 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0028 - Withdrawal Space - 1hb - (16.11 SQM)	● Student Space (7)	
B00E - R0029 - Home Base - (46.74 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0030 - Home Base - (46.84 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0032 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Home Base - (46.71 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1004 - Home Base - (46.72 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1005 - Withdrawal Space - 1hb - (39.11 SQM)	● Student Space (18)	
B00E - R1006 - Home Base - (46.96 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1007 - Home Base - (46.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1008 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Special Programs Room - (16.55 SQM)	● Student Space (7)	
B00E - R1010 - Movement - (76.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Withdrawal - M - (17.23 SQM)	● Student Space (7)	
B00F - R0001 - Canteen - (36.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Raised Platform - (63.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Communal Space - (282.64 SQM)	● Student Space (131)	
B00F - R0015 - Movement - (205.6 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - (19.38 SQM)	● Student Space (8)	
B00N - R0004 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0005 - Withdrawal - M - (11.67 SQM)	● Student Space (5)	
B00N - R0006 - Home Base - (60.82 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0008 - Practical Activities - (19.6 SQM)	● Student Space (9)	
B00N - R0009 - Practical Activities - (21.33 SQM)	● Student Space (9)	
B00N - R0010 - Special Programs Room - (8.62 SQM)	● Student Space (3)	
B00N - R0012 - Home Base - (56.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00O - R0002 - Practical Activities - (19.18 SQM)	● Student Space (8)	
B00O - R0004 - Home Base - (48.89 SQM) - Teaching Space: 1	● Student Space (22)	
B00O - R0006 - Home Base - (48.74 SQM) - Teaching Space: 1	● Student Space (22)	
B00O - R0008 - Practical Activities - (19.19 SQM)	● Student Space (8)	
OS 534 10400 - OS 534 10400 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 13435 - OS 601 13435 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13614 - OS 601 13614 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13683 - OS 601 13683 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13879 - OS 601 13879 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14362 - OS 601 14362 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10806 - OS 602 10806 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13017 - OS 602 13017 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	