

VENTILATION AUDIT REPORT

SCHOOL:	Queanbeyan South Public School (4394)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Queanbeyan-Palerang

4394 - Queanbeyan South Public School
Site Plan (12560)



1:1,858




Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (12.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (23.72 SQM)	Office (5)	
B00A - R0004 - Deputy Principal - (14.27 SQM)	Office (3)	
B00A - R0007 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Clerical Office/Workroom - (22.81 SQM)	Office (5)	
B00A - R0017 - Staff Room Annexe - (13.1 SQM)	Office (3)	
B00A - R0018 - Staff Room Annexe - (15.08 SQM)	Office (3)	
B00A - R0021 - Principal - (18.57 SQM)	Office (4)	
B00A - R0022 - Staff Room Annexe - (12.28 SQM)	Office (3)	
B00A - R0025 - Movement - (26.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Room - (57.41 SQM)	Office (14)	
B00A - R0031 - Staff Kitchen - (7.45 SQM)	Office (1)	
B00A - R0032 - Movement - (36.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Clerical Office - (8.99 SQM)	Office (2)	
B00A - R0035 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Reading Area - (52.9 SQM)	Student Space (24)	
B00A - R1005 - Reading Area - (212.18 SQM)	Student Space (98)	
B00A - R1006 - Seminar/Study - (12.63 SQM)	Office (3)	
B00A - R1012 - Movement - (31.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Interview - (6.41 SQM)	Office (1)	
B00A - R1017 - Interview - (5.93 SQM)	Office (1)	
B00A - R1018 - Movement - (16.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Home Base - (57.25 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0007 - Home Base - (57.48 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0010 - Practical Activities - 2hb - (12 SQM)	Student Space (5)	
B00B - R0011 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (47.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (26.99 SQM)	Student Space (12)	
B00C - R0008 - Movement - (22.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (76.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Home Base - Pre - (69.22 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R0001 - Movement - (89.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (12.41 SQM)	Student Space (5)	
B00E - R0003 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Home Base - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Practical Activities - 1hb - (12.42 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (85.58 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0007 - Practical Activities - 1hb - (11.48 SQM)	Student Space (5)	
B00E - R0010 - Practical Activities - 1hb - (12.36 SQM)	Student Space (5)	
B00E - R0011 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0012 - Home Base - (59.59 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0013 - Practical Activities - 1hb - (12.41 SQM)	Student Space (5)	
B00E - R0014 - Movement - (8.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0017 - Movement - (6.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (87.04 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0005 - Home Base - (56.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0009 - Home Base - (56.84 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Home Base - (86.8 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0014 - Movement - (80.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00H - M0001 - Movement - (15.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (197.06 SQM)	● Student Space (91)	
B00H - R0012 - Canteen - (32.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (48.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (71.69 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (13.42 SQM)	● Student Space (6)	
B00I - R0002 - Home Base - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0003 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Withdrawal Space - 1hb - (18.26 SQM)	● Student Space (8)	
B00I - R0008 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Home Base - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0010 - Practical Activities - 1hb - (13.43 SQM)	● Student Space (6)	
B00I - R0011 - Movement - (62.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Practical Activities - 1hb - (13.42 SQM)	● Student Space (6)	
B00J - R0002 - Home Base - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Withdrawal Space - 1hb - (18.26 SQM)	● Student Space (8)	
B00J - R0008 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Home Base - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0010 - Practical Activities - 1hb - (13.43 SQM)	● Student Space (6)	
B00J - R0013 - Movement - (62.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - 1hb - (13.43 SQM)	● Student Space (6)	
B00K - R0002 - Home Base - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0003 - Movement - (12.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Withdrawal Space - 1hb - (18.26 SQM)	● Student Space (8)	
B00K - R0008 - Movement - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Home Base - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0010 - Practical Activities - 1hb - (13.43 SQM)	● Student Space (6)	
B00K - R0011 - Movement - (62.6 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (86.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Home Base - (65.82 SQM) - Teaching Space: 1	● Student Space (30)	
B00L - R0004 - Home Base - (65.82 SQM) - Teaching Space: 1	● Student Space (30)	
B00L - R0005 - Home Base - (62.86 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R1002 - Home Base - (64.33 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R1003 - Home Base - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00L - R1004 - Home Base - (63.03 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R1005 - Home Base - (61.46 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R1006 - Movement - (71.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Staff Room - (51.89 SQM)	● Office (12)	
B00M - R0003 - Movement - (45.94 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0005 - Staff Room Annexe - (15.65 SQM)	 Office (3)	
B00M - R0006 - Movement - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00M - R0007 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Home Base - (47.45 SQM) - Teaching Space: 1	 Student Space (22)	
B00P - R0001 - Communal Space - (198.45 SQM)	 Student Space (92)	
B00P - R0002 - Raised Platform - (53.95 SQM)	Not Applicable	Circulation or storage space.
B00P - R0016 - Movement - (8.49 SQM)	Not Applicable	Circulation or storage space.
B00P - R0018 - Movement - (18.1 SQM)	Not Applicable	Circulation or storage space.