


VENTILATION AUDIT REPORT

SCHOOL:	Queanbeyan West Public School (4127)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Queanbeyan-Palerang

4127 - Queanbeyan West Public School
Site Plan (11235)



1:1,250

Printed: 15-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Duplicating Workroom - (14.22 SQM)	Office (3)	
B00A - R0003 - Clerical Office - (10.15 SQM)	Office (2)	
B00A - R0008 - Deputy Principal - (17.13 SQM)	Office (4)	
B00A - R0009 - Principal - (16.95 SQM)	Office (4)	
B00A - R0010 - Staff Room Annexe - (13.39 SQM)	Office (3)	
B00A - R0015 - Movement - (35.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Clerical Office - (18.44 SQM)	Office (4)	
B00A - R0019 - Staff Room - (54.14 SQM)	Office (13)	
B00A - R0020 - Staff Kitchen - (8.61 SQM)	Office (2)	
B00B - R0001 - Movement - (52.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (87.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0006 - Home Base - (67.27 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0009 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - Home Base - (53.52 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Movement - (8.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.87 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (85.27 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0012 - Withdrawal Space - 1hb - (17.82 SQM)	Student Space (8)	
B00C - R0014 - Movement - (46.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Special Programs Room - (6.3 SQM)	Student Space (2)	
B00D - R0004 - Withdrawal Space - 1hb - (10.24 SQM)	Student Space (4)	
B00D - R0005 - Special Programs Room - (10 SQM)	Student Space (4)	
B00D - R0007 - Movement - (18.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (87.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Practical Activities - 1hb - (20.75 SQM)	Student Space (9)	
B00E - R0004 - Home Base - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0005 - Home Base - (53.95 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0006 - Practical Activities - 1hb - (20.75 SQM)	Student Space (9)	
B00E - R0011 - Movement - (28.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (82.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (20.5 SQM)	Student Space (9)	
B00F - R0003 - Home Base - (51.03 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0004 - Home Base - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0005 - Practical Activities - 1hb - (20.5 SQM)	Student Space (9)	
B00F - R0006 - Practical Activities - 1hb - (20.5 SQM)	Student Space (9)	
B00F - R0007 - Home Base - (50.26 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0008 - Home Base - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0009 - Practical Activities - 1hb - (20.57 SQM)	Student Space (9)	
B00G - R0004 - Movement - (64.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Practical Activities - 1hb - (20.55 SQM)	Student Space (9)	
B00G - R0010 - Home Base - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0011 - Home Base - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0012 - Practical Activities - 1hb - (20.55 SQM)	Student Space (9)	
B00H - R0003 - Movement - (24.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Canteen - (20.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Communal Space - (157.21 SQM)	Student Space (72)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0015 - Movement - (122.69 SQM)	Not Applicable	Circulation or storage space.
B00O - R0006 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Reading Area - (169.47 SQM)	● Student Space (78)	
OS 601 13673 - OS 601 13673 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10130 - OS 602 10130 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10156 - OS 602 10156 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11507 - OS 602 11507 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11579 - OS 602 11579 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14197 - OS 602 14197 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15191 - OS 602 15191 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10079 - OS 603 10079 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19798 - OS 606 19798 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	