

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Rainbow Street Public School (2930)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Coogee</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Randwick</b>

2930 - Rainbow Street Public School  
Site Plan (10522)



1:1,926







Printed: 07-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0041 - Entry Vestibule - (40.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Interview - (12.25 SQM)	Office (3)	
B00A - R0043 - Interview - (13.36 SQM)	Office (3)	
B00A - R0044 - Deputy Principal - Type 2 - (16.65 SQM)	Office (4)	
B00A - R0045 - Clerical Office/Workroom - (13.82 SQM)	Office (3)	
B00A - R0046 - Deputy Principal - (15.08 SQM)	Office (3)	
B00A - R0047 - Deputy Principal - Type 2 - (31.41 SQM)	Office (7)	
B00A - R0048 - Staff Room Annexe - (25.5 SQM)	Office (6)	
B00A - R0050 - Staff Room - (93.6 SQM)	Office (23)	
B00A - R0052 - Principal - (32.05 SQM)	Office (8)	
B00A - R0053 - Staff Kitchen - (17.43 SQM)	Office (4)	
B00A - R0055 - Movement - (54.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Sick Bay - (10.49 SQM)	Student Space (4)	
B00A - R0058 - Clerical Office - (60.44 SQM)	Office (15)	
B00A - R0060 - Clerical Office - (25.23 SQM)	Office (6)	
B00A - R0061 - Movement - (30.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1041 - Home Base - (66.45 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1042 - Home Base - (49.61 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1043 - Home Base - (58.49 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1044 - Home Base - (50.39 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1045 - Home Base - (52.5 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1048 - Withdrawal Space - 1hb - (12.03 SQM)	Student Space (5)	
B00A - R1050 - Withdrawal Space - 1hb - (11.78 SQM)	Student Space (5)	
B00A - R1054 - Movement - (100.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1057 - Home Base/Practical Activities - (93.34 SQM) - Teaching Space: 1	Student Space (43)	
B00I - R0002 - Raised Platform - (64.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (9.51 SQM)	Not Applicable	Circulation or storage space.
B00I - R0027 - Movement - (12.97 SQM)	Not Applicable	Circulation or storage space.
B00I - R0030 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00I - R0033 - Canteen - (52.68 SQM)	Not Applicable	Circulation or storage space.
B00I - R0034 - Movement - (10.72 SQM)	Not Applicable	Circulation or storage space.
B00I - R0036 - Communal Space - (213.09 SQM)	Student Space (98)	
B00J - R0001 - Home Base - (62.41 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0002 - Withdrawal Space - 1hb - (9.56 SQM)	Student Space (4)	
B00J - R0003 - Practical Activities - 2hb - (41.2 SQM)	Student Space (19)	
B00J - R0006 - Home Base - (63.04 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0007 - Withdrawal Space - 1hb - (10.78 SQM)	Student Space (5)	
B00J - R0011 - Home Base X2 - (129.44 SQM) - Teaching Space: 2	Student Space (60)	
B00J - R0013 - Withdrawal Space - 2hb - (12.27 SQM)	Student Space (5)	
B00J - R0014 - Practical Activities - 4hb - (46.7 SQM)	Student Space (21)	
B00J - R0015 - Presentation Area - (43.3 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Home Base X2 - (123.03 SQM) - Teaching Space: 2	Student Space (57)	
B00J - R0018 - Withdrawal Space - 2hb - (11.65 SQM)	Student Space (5)	
B00J - R0020 - Home Base X2 - (128.72 SQM) - Teaching Space: 2	Student Space (59)	
B00J - R0022 - Withdrawal Space - 2hb - (11.91 SQM)	Student Space (5)	
B00J - R0023 - Practical Activities - 4hb - (46.82 SQM)	Student Space (21)	
B00J - R0024 - Presentation Area - (44.61 SQM)	Not Applicable	Circulation or storage space.
B00J - R0025 - Home Base X2 - (130.86 SQM) - Teaching Space: 2	Student Space (60)	
B00J - R0027 - Withdrawal Space - 2hb - (11.91 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0031 - Withdrawal Space - 1hb - (9.35 SQM)	Student Space (4)	
B00J - R0032 - Home Base - (62.37 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0034 - Practical Activities - 2hb - (40.5 SQM)	Student Space (18)	
B00J - R0035 - Home Base - (62.39 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0036 - Withdrawal Space - 1hb - (9 SQM)	Student Space (4)	
B00J - R1001 - Home Base X2 - (128.86 SQM) - Teaching Space: 2	Student Space (59)	
B00J - R1003 - Withdrawal Space - 1hb - (12.09 SQM)	Student Space (5)	
B00J - R1004 - Practical Activities - 4hb - (58.53 SQM)	Student Space (27)	
B00J - R1005 - Presentation Area - (44.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R1006 - Home Base X2 - (128.96 SQM) - Teaching Space: 2	Student Space (59)	
B00J - R1008 - Withdrawal Space - 2hb - (12 SQM)	Student Space (5)	
B00J - R1013 - Movement - (75.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - Practical Activities - 4hb - (44.75 SQM)	Student Space (20)	
B00J - R1015 - Home Base X3 - (173.06 SQM) - Teaching Space: 3	Student Space (80)	
B00J - R1017 - Withdrawal Space - 1hb - (9.01 SQM)	Student Space (4)	
B00J - R1018 - Presentation Area - (39.71 SQM)	Not Applicable	Circulation or storage space.
B00J - R1019 - Withdrawal Space - 2hb - (12 SQM)	Student Space (5)	
B00J - R1020 - Practical Activities - 4hb - (42.82 SQM)	Student Space (19)	
B00J - R1021 - Home Base X3 - (172.91 SQM) - Teaching Space: 3	Student Space (80)	
B00J - R1023 - Presentation Area - (39.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R1024 - Withdrawal Space - 2hb - (11.83 SQM)	Student Space (5)	
B00J - R1025 - Withdrawal Space - 2hb - (10.32 SQM)	Student Space (4)	
B00J - R1026 - Movement - (101.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R1030 - Practical Activities - 4hb - (44.46 SQM)	Student Space (20)	
B00J - R1031 - Home Base X3 - (168.69 SQM) - Teaching Space: 3	Student Space (78)	
B00J - R1033 - Presentation Area - (40.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R1034 - Withdrawal Space - 2hb - (11.92 SQM)	Student Space (5)	
B00J - R1035 - Withdrawal Space - 2hb - (9.21 SQM)	Student Space (4)	
B00J - R1038 - Movement - (96.17 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base X4 - (260.1 SQM) - Teaching Space: 4	Student Space (120)	
B00K - R0002 - Practical Activities - 4hb - (49.16 SQM)	Student Space (22)	
B00K - R0006 - Withdrawal Space - 2hb - (13.13 SQM)	Student Space (6)	
B00K - R0007 - Presentation Area - (48.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Withdrawal Space - 2hb - (12.68 SQM)	Student Space (5)	
B00K - R1001 - Practical Activities - 2hb - (47.1 SQM)	Student Space (21)	
B00K - R1002 - Home Base X3 - (166.33 SQM) - Teaching Space: 3	Student Space (77)	
B00K - R1004 - Withdrawal Space - 2hb - (13.1 SQM)	Student Space (6)	
B00K - R1006 - Presentation Area - (39.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R1007 - Withdrawal Space - 1hb - (9.4 SQM)	Student Space (4)	
B00K - R1008 - Withdrawal Space - 1hb - (9.43 SQM)	Student Space (4)	
B00K - R1009 - Presentation Area - (39.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R1011 - Withdrawal Space - 2hb - (12.59 SQM)	Student Space (5)	
B00K - R1012 - Home Base X3 - (167.85 SQM) - Teaching Space: 3	Student Space (77)	
B00K - R1013 - Practical Activities - 3hb - (50.44 SQM)	Student Space (23)	
B00L - R0001 - Reading Area - (183.13 SQM)	Student Space (84)	
B00L - R0006 - Entry Vestibule - (7.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Seminar/Study - (25.5 SQM)	Office (6)	
B00L - R1001 - Reading Area - (91.74 SQM)	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1002 - Special Programs Room - Type 1 - (32.53 SQM)	 Student Space (15)	
B00L - R1003 - Special Programs Room - Type 1 - (33.13 SQM)	 Student Space (15)	
B00L - R1004 - Special Programs Room - (23.95 SQM)	 Student Space (11)	
B00L - R1005 - Special Programs Room - (21.11 SQM)	 Student Space (9)	
B00L - R1006 - Special Programs Room - Type 2 - (17.25 SQM)	 Student Space (8)	
B00L - R1007 - Special Programs Room - Type 2 - (18.78 SQM)	 Student Space (8)	
B00L - R1011 - Movement - (11.98 SQM)	Not Applicable	Circulation or storage space.