

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Randwick Boys High School (8161)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Coogee</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Randwick</b>

8161 - Randwick Boys High School  
Site Plan (10522)



1:1,927

Printed: 20-Apr-2020








## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (18.69 SQM)	Office (4)	
B00A - R0005 - Interview/Office - Type 1 - (13.57 SQM)	Office (3)	
B00A - R0006 - Duplicating Workroom - (25.96 SQM)	Office (6)	
B00A - R0007 - Leading Teacher - (12.9 SQM)	Office (3)	
B00A - R0009 - Senior Study - (59.22 SQM)	Office (14)	
B00A - R0011 - Senior Seminar - (13.16 SQM)	Office (3)	
B00A - R0012 - Interview/Office - Type 1 - (12.8 SQM)	Office (3)	
B00A - R0014 - Deputy Principal Office - (12.75 SQM)	Office (3)	
B00A - R0025 - Movement - (105.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Staff Kitchen - (7.54 SQM)	Office (1)	
B00A - R0031 - Pupil Entry - (23.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Administration - Clerical - (85.97 SQM)	Office (21)	
B00A - R0033 - Outdoor Learning Area - (164.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Staff Study - (12.54 SQM)	Office (3)	
B00A - R1020 - Commonroom - (108.58 SQM)	Office (27)	
B00A - R1021 - Staff Study - (152.17 SQM)	Office (38)	
B00A - R1023 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (48.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Staff Study - (45.81 SQM)	Office (11)	
B00A - R1026 - Staff Study - (122.63 SQM)	Office (30)	
B00A - R1028 - Movement - (20.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Staff Study - (77.32 SQM)	Office (19)	
B00A - R1030 - Movement - (39.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R1031 - Interview/Office - Type 1 - (14.7 SQM)	Office (3)	
B00B - R0006 - Main Area - (231.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Workroom - (50.1 SQM)	Office (12)	
B00B - R0012 - Movement - (45.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Audio Visual Workroom - (48.35 SQM)	Student Space (22)	
B00B - R1001 - Main Area - (111.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Main Area - (121.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Seminar - (16.12 SQM)	Office (4)	
B00B - R1005 - Seminar - (16.33 SQM)	Office (4)	
B00B - R1006 - Seminar - (16.45 SQM)	Office (4)	
B00B - R1007 - Seminar - (16.33 SQM)	Office (4)	
B00B - R1008 - Seminar - (16.16 SQM)	Office (4)	
B00C - R0001 - Gymnasium - (525.46 SQM)	Student Space (243)	
B00C - R0004 - Staff Study - (15.82 SQM)	Office (3)	
B00C - R0008 - Student Canteen - (5.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (77.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (87.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (77.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Study Space - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - General Learning Space - (47.18 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1005 - General Learning Space - (47.33 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1008 - General Learning Space - (47.46 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1009 - General Learning Space - (47.25 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1011 - Study Space - (16.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (21.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (18.5 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0004 - Serviced Learning Space - (53.96 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0005 - General Learning Space - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0006 - General Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0011 - Laboratory L.S. - (86.78 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0012 - Preparation - (33.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Laboratory L.S. - (87.37 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0015 - Movement - (14.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (18.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (134.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Movement - (138.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - Staff Study - (25.26 SQM)	● Office (6)	
B00D - R1006 - General Learning Space - (54.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1007 - General Learning Space - (56.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1010 - General Learning Space - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1013 - General Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1014 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1015 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - Movement - (11.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (119.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (18.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Study - (26.36 SQM)	● Office (6)	
B00E - R0010 - Laboratory L.S. - (93.04 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0013 - Laboratory L.S. - (92.92 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0019 - Gymnasium - (79.74 SQM)	● Student Space (36)	
B00E - R0020 - Preparation - Science - (31.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Movement - (117.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Staff Study - (26.15 SQM)	● Office (6)	
B00E - R1008 - General Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1009 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1010 - Computer Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1013 - Computer Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1014 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1015 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1017 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R1019 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (18.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Laboratory L.S. - (85.45 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0007 - Preparation - (23.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Laboratory L.S. - (87.09 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0011 - Movement - (76.59 SQM)	Not Applicable	Circulation or storage space.
B00F - R1004 - Movement - (69.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Staff Study - (28.6 SQM)	● Office (7)	
B00F - R1006 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R1009 - General Learning Space - (51.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R1010 - General Learning Space - (56.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R1012 - Movement - (11.8 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Materials Technology L.S. - (91.63 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0002 - Metal Technology Bay - (34.76 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Materials Technology L.S. - (89.55 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0004 - Materials Technology L.S. - (93.16 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0005 - Wood Technology Bay - (33.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Materials Technology L.S. - (90.17 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0010 - Movement - (286.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Materials Technology L.S. - (90.44 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0014 - Wood Technology Bay - (34.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Materials Technology L.S. - (90.35 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0019 - Staff Study - (26.09 SQM)	● Office (6)	
B00G - R0020 - Interview/Office - Type 1 - (16.07 SQM)	● Office (4)	
B00G - R0023 - Workshop Area - (58.24 SQM)	● Student Space (27)	
B00G - R0024 - Welding Area - (12.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Movement - (90.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Design L.S. - (55.4 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R1005 - Design L.S. - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R1006 - Art Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1007 - Art Learning Space - (60.96 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1009 - Movement - (248.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Art Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1013 - Art Learning Space - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R1014 - Darkroom Space - (27.85 SQM)	● Office (6)	
B00G - R1015 - Design L.S. - (97.67 SQM) - Teaching Space: 1	● Student Space (45)	
B00G - R1017 - Staff Study - (24.36 SQM)	● Office (6)	
B00G - R1018 - Computer Learning Space - (59.87 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1021 - Interview/Office - Type 1 - (13.93 SQM)	● Office (3)	
B00H - R0003 - Multi-Purpose Space - (414.61 SQM)	● Student Space (192)	
B00H - R0006 - Staff Kitchen - (10.37 SQM)	● Office (2)	
B00H - R0008 - Movement - (14.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Stage - (89.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Senior Study - (57.73 SQM)	● Office (14)	
B00I - R0004 - General Learning Space - (57.68 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0005 - Practice/Seminar - (19.83 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (27.88 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Performance Workspace - (98.27 SQM) - Teaching Space: 1	● Student Space (45)	
B00I - R0009 - General Learning Space - (57.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0010 - Staff Study - (31.67 SQM)	● Office (7)	
B00I - R0011 - Senior Study - (57.54 SQM)	● Office (14)	
B00I - R0012 - Movement - (234.97 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - General Learning Space - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0014 - General Learning Space - (58.37 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0015 - General Learning Space - (98.18 SQM) - Teaching Space: 1	● Student Space (45)	
B00I - R0026 - Practice/Seminar - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00I - R0027 - Music Learning Space - (98.38 SQM) - Teaching Space: 1	● Student Space (45)	
B00I - R0028 - General Learning Space - (57.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0029 - General Learning Space - (59.04 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0030 - Movement - (9.93 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0003 - Student Canteen - (53.66 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Movement - (27.23 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Staff Study - (14.58 SQM)	 Office (3)	
B00K - R0007 - Staff Study - (17.53 SQM)	 Office (4)	
B00K - R0008 - General Assistants - (13.07 SQM)	 Office (3)	
B00K - R0011 - Music Learning Space - (78.05 SQM) - Teaching Space: 1	 Student Space (36)	
B00K - R0012 - Staff Study - (25.75 SQM)	 Office (6)	
B00K - R0014 - Practice/Seminar - (25.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Music Learning Space - (60.75 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0016 - Movement - (52.25 SQM)	Not Applicable	Circulation or storage space.
B00K - R0017 - Movement - (25.63 SQM)	Not Applicable	Circulation or storage space.
OS 710 15773 - OS 710 15773 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	