

VENTILATION AUDIT REPORT

SCHOOL:	Raymond Terrace Public School (2943)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

2943 - Raymond Terrace Public School
Site Plan (10724)



1:1,069

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (47.99 SQM)	Office (11)	
B00A - R0003 - Staff Room Annexe - (31.54 SQM)	Office (7)	
B00A - R0006 - Withdrawal Space - 1hb - (15.6 SQM)	Student Space (7)	
B00A - R0007 - Practical Activities - 1hb - (35.66 SQM)	Student Space (16)	
B00A - R0008 - Home Base - (46.9 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0009 - Home Base - (47.15 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0011 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (71.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (78.6 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0006 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Interview - (13.82 SQM)	Office (3)	
B00B - R0012 - Movement - (28.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Deputy Principal - (13.89 SQM)	Office (3)	
B00B - R0016 - Principal - (18.06 SQM)	Office (4)	
B00B - R0017 - Duplicating Workroom - (22.41 SQM)	Office (5)	
B00B - R0019 - Clerical Office - (17.79 SQM)	Office (4)	
B00B - R0020 - Entry Vestibule - (9.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Interview - (14.02 SQM)	Office (3)	
B00B - R0025 - Sick Bay - (13.01 SQM)	Student Space (6)	
B00B - R0027 - Movement - (45.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (45.46 SQM)	Student Space (21)	
B00C - R0005 - Reading Area - (170.24 SQM)	Student Space (78)	
B00E - R0001 - Practical Activities - 1hb - (16.47 SQM)	Student Space (7)	
B00E - R0002 - Home Base - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Home Base - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0004 - Practical Activities - 1hb - (16.47 SQM)	Student Space (7)	
B00F - R0001 - Practical Activities - 1hb - (16.47 SQM)	Student Space (7)	
B00F - R0002 - Home Base - (52.12 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0003 - Home Base - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0004 - Practical Activities - 1hb - (16.47 SQM)	Student Space (7)	
B00G - R0002 - Practical Activities - 1hb - (18.01 SQM)	Student Space (8)	
B00G - R0003 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0004 - Movement - (75.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0006 - Practical Activities - 1hb - (11.42 SQM)	Student Space (5)	
B00G - R0007 - Practical Activities - 1hb - (11.42 SQM)	Student Space (5)	
B00G - R0008 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0009 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0010 - Practical Activities - 1hb - (18.01 SQM)	Student Space (8)	
B00I - R0002 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00I - R0003 - Home Base - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0004 - Movement - (70.52 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Home Base - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0006 - Practical Activities - 1hb - (11 SQM)	Student Space (5)	
B00I - R0008 - Practical Activities - 1hb - (10.92 SQM)	Student Space (5)	
B00I - R0009 - Home Base - (54.38 SQM) - Teaching Space: 1	Student Space (25)	
B00I - R0010 - Home Base - (59.15 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0011 - Practical Activities - 1hb - (17.66 SQM)	● Student Space (8)	
B00P - R0001 - Dental Clinic - (12.59 SQM)	● Office (3)	
B00P - R0002 - Dental Clinic - (8.98 SQM)	● Office (2)	
B00P - R0003 - Dental Clinic - (8.94 SQM)	● Office (2)	
B00P - R0006 - Dental Clinic - (5.04 SQM)	● Office (1)	
B00P - R0010 - Dental Clinic - (11.58 SQM)	● Office (2)	
B00S - R0001 - Canteen - (44.18 SQM)	Not Applicable	Circulation or storage space.
B00S - R0002 - Communal Space - (236.53 SQM)	● Student Space (109)	
B00S - R0009 - Raised Platform - (55.44 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00T - R0004 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00T - R0006 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00T - R0007 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0009 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00T - R0011 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0012 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00T - R0013 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00T - R0014 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00U - R0003 - Special Programs Room - (19.16 SQM)	● Student Space (8)	
B00U - R0004 - Special Programs Room - (16.54 SQM)	● Student Space (7)	
B00U - R0005 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00U - R0006 - Special Programs Room - (28.5 SQM)	● Student Space (13)	
B00U - R0011 - Special Programs Room - (18.83 SQM)	● Student Space (8)	
B00U - R0014 - Staff Kitchen - (13.18 SQM)	● Office (3)	