

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Red Hill Environmental Education Centre (5750)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Dubbo</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Western</b>

5750 - Red Hill Environmental Education Centre  
Site Plan (06310)



1:1,023

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Dormitory - (85.17 SQM)	Office (21)	
B00A - R0004 - Movement - (40.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Dormitory - (28.46 SQM)	Office (7)	
B00A - R0006 - Interview - (48.55 SQM)	Office (12)	
B00A - R0007 - Dormitory - (16.31 SQM)	Office (4)	
B00A - R0008 - Dormitory - (8.23 SQM)	Office (2)	
B00A - R0010 - Dormitory - (63.87 SQM)	Office (15)	
B00B - R0002 - Movement - (15.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Staff Kitchen - (9.17 SQM)	Office (2)	
B00C - R0001 - Movement - (26.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (33.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Staff Study - (46.27 SQM)	Office (11)	
B00C - R1008 - Staff Kitchen - (5.21 SQM)	Office (1)	
B00C - R1009 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Main Area - (40.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Principal - (12.95 SQM)	Office (3)	
B00E - R0001 - Practical Activities - (51.72 SQM)	Student Space (23)	
B00E - R0002 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Staff Kitchen - (7.49 SQM)	Office (1)	
B00J - R0001 - Practical Activities - (22.19 SQM)	Student Space (10)	