

VENTILATION AUDIT REPORT

| | |
|------------------------|-------------------------------|
| SCHOOL: | Red Hill Public School (4410) |
| AMU REGION: | Southern NSW |
| STATE ELECTORATE: | Wagga Wagga |
| LOCAL GOVERNMENT AREA: | Wagga Wagga |

4410 - Red Hill Public School
Site Plan (11342)



1:813

Printed: 21-Mar-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0003 - Clerical Office - (13.21 SQM) | Office (3) | |
| B00A - R0006 - Staff Room Annexe - (9.37 SQM) | Office (2) | |
| B00A - R0007 - Staff Room Annexe - (9.36 SQM) | Office (2) | |
| B00A - R0008 - Movement - (15.57 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0009 - Duplicating Workroom - (15.81 SQM) | Office (3) | |
| B00A - R0011 - Staff Room - (84.5 SQM) | Office (21) | |
| B00A - R0014 - Movement - (23.78 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0015 - Canteen - (27.34 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0017 - Movement - (5.1 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0024 - Movement - (11.12 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0031 - Movement - (11.53 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0033 - Entry Vestibule - (42.83 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0034 - Clerical Office - (43.99 SQM) | Office (10) | |
| B00A - R0035 - Sick Bay - (9.72 SQM) | Student Space (4) | |
| B00A - R0036 - Principal - (17.51 SQM) | Office (4) | |
| B00A - R0037 - Movement - (17.8 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0038 - Interview - (9.83 SQM) | Office (2) | |
| B00A - R0039 - Movement - (133.07 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0001 - Movement - (112.84 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0010 - Home Base - M - (85 SQM) - Teaching Space: 1 | Student Space (39) | |
| B00B - R0015 - Home Base - M - (56.45 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00B - R0016 - Home Base - M - (56.84 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00C - R0001 - Movement - (71.48 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0006 - Home Base - E - (52.2 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R0007 - Practical Activities - E - (12.2 SQM) | Student Space (5) | |
| B00D - R0001 - Movement - (112.9 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Home Base - (79.85 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00D - R0005 - Staff Room Annexe - (9.02 SQM) | Office (2) | |
| B00D - R0019 - Interview/Office - Type 3 - (56.86 SQM) | Office (14) | |
| B00D - R0020 - Clerical Office - (21.19 SQM) | Office (5) | |
| B00D - R0021 - Interview - (19.83 SQM) | Office (4) | |
| B00D - R0022 - Interview - (16.36 SQM) | Office (4) | |
| B00D - R0023 - Interview - (17.26 SQM) | Office (4) | |
| B00D - R0024 - Staff Kitchen - (18.39 SQM) | Office (4) | |
| B00E - R0001 - Movement - (118.59 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0004 - Raised Platform - (45.14 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0008 - Communal Space - (230.62 SQM) | Student Space (106) | |
| B00F - R0001 - Movement - (119.22 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0004 - Movement - (6.5 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0010 - Reading Area - (257.84 SQM) | Student Space (119) | |
| B00F - R0011 - Staff Room Annexe - (13.63 SQM) | Office (3) | |
| B00G - R0001 - Movement - (112.01 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0005 - Practical Activities - 1hb - (16.9 SQM) | Student Space (7) | |
| B00G - R0006 - Home Base - (53.39 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00G - R0007 - Home Base - (53.46 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00G - R0008 - Practical Activities - 1hb - (17.38 SQM) | Student Space (8) | |
| B00G - R0009 - Practical Activities - 1hb - (16.98 SQM) | Student Space (7) | |
| B00G - R0010 - Home Base - (81.22 SQM) - Teaching Space: 1 | Student Space (37) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00G - R0012 - Staff Room Annexe - (8.48 SQM) | Office (2) | |
| B00H - R0001 - Movement - (120.01 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0005 - Interview - (10.99 SQM) | Office (2) | |
| B00H - R0007 - Practical Activities - 1hb - (17.7 SQM) | Student Space (8) | |
| B00H - R0008 - Home Base - (51.62 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00H - R0009 - Home Base - (51.49 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00H - R0010 - Practical Activities - 1hb - (17.71 SQM) | Student Space (8) | |
| B00H - R0011 - Practical Activities - 1hb - (17.7 SQM) | Student Space (8) | |
| B00H - R0012 - Home Base - (51.33 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00H - R0013 - Home Base - (52.59 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00H - R0014 - Practical Activities - 1hb - (17.27 SQM) | Student Space (8) | |
| B00J - R0001 - Movement - (120.01 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0002 - Practical Activities - 1hb - (16.97 SQM) | Student Space (7) | |
| B00J - R0003 - Practical Activities - 1hb - (17.15 SQM) | Student Space (7) | |
| B00J - R0004 - Home Base - (51.04 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00J - R0005 - Home Base - (50.94 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00J - R0006 - Practical Activities - 1hb - (17.2 SQM) | Student Space (7) | |
| B00J - R0013 - Practical Activities - 1hb - (17.25 SQM) | Student Space (8) | |
| B00J - R0014 - Home Base - (50.86 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00J - R0015 - Home Base - (51.4 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00K - R0001 - Movement - (120.1 SQM) | Not Applicable | Circulation or storage space. |
| B00K - R0002 - Practical Activities - 1hb - (16.1 SQM) | Student Space (7) | |
| B00K - R0003 - Practical Activities - 1hb - (16.16 SQM) | Student Space (7) | |
| B00K - R0004 - Home Base - (50.39 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00K - R0005 - Home Base - (50.8 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00K - R0006 - Practical Activities - 1hb - (17.02 SQM) | Student Space (7) | |
| B00K - R0013 - Practical Activities - 1hb - (16.9 SQM) | Student Space (7) | |
| B00K - R0014 - Home Base - (50.88 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00K - R0015 - Home Base - (50.68 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00L - R0002 - Entry Vestibule - (13.88 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0005 - Home Base - Pre - (68.92 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00L - R0006 - Practical Activities - Pre - (46.29 SQM) | Student Space (21) | |
| B00L - R0015 - Movement - (69.31 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0001 - Special Programs Room - (37.05 SQM) | Student Space (17) | |
| B00M - R0002 - Special Programs Room - (37.24 SQM) | Student Space (17) | |
| B00M - R0003 - Home Base - (58.06 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00M - R0005 - Withdrawal Space - 1hb - (8.87 SQM) | Student Space (4) | |
| B00M - R0006 - Practical Activities - (20.95 SQM) | Student Space (9) | |