

VENTILATION AUDIT REPORT

SCHOOL:	Red Range Public School (2948)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Glen Innes Severn

2948 - Red Range Public School
Site Plan (10726)



1:1,274

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0002 - Practical Activities - 1hb - (14.14 SQM)	● Student Space (6)	
B00A - R0004 - Reading Area - (60.76 SQM)	● Student Space (28)	
B00A - R0005 - Seminar/Study - (6.32 SQM)	● Office (1)	
B00A - R0006 - Staff Room - (14.39 SQM)	● Office (3)	
B00A - R0007 - Practical Activities - 1hb - (14.43 SQM)	● Student Space (6)	
B00A - R0009 - Home Base - (61.04 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0010 - Sick Bay - (6.58 SQM)	● Student Space (3)	
B00A - R0012 - Principal - (17.83 SQM)	● Office (4)	
B00A - R0015 - Clerical Office/Workroom - (17.63 SQM)	● Office (4)	
B00A - R0016 - Entry Vestibule - (11.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (23.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (15.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (63.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (59.99 SQM)	● Student Space (27)	
OS 602 15004 - OS 602 15004 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	