

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Redhead Public School (2946)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

2946 - Redhead Public School  
Site Plan (12847)





1:939

Printed: 02-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (13.33 SQM)	 Office (3)	
B00A - R0002 - Movement - (67.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Room Annexe - (12.42 SQM)	 Office (3)	
B00A - R0004 - Entry Vestibule - (11.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (28.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office - (11.42 SQM)	 Office (2)	
B00A - R0007 - Sick Bay - (7.01 SQM)	 Student Space (3)	
B00A - R0008 - Duplicating Workroom - (11.26 SQM)	 Office (2)	
B00A - R0009 - Principal - (16.51 SQM)	 Office (4)	
B00A - R0010 - Staff Room Annexe - (12.45 SQM)	 Office (3)	
B00A - R0015 - Staff Room - (52.25 SQM)	 Office (13)	
B00B - R0003 - Withdrawal Space - 1hb - (17.63 SQM)	 Student Space (8)	
B00B - R0005 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (79.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (53.73 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0008 - Home Base - (53.66 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0009 - Home Base - (53.28 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0012 - Home Base - (53.65 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R9011 - Canteen - (40.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R9012 - Movement - (54.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (74.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (56.24 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0005 - Home Base - (56.26 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0007 - Movement - (9.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (73.42 SQM) - Teaching Space: 1	 Student Space (34)	
B00C - R0010 - Practical Activities - 1hb - (21.55 SQM)	 Student Space (9)	
B00C - R0011 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (43.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (56.45 SQM) - Teaching Space: 1	 Student Space (26)	
B00D - R0004 - Home Base - (84.85 SQM) - Teaching Space: 1	 Student Space (39)	
B00G - R0002 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Reading Area - (120.4 SQM)	 Student Space (55)	
B00I - R0003 - Special Programs Room - (64.47 SQM)	 Student Space (29)	
B00J - R0004 - Communal Space - (222.33 SQM)	 Student Space (103)	
B00J - R0005 - Movement - (5.71 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Raised Platform - (61 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Canteen - (15.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Movement - (16.88 SQM)	Not Applicable	Circulation or storage space.
OS 602 11696 - OS 602 11696 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16322 - OS 602 16322 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	