

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Regents Park Public School (2950)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Bankstown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canterbury-Bankstown</b>

2950 - Regents Park Public School  
Site Plan (11969)



1:763

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0004 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0024 - Canteen - (18.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Principal - (21 SQM)	● Office (5)	
B00A - R0028 - Sick Bay - (7.16 SQM)	● Student Space (3)	
B00A - R0029 - Duplicating Workroom - (9.16 SQM)	● Office (2)	
B00A - R0031 - Clerical Office - (18.57 SQM)	● Office (4)	
B00A - R0032 - Entry Vestibule - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (42.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Staff Kitchen - (13.45 SQM)	● Office (3)	
B00A - R0050 - Staff Room - (43.59 SQM)	● Office (10)	
B00A - R0054 - Movement - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Home Base - (57.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1004 - Home Base - (57.24 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1008 - Home Base - (57.24 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1011 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1020 - Movement - (125.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Entry Vestibule - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Seminar/Study - (37.01 SQM)	● Office (9)	
B00B - R0013 - Reading Area - (124.23 SQM)	● Student Space (57)	
B00B - R0014 - Clerical Office/Workroom - (21.23 SQM)	● Office (5)	
B00C - R0001 - Home Base - (52.2 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0002 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Movement - (35.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (51.06 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0002 - Home Base - (51.34 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0001 - Home Base - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0002 - Home Base - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0001 - Home Base - (52.2 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0002 - Practical Activities - 1hb - (52.34 SQM)	● Student Space (24)	
B00H - R0001 - Withdrawal Space - 1hb - (13.24 SQM)	● Student Space (6)	
B00H - R0002 - Interview - (9.36 SQM)	● Office (2)	
B00H - R0004 - Home Base - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0005 - Practical Activities - 1hb - (53.8 SQM)	● Student Space (24)	
B00L - R0001 - Communal Space - (144.97 SQM)	● Student Space (67)	
B00L - R0002 - Raised Platform - (63.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities/Movement - 1hb - (19.36 SQM)	● Student Space (8)	
B00M - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	● Student Space (4)	
B00M - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0008 - Practical Activities/Movement - 1hb - (19.36 SQM)	● Student Space (8)	