

VENTILATION AUDIT REPORT

SCHOOL:	Regentville Public School (2951)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Penrith

2951 - Regentville Public School
Site Plan (10523)



1:1,238

Printed: 15-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (59.24 SQM)	Office (14)	
B00A - R0003 - Clerical Office - (14.67 SQM)	Office (3)	
B00A - R0007 - Duplicating Workroom - (40.67 SQM)	Office (10)	
B00A - R0008 - Deputy Principal - (14.06 SQM)	Office (3)	
B00A - R0010 - Principal - (23.21 SQM)	Office (5)	
B00A - R0011 - Entry Vestibule - (14.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Entry Vestibule - (31.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office/Workroom - (16.08 SQM)	Office (4)	
B00A - R0015 - Interview - (13.15 SQM)	Office (3)	
B00A - R0021 - Movement - (16.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Communal Space - (39.52 SQM)	Student Space (18)	
B00B - R0017 - Communal Space - (225.17 SQM)	Student Space (104)	
B00C - R0004 - Reading Area - (225.97 SQM)	Student Space (104)	
B00D - R0002 - Practical Activities - 1hb - (24.38 SQM)	Student Space (11)	
B00D - R0004 - Home Base - (55.91 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0005 - Withdrawal Space - 1hb - (10.76 SQM)	Student Space (4)	
B00D - R0006 - Practical Activities - 1hb - (24.28 SQM)	Student Space (11)	
B00D - R0008 - Home Base - (56.41 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Canteen - (44.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (56.29 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0004 - Home Base - (56.69 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0008 - Practical Activities - 1hb - (24.21 SQM)	Student Space (11)	
B00F - R0009 - Withdrawal Space - 1hb - (11.28 SQM)	Student Space (5)	
B00F - R0010 - Practical Activities - 1hb - (24.49 SQM)	Student Space (11)	
B00G - R0001 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00G - R0002 - Home Base - (51.69 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0003 - Home Base - (51.4 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0004 - Withdrawal Space - 1hb - (5.95 SQM)	Student Space (2)	
B00G - R0006 - Practical Activities - 1hb - (28.25 SQM)	Student Space (13)	
B00G - R0007 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Practical Activities - 1hb - (27.36 SQM)	Student Space (12)	
B00G - R0011 - Movement - (76.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Special Programs Room - (41.25 SQM)	Student Space (19)	
B00I - R0001 - Withdrawal Space - 1hb - (6.03 SQM)	Student Space (2)	
B00I - R0002 - Home Base - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0003 - Practical Activities - 1hb - (27.64 SQM)	Student Space (12)	
B00I - R0005 - Home Base - (51.76 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0006 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00I - R0008 - Practical Activities - 1hb - (28.49 SQM)	Student Space (13)	
B00I - R0009 - Withdrawal Space - 1hb - (6 SQM)	Student Space (2)	
B00I - R0010 - Home Base - (51.69 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0011 - Practical Activities - 1hb - (28.57 SQM)	Student Space (13)	
B00I - R0013 - Home Base - (51.26 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0014 - Withdrawal Space - 1hb - (6.11 SQM)	Student Space (2)	
B00I - R0017 - Practical Activities - 1hb - (27.66 SQM)	Student Space (12)	
B00K - R0001 - Home Base - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0003 - Movement - (11.54 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0001 - Home Base - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00M - R0004 - Home Base - (85.51 SQM) - Teaching Space: 1	● Student Space (39)	
B00M - R0009 - Special Programs Room - (42.8 SQM)	● Student Space (19)	
B00P - R0001 - Movement - (15.64 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00Q - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00Q - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00R - R0002 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
B00R - R0004 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00R - R0006 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
B00S - R0002 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
B00S - R0004 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00S - R0006 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0008 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
B00T - R0002 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
B00T - R0004 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00T - R0006 - Home Base - (58.74 SQM) - Teaching Space: 1	● Student Space (27)	
B00T - R0008 - Practical Activities - 1hb - (19.65 SQM)	● Student Space (9)	
OS 602 11244 - OS 602 11244 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13305 - OS 602 13305 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13977 - OS 602 13977 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15851 - OS 602 15851 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16243 - OS 602 16243 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	