


VENTILATION AUDIT REPORT

SCHOOL:	Richmond High School (8178)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

8178 - Richmond High School
Site Plan (10524)



1:2,478

Printed: 23-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Leading Teacher - (21.48 SQM)	Office (5)	
B001 - R0005 - Leading Teacher - (13.11 SQM)	Office (3)	
B001 - R0006 - Deputy Principal Office - (14.13 SQM)	Office (3)	
B001 - R0007 - Pupil Entry - (18.78 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Administration - Clerical - (12.82 SQM)	Office (3)	
B001 - R0009 - Administration - Clerical - (12.79 SQM)	Office (3)	
B001 - R0010 - Principal Office - (22.75 SQM)	Office (5)	
B001 - R0012 - Duplicating Workroom - (21.53 SQM)	Office (5)	
B001 - R0013 - Administration - Clerical - (40.78 SQM)	Office (10)	
B001 - R0014 - Public Entry - (14.66 SQM)	Not Applicable	Circulation or storage space.
B001 - R0015 - Interview/Office - Type 1 - (14.96 SQM)	Office (3)	
B001 - R0019 - Clinic - Boys - (13.67 SQM)	Office (3)	
B001 - R0020 - Movement - (45.46 SQM)	Not Applicable	Circulation or storage space.
B001 - R0023 - Staff Study - (68.44 SQM)	Office (17)	
B001 - R0024 - Staff Study - (38.27 SQM)	Office (9)	
B002 - R0001 - Design L.S. - (49.72 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R0002 - Staff Study - (24.72 SQM)	Office (6)	
B002 - R0003 - Design L.S. - (50.84 SQM) - Teaching Space: 1	Student Space (23)	
B002 - R0004 - Movement - (79.24 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Materials Technology L.S. - (89.35 SQM) - Teaching Space: 1	Student Space (41)	
B002 - R0006 - Materials Technology L.S. - (80.24 SQM) - Teaching Space: 1	Student Space (37)	
B002 - R0009 - Materials Technology L.S. - (81.08 SQM) - Teaching Space: 1	Student Space (37)	
B002 - R0010 - Materials Technology L.S. - (71.04 SQM) - Teaching Space: 1	Student Space (32)	
B002 - R0013 - Staff Study - (19.57 SQM)	Office (4)	
B002 - R0014 - Movement - (11.8 SQM)	Not Applicable	Circulation or storage space.
B002 - R0016 - Wood Technology Bay - (44.52 SQM)	Not Applicable	Circulation or storage space.
B002 - R0018 - Staff Study - (22.35 SQM)	Office (5)	
B002 - R0025 - Movement - (18.33 SQM)	Not Applicable	Circulation or storage space.
B002 - R0029 - Metal Technology Bay - (64.66 SQM)	Not Applicable	Circulation or storage space.
B003 - R0001 - Staff Study - (48.47 SQM)	Office (12)	
B003 - R0004 - Study Space - (27.82 SQM)	Not Applicable	Circulation or storage space.
B003 - R0010 - Food Technology L.S. - (95.89 SQM) - Teaching Space: 1	Student Space (44)	
B003 - R0012 - Design L.S. - (65.8 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0015 - Design L.S. - (65.73 SQM) - Teaching Space: 1	Student Space (30)	
B003 - R0020 - Music Learning Space - (64.11 SQM) - Teaching Space: 1	Student Space (29)	
B003 - R0022 - Movement - (24.66 SQM)	Not Applicable	Circulation or storage space.
B003 - R0023 - Practice/Seminar - (18.4 SQM)	Not Applicable	Circulation or storage space.
B003 - R0025 - Music Learning Space - (75.66 SQM) - Teaching Space: 1	Student Space (35)	
B003 - R0026 - Preparation - (23.56 SQM)	Not Applicable	Circulation or storage space.
B003 - R0029 - Laboratory L.S. - (104.57 SQM) - Teaching Space: 1	Student Space (48)	
B003 - R0031 - Movement - (107.19 SQM)	Not Applicable	Circulation or storage space.
B003 - R0035 - Food Technology L.S. - (81.89 SQM) - Teaching Space: 1	Student Space (37)	
B003 - R0036 - Preparation - (22.91 SQM)	Not Applicable	Circulation or storage space.
B003 - R0037 - General Learning Space - (31.98 SQM) - Teaching Space: 1	Student Space (14)	
B004 - R0001 - Art Learning Space - (59.42 SQM) - Teaching Space: 1	Student Space (27)	
B004 - R0002 - Workshop - (59.56 SQM)	Student Space (27)	
B004 - R0004 - Art Learning Space - (60.94 SQM) - Teaching Space: 1	Student Space (28)	
B004 - R0007 - Art Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0008 - Leading Teacher - (10.87 SQM)	Office (2)	
B004 - R0009 - Staff Study - (14.76 SQM)	Office (3)	
B005 - R0001 - General Learning Space - (49.72 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0002 - Study Space - (23.92 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Staff Study - (41.83 SQM)	Office (10)	
B005 - R0009 - General Learning Space - (49.8 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0012 - General Learning Space - (49.93 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0013 - General Learning Space - (50.43 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0014 - General Learning Space - (50.08 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0015 - General Learning Space - (50.29 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0016 - General Learning Space - (50.58 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R0017 - Movement - (85.18 SQM)	Not Applicable	Circulation or storage space.
B005 - R1001 - General Learning Space - (50.5 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1002 - Staff Study - (24.6 SQM)	Office (6)	
B005 - R1007 - Staff Study - (43.25 SQM)	Office (10)	
B005 - R1009 - Computer Learning Space - (51.22 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1011 - General Learning Space - (50.49 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1012 - General Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1013 - General Learning Space - (51.21 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1014 - General Learning Space - (50.57 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1015 - General Learning Space - (51.51 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1016 - Movement - (98.31 SQM)	Not Applicable	Circulation or storage space.
B006 - R0003 - Laboratory L.S. - (102.84 SQM) - Teaching Space: 1	Student Space (47)	
B006 - R0004 - Preparation - (49.46 SQM)	Not Applicable	Circulation or storage space.
B006 - R0005 - Laboratory L.S. - (103.64 SQM) - Teaching Space: 1	Student Space (48)	
B006 - R0006 - Staff Study - (34.22 SQM)	Office (8)	
B006 - R0007 - Movement - (55.93 SQM)	Not Applicable	Circulation or storage space.
B006 - R0008 - Staff Study - (35.89 SQM)	Office (8)	
B006 - R0009 - Leading Teacher - (13.69 SQM)	Office (3)	
B006 - R0030 - Movement - (51.61 SQM)	Not Applicable	Circulation or storage space.
B006 - R0035 - Student Canteen - (69.57 SQM)	Not Applicable	Circulation or storage space.
B006 - R0036 - Movement - (139.76 SQM)	Not Applicable	Circulation or storage space.
B006 - R1001 - Movement - (33.06 SQM)	Not Applicable	Circulation or storage space.
B006 - R1006 - General Learning Space - (54.75 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1007 - General Learning Space - (55.11 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1008 - Movement - (84.39 SQM)	Not Applicable	Circulation or storage space.
B006 - R1009 - Staff Study - (37.03 SQM)	Office (9)	
B006 - R1010 - Staff Study - (14.13 SQM)	Office (3)	
B006 - R1016 - Movement - (59.33 SQM)	Not Applicable	Circulation or storage space.
B006 - R1017 - General Learning Space - (54.9 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1018 - Movement - (57.89 SQM)	Not Applicable	Circulation or storage space.
B006 - R1019 - General Learning Space - (55.11 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1020 - General Learning Space - (55.11 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1021 - General Learning Space - (54.89 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1022 - Movement - (62.41 SQM)	Not Applicable	Circulation or storage space.
B006 - R1023 - General Learning Space - (54.97 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1024 - Movement - (81.59 SQM)	Not Applicable	Circulation or storage space.
B006 - R1025 - General Learning Space - (54.73 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R1028 - General Learning Space - (54.58 SQM) - Teaching Space: 1	Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R1030 - Staff Study - (26.04 SQM)	Office (6)	
B006 - R1032 - Movement - (43.03 SQM)	Not Applicable	Circulation or storage space.
B007 - R0001 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	Student Space (42)	
B007 - R0005 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	Student Space (42)	
B007 - R0008 - Movement - (40.68 SQM)	Not Applicable	Circulation or storage space.
B007 - R0009 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	Student Space (42)	
B007 - R0010 - Preparation - (31.57 SQM)	Not Applicable	Circulation or storage space.
B007 - R0013 - Laboratory L.S. - (91.44 SQM) - Teaching Space: 1	Student Space (42)	
B007 - R0019 - Preparation - (48.46 SQM)	Not Applicable	Circulation or storage space.
B007 - R1001 - Workroom - (72.65 SQM)	Office (18)	
B007 - R1002 - Main Area - (288.75 SQM)	Not Applicable	Circulation or storage space.
B007 - R1003 - Seminar - (12.88 SQM)	Office (3)	
B007 - R1004 - Seminar - (12.15 SQM)	Office (3)	
B007 - R1009 - Workroom - (11.69 SQM)	Office (2)	
B007 - R1010 - Seminar - (12.89 SQM)	Office (3)	
B007 - R1011 - Audio Visual Workroom - (28.5 SQM)	Student Space (13)	
B007 - R1014 - Workroom - (17.63 SQM)	Office (4)	
B007 - R1016 - Entry - (34.25 SQM)	Not Applicable	Circulation or storage space.
B007 - R2001 - Computer Learning Space - (38.26 SQM) - Teaching Space: 1	Student Space (17)	
B007 - R2002 - Main Area - (69.71 SQM)	Not Applicable	Circulation or storage space.
B007 - R2004 - Seminar - (15.18 SQM)	Office (3)	
B008 - R0007 - Stage - (74.84 SQM)	Not Applicable	Circulation or storage space.
B008 - R0015 - Student Canteen - (20.2 SQM)	Not Applicable	Circulation or storage space.
B008 - R0016 - Public Entry - (21.06 SQM)	Not Applicable	Circulation or storage space.
B008 - R0020 - Multi-Purpose Space - (596.73 SQM)	Student Space (276)	
B009 - R0001 - General Learning Space - (71.57 SQM) - Teaching Space: 1	Student Space (33)	
B009 - R0003 - Movement - (45.08 SQM)	Not Applicable	Circulation or storage space.
B009 - R0007 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B009 - R0008 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (24)	
B009 - R0009 - Administration - Clerical - (11.92 SQM)	Office (2)	
B009 - R0010 - Movement - (14.41 SQM)	Not Applicable	Circulation or storage space.
B009 - R0012 - Staff Study - (45.95 SQM)	Office (11)	
B009 - R0013 - Gymnasium - (53.16 SQM)	Student Space (24)	
B010 - R0001 - Gymnasium - (268.53 SQM)	Student Space (124)	
B010 - R0012 - Performance Workshop - (60.17 SQM)	Student Space (27)	
B010 - R0013 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B012 - R0003 - Workshop Area - (26.01 SQM)	Student Space (12)	
B014 - R0002 - Growing/Breeding - (36.01 SQM)	Not Applicable	Circulation or storage space.
B016 - R0001 - Preparation - Materials - (30.38 SQM)	Not Applicable	Circulation or storage space.
B019 - R0001 - Movement Studio - (94.38 SQM)	Not Applicable	Circulation or storage space.
B020 - R0002 - Food Technology L.S. - (158.62 SQM) - Teaching Space: 1	Student Space (73)	
B020 - R0003 - Food/Research Space - (8.63 SQM)	Not Applicable	Circulation or storage space.
B021 - R0001 - Multi-Purpose Space - (653.34 SQM)	Student Space (303)	
B021 - R0002 - Staff Kitchen - (14.53 SQM)	Office (3)	
B021 - R0017 - Stage - (101.09 SQM)	Not Applicable	Circulation or storage space.
B021 - R0018 - Movement - (15.7 SQM)	Not Applicable	Circulation or storage space.
B021 - R0025 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
NS 200 14798 - NS 200 14798 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 601 14596 - OS 601 14596 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	