

VENTILATION AUDIT REPORT

SCHOOL:	Richmond North Public School (2965)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

2965 - Richmond North Public School
Site Plan (11238)



1:1,146

Printed: 15-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Deputy Principal - (15.37 SQM)	Office (3)	
B00A - R0003 - Sick Bay - (11.81 SQM)	Student Space (5)	
B00A - R0005 - Clerical Office - (8.79 SQM)	Office (2)	
B00A - R0010 - Principal - (16.47 SQM)	Office (4)	
B00A - R0011 - Duplicating Workroom - (11.39 SQM)	Office (2)	
B00A - R0012 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0016 - Home Base - (56.82 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0018 - Movement - (47.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Entry Vestibule - (25.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (18.86 SQM)	Student Space (8)	
B00B - R0002 - Home Base - (53.71 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - Home Base - (84.31 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0004 - Practical Activities - 1hb - (14.42 SQM)	Student Space (6)	
B00B - R0012 - Movement - (52.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Special Programs Room - (43.99 SQM)	Student Space (20)	
B00C - R0009 - Reading Area - (229.9 SQM)	Student Space (106)	
B00C - R0010 - Movement - (161.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (84.78 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0006 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0015 - Movement - (72.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R9001 - Withdrawal Space - 1hb - (103.66 SQM)	Student Space (48)	
B00E - R9002 - Staff Room Annexe - (19.88 SQM)	Office (4)	
B00F - R0002 - Movement - (16.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Interview - (14.92 SQM)	Office (3)	
B00F - R0010 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0011 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0015 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Staff Room - (38.01 SQM)	Office (9)	
B00F - R0022 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0023 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0028 - Movement - (36.96 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Canteen - (40.17 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (146.98 SQM)	Student Space (68)	
B00J - R0002 - Raised Platform - (59.36 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.