

VENTILATION AUDIT REPORT

SCHOOL:	Riverside Girls High School (8243)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Hunters Hill

8243 - Riverside Girls High School
Site Plan (11827)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Kitchen - (19.06 SQM)	Office (4)	
B00A - R0006 - Multi-Purpose Space - (421.09 SQM)	Student Space (195)	
B00A - R0009 - Movement - (30.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Stage - (129.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R9008 - General Assistants - (59.22 SQM)	Office (14)	
B00B - R0016 - Interview/Meeting - (25.43 SQM)	Office (6)	
B00B - R0017 - Deputy Principal Office - (21.43 SQM)	Office (5)	
B00B - R0018 - Administration - Clerical - (56.01 SQM)	Office (14)	
B00B - R0020 - Deputy Principal Office - (13.58 SQM)	Office (3)	
B00B - R0026 - Clinic - Girls - (13.51 SQM)	Office (3)	
B00B - R0027 - Deputy Principal Office - (13.5 SQM)	Office (3)	
B00B - R0029 - Leading Teacher - (12.86 SQM)	Office (3)	
B00B - R0030 - Movement - (23.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Leading Teacher - (12.01 SQM)	Office (3)	
B00B - R0032 - Ancillary Staff - (11.9 SQM)	Office (2)	
B00B - R0036 - Principal Office - (22.98 SQM)	Office (5)	
B00B - R0042 - Public Reception - (29.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0044 - Student Reception - (23.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Staff Study - (65.78 SQM)	Office (16)	
B00C - R0006 - Laboratory L.S. - (85.04 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0008 - Preparation - Science - (28.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Laboratory L.S. - (96.4 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0016 - Laboratory L.S. - (84.96 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0020 - Gymnasium - (276.94 SQM)	Student Space (128)	
B00C - R0023 - Movement - (10.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (46.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0032 - Movement - (181.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Preparation - Science - (38.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Practice/Seminar - (6.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Music Learning Space - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1004 - Computer Learning Space - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1006 - General Learning Space - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1007 - Computer Learning Space - (54.26 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1011 - Art Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1013 - Art Learning Space - (55.79 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1020 - General Learning Space - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1021 - Practice/Seminar - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R1023 - Movement - (35.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R1024 - Performance Workshop - (114.98 SQM)	Student Space (53)	
B00C - R1025 - Music Learning Space - (60.37 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1027 - Practice/Seminar - (24.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R1032 - Dark Room - (21.91 SQM)	Office (5)	
B00C - R1033 - Art Learning Space - (54.51 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1036 - Movement - (200.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Computer Learning Space - (56.16 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0002 - Food Technology L.S. - (74.72 SQM) - Teaching Space: 1	Student Space (34)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0003 - Food Technology L.S. - (75.01 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0005 - General Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0009 - General Learning Space - (48.56 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0010 - General Learning Space - (48.64 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0011 - General Learning Space - (58.13 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0020 - General Learning Space - (48.57 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0021 - General Learning Space - (48.84 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0026 - General Learning Space - (48.78 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0027 - General Learning Space - (48.64 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0031 - Staff Kitchen - (13.29 SQM)	Office (3)	
B00D - R0032 - Staff Study - (17.72 SQM)	Office (4)	
B00D - R0033 - Staff Study - (13.26 SQM)	Office (3)	
B00D - R0035 - Interview/Office - Type 1 - (17.66 SQM)	Office (4)	
B00D - R0039 - Movement - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0043 - Movement - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0061 - Preparation - Materials - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0063 - Movement - (286.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0064 - Commonroom - (49.79 SQM)	Office (12)	
B00D - R0065 - Commonroom - (46.4 SQM)	Office (11)	
B00D - R0066 - Staff Kitchen - (11.24 SQM)	Office (2)	
B00D - R0068 - Staff Study - (48.51 SQM)	Office (12)	
B00D - R0069 - Staff Study - (46.55 SQM)	Office (11)	
B00D - R1004 - Design/Technology L.S. - (77.03 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R1006 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - General Learning Space - (49.44 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1010 - General Learning Space - (49.44 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1011 - General Learning Space - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1012 - General Learning Space - (50.67 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1013 - Interview/Office - Type 1 - (18.42 SQM)	Office (4)	
B00D - R1014 - General Learning Space - (50.46 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1015 - General Learning Space - (58.99 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1016 - General Learning Space - (49.51 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1017 - General Learning Space - (49.66 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1021 - General Learning Space - (49.51 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1022 - General Learning Space - (49.52 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1026 - Movement - (42.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - Staff Study - (59.11 SQM)	Office (14)	
B00D - R1035 - Design/Technology L.S. - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1039 - Staff Study - (19.48 SQM)	Office (4)	
B00D - R1040 - Seminar - Type 1 - (29.08 SQM)	Office (7)	
B00D - R1042 - Staff Study - (39.8 SQM)	Office (9)	
B00D - R1043 - Tea Room - (12.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R1044 - Movement - (288.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (100.84 SQM) - Teaching Space: 1	Student Space (46)	
B00E - R0003 - Preparation - Science - (19.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Tiered Learning Area - (49.07 SQM)	Student Space (22)	
B00E - R0005 - General Learning Space - (50.63 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0006 - Preparation - Science - (25.69 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0007 - Laboratory L.S. - (86.39 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0012 - Movement - (95.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Design L.S. - (66.5 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1002 - General Learning Space - (53.28 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1003 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1007 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - Movement - (91.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1016 - Stage - (21.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Main Entry - (98.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Main Area - (173.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Seminar - (12.78 SQM)	● Office (3)	
B00F - R0014 - Seminar - (10.9 SQM)	● Office (2)	
B00F - R0020 - Audio Visual Workroom - (15.78 SQM)	● Student Space (7)	
B00F - R0021 - Computer Room - (10.97 SQM)	● Student Space (5)	
B00G - R0001 - Computer Learning Space - (101.56 SQM) - Teaching Space: 1	● Student Space (47)	
B00G - R0002 - Multi Media Studio - (10.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Computer Learning Space - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Senior Study - (59.85 SQM)	● Office (14)	
B00G - R0009 - Movement - (19.12 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Computer Learning Space - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Student Canteen - (53.39 SQM)	Not Applicable	Circulation or storage space.
OS 601 11107 - OS 601 11107 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 11616 - OS 602 11616 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 760 10965 - OS 760 10965 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.