

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Riverstone High School (8907)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Riverstone</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

8907 - Riverstone High School  
Site Plan (12848)



1:2,161

Printed: 22-May-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Art Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0002 - Darkroom Space - (18.21 SQM)	● Office (4)	
B00A - R0016 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Workshop - (74.21 SQM)	● Student Space (34)	
B00A - R0030 - Art Learning Space - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0041 - Staff Study - (18.99 SQM)	● Office (4)	
B00A - R0042 - Computer Room - (34.33 SQM)	● Student Space (15)	
B00A - R0044 - Principal Office - (19.28 SQM)	● Office (4)	
B00A - R0045 - Administration - Executive - (43.22 SQM)	● Office (10)	
B00A - R0046 - Interview/Meeting - (12.72 SQM)	● Office (3)	
B00A - R0048 - Student Reception - (14.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Interview/Meeting - (11.81 SQM)	● Office (2)	
B00A - R0050 - Clinic - Boys - (10.35 SQM)	● Office (2)	
B00A - R0051 - Clinic - Girls - (10.33 SQM)	● Office (2)	
B00A - R0052 - Administration - Clerical - (111.32 SQM)	● Office (27)	
B00A - R0056 - Tea Room - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Interview/Office - Type 1 - (10.91 SQM)	● Office (2)	
B00A - R0060 - Interview/Office - Type 1 - (11.91 SQM)	● Office (2)	
B00A - R0061 - Visitors Office - (15.68 SQM)	● Office (3)	
B00A - R0062 - Public Reception - (19.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (83.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1002 - General Learning Space - (65.01 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1005 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1008 - General Learning Space - (64.87 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1010 - General Learning Space - (51.15 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1013 - Staff Study - (25.43 SQM)	● Office (6)	
B00A - R1014 - Administration - Clerical - (6.38 SQM)	● Office (1)	
B00A - R1015 - Leading Teacher - (13.48 SQM)	● Office (3)	
B00A - R1017 - Movement - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Interview/Office - Type 1 - (8.22 SQM)	● Office (2)	
B00A - R1020 - Administration - Clerical - (8.22 SQM)	● Office (2)	
B00A - R1021 - General Learning Space - (77.86 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R1022 - Staff Study - (25.43 SQM)	● Office (6)	
B00A - R1023 - Movement - (8.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R1028 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1032 - Movement - (67.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1033 - Movement - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (13.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0005 - Staff Study - (25.65 SQM)	● Office (6)	
B00B - R0006 - Food Technology L.S. - (65.01 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0008 - Food Technology L.S. - (64.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0011 - Computer Learning Space - (65.18 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0012 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0015 - General Learning Space - (65.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0016 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0017 - Movement - (95.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0026 - Staff Study - (32.34 SQM)	Office (8)	
B00B - R0030 - Laboratory L.S. - (85.13 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0032 - Preparation - (28.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Laboratory L.S. - (84.39 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0038 - General Learning Space - (51.72 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0039 - General Learning Space - (51.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0040 - General Learning Space - (51.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0041 - Computer Learning Space - (51.72 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0042 - General Learning Space - (51.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0043 - Movement - (95.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Movement - (21.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0050 - Movement - (15.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Movement - (15.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Music Learning Space - (51.43 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1004 - Staff Study - (25.71 SQM)	Office (6)	
B00B - R1007 - Design L.S. - (64.93 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1011 - Commonroom - (64.36 SQM)	Office (16)	
B00B - R1014 - Study Space - (25.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Music Learning Space - (51.57 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1018 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R1024 - Staff Study - (51.65 SQM)	Office (12)	
B00B - R1025 - General Learning Space - (50.51 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1026 - General Learning Space - (50.66 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1027 - General Learning Space - (51.51 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1029 - General Learning Space - (51.58 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1030 - General Learning Space - (51.58 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1031 - General Learning Space - (51.57 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1032 - General Learning Space - (51.58 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1033 - General Learning Space - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1034 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1035 - Movement - (96.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1036 - Performance Workspace - (51.43 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1039 - Movement - (15.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R1040 - Movement - (18.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R1042 - General Learning Space - Type 1 - (51.72 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1043 - Performance Workshop - (52.43 SQM)	Student Space (24)	
B00B - R1045 - Movement - (18.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R1046 - Movement - (76.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1051 - Multi Media Studio - (7.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R1052 - Multi Media Studio - (16.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Student Canteen - (17.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Gymnasium - (451.28 SQM)	Student Space (209)	
B00H - R0006 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Stage - (119.33 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (74.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0002 - Preparation - (48.9 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Laboratory L.S. - (91.91 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0007 - Laboratory L.S. - (91.72 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0008 - Staff Study - (48.89 SQM)	○ Office (12)	
B00L - R0009 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	● Student Space (42)	
B00L - R0010 - Movement - (40.19 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Movement - (56.44 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Main Area - (382.56 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Seminar - (27.02 SQM)	○ Office (6)	
B00L - R1006 - Workroom - (11.47 SQM)	○ Office (2)	
B00L - R1007 - Seminar - (23.77 SQM)	○ Office (5)	
B00L - R1009 - Audio Visual Workroom - (29.29 SQM)	● Student Space (13)	
B00L - R1011 - Workroom - (19.68 SQM)	○ Office (4)	
B00L - R1016 - Movement - (52.65 SQM)	Not Applicable	Circulation or storage space.
B00L - R2001 - Main Area - (107.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R2002 - Seminar - (18.17 SQM)	○ Office (4)	
B00L - R2003 - Workroom - (18.28 SQM)	○ Office (4)	
B00L - R2004 - Seminar - (30.28 SQM)	○ Office (7)	
B00N - R0004 - Movement - (22.31 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Pupil Entry - (68.11 SQM)	Not Applicable	Circulation or storage space.
B00O - R0003 - General Learning Space - (69.73 SQM) - Teaching Space: 1	● Student Space (32)	
B00O - R0004 - General Learning Space - (58.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0006 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00O - R0007 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00O - R0008 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00O - R0017 - Student Canteen - (84.26 SQM)	Not Applicable	Circulation or storage space.
B00O - R0048 - Tiered Learning Area - (34.03 SQM)	● Student Space (15)	
B00O - R1001 - Movement - (14.39 SQM)	Not Applicable	Circulation or storage space.
B00O - R1003 - General Learning Space - Type 13 - (40.98 SQM) - Teaching Space: 1	● Student Space (19)	
B00O - R1004 - General Learning Space - (60.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R1005 - Special Learning Space - (8.86 SQM)	● Student Space (4)	
B00O - R1006 - Special Learning Space - (6.01 SQM)	● Student Space (2)	
B00O - R1007 - Special Learning Space - (6.57 SQM)	● Student Space (3)	
B00O - R1008 - Special Learning Space - (10.53 SQM)	● Student Space (4)	
B00O - R1009 - General Learning Space - (67.37 SQM) - Teaching Space: 1	● Student Space (31)	
B00O - R1010 - Outdoor Learning Area - (45.83 SQM)	Not Applicable	Circulation or storage space.
B00O - R1011 - Special Learning Space - (8.36 SQM)	● Student Space (3)	
B00O - R1012 - General Learning Space - (22.72 SQM)	● Student Space (10)	
B00O - R1013 - General Learning Space - (39.58 SQM)	● Student Space (18)	
B00O - R1018 - Special Learning Space - (13.64 SQM)	● Student Space (6)	
B00O - R1019 - General Learning Space - Type 13 - (35.08 SQM)	● Student Space (16)	
B00O - R1020 - General Learning Space - (57.87 SQM) - Teaching Space: 1	● Student Space (26)	
B00O - R1021 - General Learning Space - (40.8 SQM)	● Student Space (18)	
B00O - R1022 - Special Learning Space-I.E.C. - (6.14 SQM)	● Student Space (2)	
B00O - R1023 - Special Learning Space - (6.51 SQM)	● Student Space (3)	
B00O - R1024 - Special Learning Space - (8.04 SQM)	● Student Space (3)	
B00O - R1025 - Special Learning Space - (7.48 SQM)	● Student Space (3)	
B00O - R1026 - General Learning Space - (63.46 SQM) - Teaching Space: 1	● Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R1027 - Outdoor Learning Area - (52.61 SQM)	Not Applicable	Circulation or storage space.
B000 - R1028 - Movement - (44.54 SQM)	Not Applicable	Circulation or storage space.
B000 - R1029 - Tiered Learning Area - (71.28 SQM)	● Student Space (33)	
B000 - R1030 - Practical Activities - (27.23 SQM)	● Student Space (12)	
B000 - R1031 - Special Learning Space - (6.51 SQM)	● Student Space (3)	
B000 - R1032 - Special Learning Space - (6.88 SQM)	● Student Space (3)	
B000 - R1033 - Special Learning Space - (6.8 SQM)	● Student Space (3)	
B000 - R1034 - Special Learning Space - (6.73 SQM)	● Student Space (3)	
B000 - R1035 - General Learning Space - (68.63 SQM) - Teaching Space: 1	● Student Space (31)	
B000 - R1036 - Outdoor Learning Area - (55.95 SQM)	Not Applicable	Circulation or storage space.
B000 - R1037 - Lecture Space - (58.27 SQM)	● Student Space (27)	
B000 - R1038 - Performance Workshop - (35.12 SQM)	● Student Space (16)	
B000 - R1042 - Movement - (70.48 SQM)	Not Applicable	Circulation or storage space.
B000 - R1043 - Special Learning Space - (15.34 SQM)	● Student Space (7)	
B000 - R1049 - Movement - (54.52 SQM)	Not Applicable	Circulation or storage space.
B000 - R1050 - Movement - (74.74 SQM)	Not Applicable	Circulation or storage space.
B000 - R1053 - Tiered Learning Area - (10.64 SQM)	● Student Space (4)	
OS 760 13230 - OS 760 13230 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 780 15057 - OS 780 15057 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.