

VENTILATION AUDIT REPORT

SCHOOL:	Riverwood Public School (3743)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Lakemba
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

3743 - Riverwood Public School
Site Plan (11240)



1:1,007

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (19.98 SQM)	Office (4)	
B00A - R0005 - Movement - (57.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Principal - (19.54 SQM)	Office (4)	
B00A - R0008 - Entry Vestibule - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office/Workroom - (19.59 SQM)	Office (4)	
B00A - R0011 - Duplicating Workroom - (10.65 SQM)	Office (2)	
B00A - R0015 - Interview - (20.58 SQM)	Office (5)	
B00A - R0018 - Staff Room - (40.64 SQM)	Office (10)	
B00B - R0001 - Staff Kitchen - (14.19 SQM)	Office (3)	
B00B - R0017 - Communal Space - (192.38 SQM)	Student Space (89)	
B00B - R0018 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (7.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Raised Platform - (71.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (15.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Canteen - (16.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Staff Room - (12.25 SQM)	Office (3)	
B00K - R0010 - Withdrawal - Pre - (12.18 SQM)	Student Space (5)	
B00K - R0012 - Home Base - Pre - (84.47 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0016 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Reading Area - (91.33 SQM)	Student Space (42)	
B00L - R0004 - Reading Area - (73.05 SQM)	Student Space (33)	
B0P1 - R0002 - Home Base - (56.84 SQM) - Teaching Space: 1	Student Space (26)	
B0P1 - R0005 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B0P1 - R0009 - Home Base - (56.66 SQM) - Teaching Space: 1	Student Space (26)	
B0P2 - R0002 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B0P2 - R0010 - Home Base - (56.74 SQM) - Teaching Space: 1	Student Space (26)	
B0P2 - R0011 - Home Base - (48.83 SQM) - Teaching Space: 1	Student Space (22)	
B0P2 - R0013 - Practical Activities - 1hb - (7.18 SQM)	Student Space (3)	
B0P2 - R0019 - Home Base - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B0P2 - R0021 - Practical Activities - 1hb - (7.26 SQM)	Student Space (3)	
B0P3 - R0001 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B0P3 - R0004 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B0P3 - R0009 - Home Base - (56.3 SQM) - Teaching Space: 1	Student Space (26)	
B0P3 - R0010 - Home Base - (56.46 SQM) - Teaching Space: 1	Student Space (26)	
B0P3 - R0013 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B0P3 - R0018 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	