

VENTILATION AUDIT REPORT

SCHOOL:	Robert Townson High School (8575)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

8575 - Robert Townson High School
Site Plan (10683)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Food Technology L.S. - (106.17 SQM) - Teaching Space: 1	● Student Space (49)	
B00A - R0002 - Textiles Technology L.S. - (69.54 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0004 - Textiles Technology L.S. - (69.39 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0007 - Food Technology L.S. - (106.29 SQM) - Teaching Space: 1	● Student Space (49)	
B00A - R0008 - Preparation - Materials - (16.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (48.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Study - (25.71 SQM)	● Office (6)	
B00B - R0005 - Deputy Principal Office - (16.31 SQM)	● Office (4)	
B00B - R0007 - Public Entry - (17.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Administration - Clerical - (42.65 SQM)	● Office (10)	
B00B - R0009 - Clinic - (14.01 SQM)	● Office (3)	
B00B - R0012 - Administration - Clerical - (13.48 SQM)	● Office (3)	
B00B - R0013 - Leading Teacher - (12.5 SQM)	● Office (3)	
B00B - R0014 - Interview/Office - Type 1 - (12.74 SQM)	● Office (3)	
B00B - R0018 - Principal Office - (20.4 SQM)	● Office (5)	
B00B - R0019 - Deputy Principal Office - (12.78 SQM)	● Office (3)	
B00B - R0023 - Commonroom - (99.63 SQM)	● Office (24)	
B00B - R0024 - Staff Kitchen - (7.64 SQM)	● Office (1)	
B00B - R0025 - Ancillary Staff - (19.38 SQM)	● Office (4)	
B00B - R0027 - Pupil Entry - (19.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Art Learning Space - (61.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0002 - Art Learning Space - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0003 - Art Learning Space - (61.17 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0005 - Art Learning Space - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0006 - Art Learning Space - (61.07 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0012 - Movement - (79.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Dark Room - (20.51 SQM)	● Office (5)	
B00C - R0018 - Staff Study - (21.16 SQM)	● Office (5)	
B00D - R0001 - General Learning Space - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Staff Study - (28.52 SQM)	● Office (7)	
B00D - R0004 - Computer Learning Space - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Movement - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Outdoor Learning Area - (163.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - T.A.S. Outdoor Area - (72.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Metal Technology L.S. - (89 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R0002 - Metal Technology Bay - (35.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Metal Technology L.S. - (90 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R0007 - Wood Technology Bay - (35.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (94.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Wood Technology L.S. - (87.71 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0019 - Wood Technology L.S. - (87.74 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0023 - Staff Study - (30.46 SQM)	● Office (7)	
B00F - R0008 - Movement - (22.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Stage - (103.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (22.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Multi-Purpose Space - (490.93 SQM)	● Student Space (227)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0017 - General Assistants - (13 SQM)	Office (3)	
B00G - R0005 - Music Learning Space - (60.75 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0006 - Practice/Seminar - (26.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Music Learning Space - (77.62 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0014 - Staff Study - (15.33 SQM)	Office (3)	
B00G - R0016 - Movement - (35.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Interview/Office - Type 1 - (13.4 SQM)	Office (3)	
B00H - R0007 - Laboratory L.S. - (81.03 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0008 - Preparation - Science - (32.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Laboratory L.S. - (80.57 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0012 - Laboratory L.S. - (80.39 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0013 - Preparation - Science - (33.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Laboratory L.S. - (80.3 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0017 - Laboratory L.S. - (80.48 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0018 - Preparation - Science - (32.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - General Learning Space - (80.39 SQM) - Teaching Space: 1	Student Space (37)	
B00H - R0020 - Movement - (151.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Staff Study - (18.86 SQM)	Office (4)	
B00H - R0024 - Staff Study - (39.47 SQM)	Office (9)	
B00J - R0003 - General Learning Space - (48.38 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0004 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0005 - General Learning Space - (48.16 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R0009 - Staff Study - (14.53 SQM)	Office (3)	
B00J - R0014 - Tiered Learning Area - (65.86 SQM)	Student Space (30)	
B00J - R0018 - Movement - (133.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Staff Study - (38.7 SQM)	Office (9)	
B00J - R1001 - General Learning Space - (47.81 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1002 - General Learning Space - (48.22 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1003 - General Learning Space - (48.16 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1004 - General Learning Space - (48.28 SQM) - Teaching Space: 1	Student Space (22)	
B00J - R1009 - Interview/Office - Type 1 - (13.03 SQM)	Office (3)	
B00J - R1011 - Movement - (110.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R1012 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00J - R1015 - Staff Study - (12.32 SQM)	Office (3)	
B00J - R1020 - Senior Study - (47.94 SQM)	Office (11)	
B00K - R0002 - Audio Visual Workroom - (32.62 SQM)	Student Space (15)	
B00K - R0004 - Seminar - (12.8 SQM)	Office (3)	
B00K - R0005 - Seminar - (12.8 SQM)	Office (3)	
B00K - R0006 - Interview/Office - Type 1 - (15.09 SQM)	Office (3)	
B00K - R0008 - Main Area - (366.26 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Tea Room - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Interview/Office - Type 1 - (13.46 SQM)	Office (3)	
B00L - R0011 - General Learning Space - (48.16 SQM) - Teaching Space: 1	Student Space (22)	
B00L - R0012 - General Learning Space - (48.09 SQM) - Teaching Space: 1	Student Space (22)	
B00L - R0013 - General Learning Space - (48.14 SQM) - Teaching Space: 1	Student Space (22)	
B00L - R0014 - General Learning Space - (39.85 SQM) - Teaching Space: 1	Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0015 - General Learning Space - (39.77 SQM) - Teaching Space: 1	● Student Space (18)	
B00L - R0016 - General Learning Space - (48 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0017 - General Learning Space - (48.28 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0018 - General Learning Space - (48.08 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R0019 - Senior Study - (14.68 SQM)	○ Office (3)	
B00L - R0020 - Staff Study - (14.72 SQM)	○ Office (3)	
B00L - R0021 - Movement - (253.79 SQM)	Not Applicable	Circulation or storage space.
B00L - R0025 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00L - R0029 - Staff Study - (25.56 SQM)	○ Office (6)	
B00L - R1006 - Interview/Office - Type 1 - (13.32 SQM)	○ Office (3)	
B00L - R1010 - Computer Learning Space - (47.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1011 - General Learning Space - (48.24 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1012 - General Learning Space - (48.38 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1013 - General Learning Space - (40.27 SQM) - Teaching Space: 1	● Student Space (18)	
B00L - R1014 - General Learning Space - (39.59 SQM) - Teaching Space: 1	● Student Space (18)	
B00L - R1015 - General Learning Space - (48.22 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1016 - General Learning Space - (48.22 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1017 - General Learning Space - (47.92 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1018 - Senior Study - (14.68 SQM)	○ Office (3)	
B00L - R1019 - Senior Study - (14.72 SQM)	○ Office (3)	
B00L - R1020 - Movement - (183.52 SQM)	Not Applicable	Circulation or storage space.
B00L - R1024 - Staff Study - (37.88 SQM)	○ Office (9)	
B00L - R1026 - Staff Study - (26.09 SQM)	○ Office (6)	
B00M - R0001 - Growing/Breeding - (11.79 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Fitness Laboratory - (24.5 SQM)	● Student Space (11)	
B00M - R0005 - General Assistants - (10.53 SQM)	○ Office (2)	
B00M - R0006 - Outdoor Learning Area - (29.91 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Student Canteen - (61.97 SQM)	Not Applicable	Circulation or storage space.
OS 601 14201 - OS 601 14201 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14734 - OS 601 14734 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15149 - OS 601 15149 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15404 - OS 601 15404 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	