

VENTILATION AUDIT REPORT

SCHOOL:	Rollands Plains Upper Public School (2985)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

2985 - Rollands Plains Upper Public School
Site Plan (11242)










1:825

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (24.47 SQM)	 Student Space (11)	
B00A - R0003 - Home Base - (47.81 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0001 - Practical Activities - 1hb - (20.29 SQM)	 Student Space (9)	
B00B - R0002 - Withdrawal Space - 1hb - (10.16 SQM)	 Student Space (4)	
B00B - R0004 - Home Base - (49.3 SQM) - Teaching Space: 1	 Student Space (22)	
B00F - R0001 - Communal Space - (59.86 SQM)	 Student Space (27)	
OS 502 15485 - OS 502 15485 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	