

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Rooty Hill High School (8908)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Mount Druit</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

8908 - Rooty Hill High School  
Site Plan (11243)



1:1,520

Printed: 28-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Multi Media Workshop - (66.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Computer Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0005 - Staff Study - (22.55 SQM)	○ Office (5)	
B00A - R0008 - Duplicating Workroom - (23.7 SQM)	○ Office (5)	
B00A - R0010 - Administration - Clerical - (11.22 SQM)	○ Office (2)	
B00A - R0011 - Administration - Clerical - (5.68 SQM)	○ Office (1)	
B00A - R0012 - Administration - Clerical - (34.77 SQM)	○ Office (8)	
B00A - R0015 - Movement - (17.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Multi-Purpose Space - (401.35 SQM)	● Student Space (186)	
B00A - R0018 - Stage - (115.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Student Canteen - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Principal Office - (23.12 SQM)	○ Office (5)	
B00A - R0022 - Movement - (22.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Deputy Principal Office - (18.22 SQM)	○ Office (4)	
B00A - R0032 - Interview/Office - Type 1 - (25.82 SQM)	○ Office (6)	
B00A - R0033 - Performance Workspace - (84.3 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0034 - Ancillary Staff - (12.61 SQM)	○ Office (3)	
B00A - R0035 - Clinic-Waiting - (8.04 SQM)	○ Office (2)	
B00A - R0038 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Movement - (23.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (113.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Movement - (68.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Special Learning Space - (39.16 SQM) - Teaching Space: 1	● Student Space (18)	
B00A - R1004 - Staff Study - (25.89 SQM)	○ Office (6)	
B00A - R1008 - Music Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1012 - Movement - (24.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Art Learning Space - (66.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1016 - Movement - (46.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1031 - Staff Lounge - (253.66 SQM)	○ Office (63)	
B00A - R1032 - Clerical Office - (12.02 SQM)	○ Office (3)	
B00A - R1034 - Staff Kitchen - (21.31 SQM)	○ Office (5)	
B00A - R1035 - Interview/Meeting - (26.43 SQM)	○ Office (6)	
B00A - R1039 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Movement - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Movement - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Wood Technology L.S. - (80.14 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0003 - Staff Study - (25.96 SQM)	○ Office (6)	
B00B - R0005 - Wood Technology L.S. - (79.42 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0006 - General Learning Space - (38.76 SQM) - Teaching Space: 1	● Student Space (17)	
B00B - R0008 - Movement - (14.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0013 - Materials Technology L.S. - (58.6 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0018 - Movement - (98.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Design L.S. - (46.49 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0029 - Workshop Area - (122.46 SQM)	● Student Space (56)	
B00B - R0032 - Outdoor Workshop - (54.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Movement - (21.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Student Canteen - (46.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0014 - General Assistants - (12.81 SQM)	Office (3)	
B00C - R0020 - Movement - (64.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (311.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Student Canteen - (243.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (93.15 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0002 - Staff Study - (25.96 SQM)	Office (6)	
B00D - R0003 - Staff Study - (20.74 SQM)	Office (5)	
B00D - R0007 - Study Space - (12.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Food Technology L.S. - (66 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0011 - Food Technology L.S. - (66.37 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0012 - Laboratory L.S. - (79.82 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0015 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Preparation - (9.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Preparation - (15.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (11.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Movement - (146.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Interview/Office - Type 1 - (12.82 SQM)	Office (3)	
B00D - R1005 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1008 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (66.37 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1013 - General Learning Space - (66.55 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1017 - Staff Study - (26.33 SQM)	Office (6)	
B00D - R1018 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1019 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1020 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (131.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0002 - General Learning Space - (53.03 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Staff Study - (15.58 SQM)	Office (3)	
B00E - R0004 - Staff Study - (12.14 SQM)	Office (3)	
B00E - R0006 - Staff Study - (25.67 SQM)	Office (6)	
B00E - R0011 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0013 - Laboratory L.S. - (90.57 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0014 - Preparation - (31.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Laboratory L.S. - (90.42 SQM) - Teaching Space: 1	Student Space (41)	
B00E - R0017 - Movement - (7.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Movement - (143.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Computer Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1002 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1003 - Staff Study - (39.46 SQM)	Office (9)	
B00E - R1004 - Staff Study - (25.81 SQM)	Office (6)	
B00E - R1009 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1010 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1011 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1013 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1014 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1021 - Movement - (140.61 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Laboratory L.S. - (100.31 SQM) - Teaching Space: 1	 Student Space (46)	
B00F - R0006 - Leading Teacher - (25.64 SQM)	 Office (6)	
B00F - R0007 - General Learning Space - (52.01 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0008 - General Learning Space - (60.48 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R0013 - Workshop - (51.93 SQM)	 Student Space (24)	
B00F - R0014 - Art Learning Space - (52.07 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R0015 - Workshop - (26.38 SQM)	 Student Space (12)	
B00F - R0020 - Laboratory L.S. - (92.1 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0025 - Movement - (29.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0030 - Materials Technology L.S. - (34.13 SQM) - Teaching Space: 1	 Student Space (15)	
B00F - R0035 - Preparation - Science - (38.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0036 - Movement - (186.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - General Learning Space - (60.55 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R1006 - Staff Study - (25.86 SQM)	 Office (6)	
B00F - R1008 - Staff Study - (19.16 SQM)	 Office (4)	
B00F - R1009 - Interview/Office - Type 1 - (12.97 SQM)	 Office (3)	
B00F - R1012 - General Learning Space - (60.6 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R1014 - General Learning Space - (60.7 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R1015 - General Learning Space - (52.01 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R1016 - General Learning Space - (52.44 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R1021 - Staff Study - (12.61 SQM)	 Office (3)	
B00F - R1022 - Staff Study - (12.61 SQM)	 Office (3)	
B00F - R1023 - General Learning Space - (65.34 SQM) - Teaching Space: 1	 Student Space (30)	
B00F - R1024 - Study Space - (25.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R1025 - General Learning Space - (52 SQM) - Teaching Space: 1	 Student Space (24)	
B00F - R1028 - Movement - (201.64 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Seminar - (12.77 SQM)	 Office (3)	
B00G - R0002 - Seminar - (12.77 SQM)	 Office (3)	
B00G - R0003 - Seminar - (12.77 SQM)	 Office (3)	
B00G - R0004 - Main Area - (417.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Computer Learning Space - (62.96 SQM) - Teaching Space: 1	 Student Space (29)	
B00G - R0015 - Main Entry - (52.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Senior Study - (59.58 SQM)	 Office (14)	
B00G - R0018 - Movement - (69.01 SQM)	Not Applicable	Circulation or storage space.
NS 200 12118 - NS 200 12118 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 601 12786 - OS 601 12786 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13919 - OS 601 13919 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14758 - OS 601 14758 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	