


VENTILATION AUDIT REPORT

SCHOOL:	Rosehill Public School (7444)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Parramatta
LOCAL GOVERNMENT AREA:	Parramatta

7444 - Rosehill Public School
Site Plan (10838)





















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (33.72 SQM)	Not Applicable	Circulation or storage space.
B001 - R0002 - Staff Room - (52.34 SQM)	Office (13)	
B001 - R0003 - Special Programs Room - (52.23 SQM)	Student Space (24)	
B001 - R0004 - Home Base - (61.77 SQM) - Teaching Space: 1	Student Space (28)	
B001 - R0005 - Practical Activities - 1hb - (21.62 SQM)	Student Space (10)	
B001 - R0006 - Movement - (15.61 SQM)	Not Applicable	Circulation or storage space.
B001 - R0007 - Withdrawal Space - 1hb - (31.35 SQM)	Student Space (14)	
B002 - R0001 - Movement - (11.78 SQM)	Not Applicable	Circulation or storage space.
B002 - R0002 - Home Base - (53.62 SQM) - Teaching Space: 1	Student Space (24)	
B002 - R0003 - Home Base - (54.61 SQM) - Teaching Space: 1	Student Space (25)	
B002 - R0004 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0006 - Movement - (44.57 SQM)	Not Applicable	Circulation or storage space.
B002 - R0007 - Movement - (10.42 SQM)	Not Applicable	Circulation or storage space.
B003 - R0004 - Home Base - (77.72 SQM) - Teaching Space: 1	Student Space (36)	
B004 - R0002 - Home Base - (54.18 SQM) - Teaching Space: 1	Student Space (25)	
B004 - R0003 - Home Base - (54.26 SQM) - Teaching Space: 1	Student Space (25)	
B004 - R0005 - Movement - (25.82 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Reading Area - (98.18 SQM)	Student Space (45)	
B005 - R0002 - Reading Area - (38.24 SQM)	Student Space (17)	
B005 - R0003 - Movement - (13.37 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B005 - R1001 - Home Base - (48.95 SQM) - Teaching Space: 1	Student Space (22)	
B005 - R1002 - Home Base - (50.38 SQM) - Teaching Space: 1	Student Space (23)	
B005 - R1003 - Movement - (38.59 SQM)	Not Applicable	Circulation or storage space.
B005 - R1005 - Movement - (9.66 SQM)	Not Applicable	Circulation or storage space.
B006 - R0002 - Home Base - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0003 - Home Base - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
B006 - R0005 - Movement - (22.66 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Interview - (17.51 SQM)	Office (4)	
B008 - R0004 - Practical Activities - 1hb - (13.32 SQM)	Student Space (6)	
B008 - R0005 - Home Base - (80.5 SQM) - Teaching Space: 1	Student Space (37)	
B008 - R0006 - Home Base - (55.88 SQM) - Teaching Space: 1	Student Space (25)	
B008 - R0007 - Practical Activities - 1hb - (5.52 SQM)	Student Space (2)	
B008 - R0008 - Home Base - (80.63 SQM) - Teaching Space: 1	Student Space (37)	
B008 - R0009 - Practical Activities - 1hb - (12.62 SQM)	Student Space (5)	
B008 - R0010 - Movement - (27.83 SQM)	Not Applicable	Circulation or storage space.
B008 - R0012 - Interview - (27.02 SQM)	Office (6)	
B008 - R0016 - Raised Platform - (18.18 SQM)	Not Applicable	Circulation or storage space.
B008 - R0017 - Communal Space - (70.3 SQM)	Student Space (32)	
B008 - R0018 - Movement - (43.87 SQM)	Not Applicable	Circulation or storage space.
B008 - R0020 - Movement - (19.98 SQM)	Not Applicable	Circulation or storage space.
B009 - R0001 - Movement - (29.58 SQM)	Not Applicable	Circulation or storage space.
B009 - R0002 - Home Base - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B009 - R0003 - Home Base - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B010 - R0002 - Home Base - (52.21 SQM) - Teaching Space: 1	Student Space (24)	
B010 - R0003 - Home Base - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B010 - R0004 - Movement - (27.03 SQM)	Not Applicable	Circulation or storage space.
B011 - R0008 - Clerical Office - (12.06 SQM)	Office (3)	
B011 - R0009 - Staff Kitchen - (11.8 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B011 - R0012 - Home Base - (91.87 SQM) - Teaching Space: 1	● Student Space (42)	
B011 - R0013 - Movement - (26.75 SQM)	Not Applicable	Circulation or storage space.
B011 - R1001 - Practical Activities - 1hb - (41.45 SQM)	● Student Space (19)	
B011 - R1008 - Home Base - Pre - (94.55 SQM) - Teaching Space: 1	● Student Space (43)	
B013 - R0001 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B013 - R0005 - Canteen - (16.76 SQM)	Not Applicable	Circulation or storage space.
B016 - R0002 - Interview - (12.89 SQM)	● Office (3)	
B016 - R0004 - Staff Room - (13.14 SQM)	● Office (3)	
B016 - R0005 - Interview - (14.39 SQM)	● Office (3)	
B016 - R0006 - Staff Room - (14.68 SQM)	● Office (3)	
B016 - R0007 - Entry Vestibule - (20.67 SQM)	Not Applicable	Circulation or storage space.
B016 - R0010 - Movement - (18.47 SQM)	Not Applicable	Circulation or storage space.
B016 - R0017 - Home Base - (67.19 SQM) - Teaching Space: 1	● Student Space (31)	
B018 - R0001 - Entry Vestibule - (22.93 SQM)	Not Applicable	Circulation or storage space.
B018 - R0002 - Clerical Office - (26.94 SQM)	● Office (6)	
B018 - R0003 - Duplicating Workroom - (23.62 SQM)	● Office (5)	
B018 - R0004 - Sick Bay - (8.8 SQM)	● Student Space (4)	
B018 - R0010 - Interview/Office - Type 3 - (16.9 SQM)	● Office (4)	
B018 - R0016 - Deputy Principal - Type 1 - (13.05 SQM)	● Office (3)	
B018 - R0017 - Principal - (17.19 SQM)	● Office (4)	
B018 - R0018 - Interview - (13.13 SQM)	● Office (3)	
B018 - R0022 - Movement - (70 SQM)	Not Applicable	Circulation or storage space.
B018 - R0025 - Study Annexe - (32.33 SQM)	● Office (8)	
B018 - R0026 - Interview - (14.94 SQM)	● Office (3)	
B018 - R0027 - Interview - (14.71 SQM)	● Office (3)	
B018 - R0028 - Principal - (26.6 SQM)	● Office (6)	
B018 - R0029 - Staff Room - (78.97 SQM)	● Office (19)	
B018 - R0030 - Staff Kitchen - (7.84 SQM)	● Office (1)	
B019 - R0001 - Communal Space - (203.91 SQM)	● Student Space (94)	
B019 - R0002 - Raised Platform - (60.63 SQM)	Not Applicable	Circulation or storage space.
B019 - R0020 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B019 - R0021 - Movement - (14.55 SQM)	Not Applicable	Circulation or storage space.
B023 - R0016 - Practical Activities - 4hb - (151.75 SQM)	● Student Space (70)	
B023 - R0017 - Home Base - (58.73 SQM) - Teaching Space: 1	● Student Space (27)	
B023 - R0018 - Withdrawal Space - 2hb - (12.14 SQM)	● Student Space (5)	
B023 - R0019 - Home Base - (57.56 SQM) - Teaching Space: 1	● Student Space (26)	
B023 - R0021 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B023 - R0022 - Withdrawal Space - 2hb - (11.73 SQM)	● Student Space (5)	
B023 - R0023 - Home Base - (56.7 SQM) - Teaching Space: 1	● Student Space (26)	
B023 - R1006 - Practical Activities - 4hb - (142.15 SQM)	● Student Space (65)	
B023 - R1007 - Home Base - (64.12 SQM) - Teaching Space: 1	● Student Space (29)	
B023 - R1008 - Withdrawal Space - 2hb - (12.14 SQM)	● Student Space (5)	
B023 - R1009 - Home Base - (64.36 SQM) - Teaching Space: 1	● Student Space (29)	
B023 - R1011 - Home Base - (67.3 SQM) - Teaching Space: 1	● Student Space (31)	
B023 - R1012 - Withdrawal Space - 2hb - (11.69 SQM)	● Student Space (5)	
B023 - R1013 - Home Base - (63.41 SQM) - Teaching Space: 1	● Student Space (29)	
B023 - R1017 - Practical Activities - 3hb - (116.67 SQM)	● Student Space (54)	
B023 - R1018 - Home Base - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B023 - R1019 - Withdrawal Space - 2hb - (9.06 SQM)	 Student Space (4)	
B023 - R1021 - Home Base - (63.14 SQM) - Teaching Space: 1	 Student Space (29)	
B023 - R1022 - Withdrawal Space - 2hb - (11.39 SQM)	 Student Space (5)	
B023 - R1023 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
B023 - R2006 - Practical Activities - 4hb - (138.75 SQM)	 Student Space (64)	
B023 - R2007 - Home Base - (64.12 SQM) - Teaching Space: 1	 Student Space (29)	
B023 - R2008 - Withdrawal Space - 2hb - (12.14 SQM)	 Student Space (5)	
B023 - R2009 - Home Base - (64.36 SQM) - Teaching Space: 1	 Student Space (29)	
B023 - R2011 - Home Base - (67.32 SQM) - Teaching Space: 1	 Student Space (31)	
B023 - R2012 - Withdrawal Space - 2hb - (11.69 SQM)	 Student Space (5)	
B023 - R2013 - Home Base - (63.38 SQM) - Teaching Space: 1	 Student Space (29)	
B023 - R2017 - Practical Activities - 3hb - (116.17 SQM)	 Student Space (53)	
B023 - R2018 - Home Base - (59.62 SQM) - Teaching Space: 1	 Student Space (27)	
B023 - R2019 - Withdrawal Space - 2hb - (9.06 SQM)	 Student Space (4)	
B023 - R2021 - Home Base - (63.14 SQM) - Teaching Space: 1	 Student Space (29)	
B023 - R2022 - Withdrawal Space - 2hb - (11.39 SQM)	 Student Space (5)	
B023 - R2023 - Home Base - (60.34 SQM) - Teaching Space: 1	 Student Space (27)	
OS 606 19046 - OS 606 19046 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	