










Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (13.23 SQM)	Office (3)	
B00A - R0004 - Sick Bay - (9.33 SQM)	Student Space (4)	
B00A - R0005 - Principal - (19.02 SQM)	Office (4)	
B00A - R0007 - Movement - (5.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Interview - (13.23 SQM)	Office (3)	
B00A - R0015 - Staff Room Annexe - (14.1 SQM)	Office (3)	
B00A - R0016 - Staff Room Annexe - (14.44 SQM)	Office (3)	
B00A - R0020 - Staff Room Annexe - (24.66 SQM)	Office (6)	
B00A - R0022 - Movement - (38.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Staff Room - (51.4 SQM)	Office (12)	
B00A - R0025 - Clerical/Printing - (20.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Interview/Office - Type 3 - (12.22 SQM)	Office (3)	
B00A - R0033 - Interview/Office - Type 3 - (7.65 SQM)	Office (1)	
B00A - R0034 - Interview/Office - Type 3 - (12.53 SQM)	Office (3)	
B00A - R0035 - Staff Kitchen - (9.76 SQM)	Office (2)	
B00A - R0037 - Movement - (12.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Interview - (6.07 SQM)	Office (1)	
B00A - R0039 - Interview - (6.07 SQM)	Office (1)	
B00A - R0042 - Principal - (18.42 SQM)	Office (4)	
B00A - R0043 - Deputy Principal - (18.46 SQM)	Office (4)	
B00B - R0003 - Reading Area - (230.9 SQM)	Student Space (107)	
B00B - R0004 - Special Programs Room - (40.12 SQM)	Student Space (18)	
B00C - R0008 - Communal Space - (207.17 SQM)	Student Space (96)	
B00C - R0009 - Raised Platform - (46.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Practical Activities - 1hb - (40.17 SQM)	Student Space (18)	
B00D - R0007 - Home Base - (61.29 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0009 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	
B00D - R0011 - Home Base - (61.29 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0002 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Practical Activities - 1hb - (40.12 SQM)	Student Space (18)	
B00E - R0007 - Home Base - (61.29 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0009 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	
B00E - R0011 - Home Base - (61.2 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0002 - Practical Activities - 1hb - (41.3 SQM)	Student Space (19)	
B00F - R0003 - Home Base - (61.29 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0006 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	
B00F - R0008 - Home Base - (60.62 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0019 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0021 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	
B00F - R0023 - Home Base - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0029 - Practical Activities - 1hb - (41.42 SQM)	Student Space (19)	
B00F - R0031 - Home Base - (60.62 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0033 - Withdrawal Space - 1hb - (11.46 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0035 - Home Base - (61.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0038 - Practical Activities - (41.35 SQM)	● Student Space (19)	
B00G - R0003 - Practical Activities - 1hb - (40.03 SQM)	● Student Space (18)	
B00G - R0006 - Home Base - (61.29 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0008 - Withdrawal Space - 1hb - (11.45 SQM)	● Student Space (5)	
B00G - R0010 - Home Base - (61.29 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0012 - Movement - (7.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Practical Activities - 1hb - (40.17 SQM)	● Student Space (18)	
B00H - R0008 - Home Base - (61.29 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0010 - Withdrawal Space - 1hb - (11.46 SQM)	● Student Space (5)	
B00H - R0012 - Home Base - (61.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0003 - Canteen - (42.14 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00J - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00J - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
B00K - R0004 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0008 - Practical Activities - 1hb - (18.66 SQM)	● Student Space (8)	
B00K - R0010 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00K - R0011 - Withdrawal Space - 1hb - (7.68 SQM)	● Student Space (3)	
B00K - R0013 - Home Base - (59.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0002 - Practical Activities - 1hb - (19.24 SQM)	● Student Space (8)	
B00L - R0003 - Home Base - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 1hb - (7.64 SQM)	● Student Space (3)	
B00L - R0007 - Practical Activities - 1hb - (18.58 SQM)	● Student Space (8)	
B00L - R0009 - Home Base - (60.57 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0010 - Withdrawal Space - 2hb - (11.81 SQM)	● Student Space (5)	
B00L - R0011 - Home Base - (60.79 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0013 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B00L - R0014 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Special Programs Room - (33.3 SQM)	● Student Space (15)	
B00N - R0001 - Practical Activities - (74.59 SQM)	● Student Space (34)	
B00N - R1001 - Clerical Office - (51.39 SQM)	● Office (12)	
B00N - R1002 - Clerical Office - (12.49 SQM)	● Office (3)	
B00N - R1003 - Clerical Office - (12.55 SQM)	● Office (3)	
B00R - R0001 - Special Programs Room - (50.87 SQM)	● Student Space (23)	
NS 101 12854 - NS 101 12854 - Learning Unit - Double Primary/PAA - (133 SQM)	● Student Space (61)	
OS 600 18338 - OS 600 18338 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 602 10786 - OS 602 10786 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11056 - OS 602 11056 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11386 - OS 602 11386 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 11390 - OS 602 11390 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11466 - OS 602 11466 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12756 - OS 602 12756 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15609 - OS 602 15609 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16636 - OS 602 16636 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 16788 - OS 603 16788 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 14695 - OS 606 14695 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	