

VENTILATION AUDIT REPORT

SCHOOL:	Roseville Public School (2994)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Davidson
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

2994 - Roseville Public School
Site Plan (11247)



1:761

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (27.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Special Programs Room - (42.86 SQM)	● Student Space (19)	
B00A - R0012 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Reading Area - (237.6 SQM)	● Student Space (110)	
B00B - R0001 - Clerical Office - (22.31 SQM)	● Office (5)	
B00B - R0002 - Sick Bay - (9.63 SQM)	● Student Space (4)	
B00B - R0005 - Interview - (16.73 SQM)	● Office (4)	
B00B - R0006 - Duplicating Workroom - (32.36 SQM)	● Office (8)	
B00B - R0007 - Staff Room Annexe - (27.23 SQM)	● Office (6)	
B00B - R0014 - Principal - (14.21 SQM)	● Office (3)	
B00B - R0015 - Deputy Principal - (13.41 SQM)	● Office (3)	
B00B - R0016 - Movement - (78.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Entry Vestibule - (28.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Room - (52.93 SQM)	● Office (13)	
B00B - R0020 - Staff Kitchen - (9.53 SQM)	● Office (2)	
B00C - R0002 - Raised Platform - (36.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (58.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (32.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Canteen - (43.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Movement - (8.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Communal Space - (261.83 SQM)	● Student Space (121)	
B00C - R0037 - Movement - (59.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (5.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (18.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Room Annexe - (11.21 SQM)	● Office (2)	
B00D - R0009 - Practical Activities - 1hb - (75.46 SQM)	● Student Space (35)	
B00D - R0012 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (7.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Home Base - (47.34 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0025 - Movement - (14.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Home Base - (56.26 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0028 - Movement - (102.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Home Base - (63.07 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0032 - Home Base - (60.44 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0033 - Practical Activities - 2hb - (15.85 SQM)	● Student Space (7)	
B00D - R0034 - Practical Activities - 2hb - (17.5 SQM)	● Student Space (8)	
B00D - R1005 - Practical Activities - 1hb - (48.72 SQM)	● Student Space (22)	
B00D - R1006 - Home Base - (48.92 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1011 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Movement - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Movement - (94.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Home Base - (64.52 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1021 - Home Base - (64.51 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1022 - Practical Activities - 2hb - (17.31 SQM)	● Student Space (8)	
B00D - R1023 - Practical Activities - 2hb - (16.85 SQM)	● Student Space (7)	
B00G - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00H - R0001 - Home Base - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0002 - Home Base - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0003 - Home Base - (59.81 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0004 - Home Base - (59.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0006 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00H - R0007 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R0008 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B00H - R0011 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B00H - R0012 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R0013 - Practical Activities - 1hb - (18.64 SQM)	● Student Space (8)	
B00H - R1001 - Home Base - (59.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1002 - Home Base - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1003 - Home Base - (59.81 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1004 - Home Base - (59.82 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1005 - Home Base - (56.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R1007 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00H - R1008 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R1009 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B00H - R1012 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B00H - R1013 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R1014 - Practical Activities - 1hb - (18.64 SQM)	● Student Space (8)	
B00H - R1016 - Withdrawal Space - 1hb - (9.09 SQM)	● Student Space (4)	
B00H - R1018 - Practical Activities - 1hb - (21.38 SQM)	● Student Space (9)	
B00H - R2001 - Home Base - (58.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R2002 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R2003 - Home Base - (59.81 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R2004 - Home Base - (59.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R2005 - Home Base - (56.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R2007 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00H - R2008 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R2009 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B00H - R2012 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B00H - R2013 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00H - R2014 - Practical Activities - 1hb - (18.64 SQM)	● Student Space (8)	
B00H - R2016 - Withdrawal Space - 1hb - (9.09 SQM)	● Student Space (4)	
B00H - R2018 - Practical Activities - 1hb - (21.39 SQM)	● Student Space (9)	
B00I - R0001 - Home Base - (60.31 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0002 - Home Base - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0004 - Practical Activities - 1hb - (19.78 SQM)	● Student Space (9)	
B00I - R0005 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00I - R0006 - Practical Activities - 1hb - (19.82 SQM)	● Student Space (9)	
B00I - R1001 - Home Base - (60.31 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R1002 - Home Base - (60.16 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R1004 - Practical Activities - 1hb - (19.78 SQM)	 Student Space (9)	
B00I - R1005 - Withdrawal Space - 2hb - (11.53 SQM)	 Student Space (5)	
B00I - R1006 - Practical Activities - 1hb - (19.82 SQM)	 Student Space (9)	