

# VENTILATION AUDIT REPORT


















<b>SCHOOL:</b>	<b>Rous Public School (3006)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Ballina</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ballina</b>

3006 - Rous Public School  
Site Plan (10697)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Reading Area - (49.12 SQM)	 Student Space (22)	
B00A - R0002 - Principal - (10.51 SQM)	 Office (2)	
B00A - R0003 - Movement - (9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (60.27 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0005 - Clerical Office/Workroom - (9.73 SQM)	 Office (2)	
B00A - R0006 - Practical Activities - 1hb - (19.74 SQM)	 Student Space (9)	
B00A - R0007 - Home Base - (47.58 SQM) - Teaching Space: 1	 Student Space (22)	
B00A - R0008 - Practical Activities - 1hb - (25.43 SQM)	 Student Space (11)	
B00C - R0001 - Movement - (27.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Communal Space - (138.77 SQM)	 Student Space (64)	
B00E - R0003 - Staff Kitchen - (9.69 SQM)	 Office (2)	
B00E - R0009 - Staff Room - (27.17 SQM)	 Office (6)	
B00E - R0011 - Reading Area - (61.05 SQM)	 Student Space (28)	
B00I - R0002 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00I - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00I - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
OS 505 12582 - OS 505 12582 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	