


VENTILATION AUDIT REPORT

SCHOOL:	Rowland Hassall School (5411)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

5411 - Rowland Hassall School
Site Plan (13312)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0A1 - R0001 - Home Base - M - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B0A1 - R0002 - Home Base - M - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B0A1 - R0003 - Home Base - M - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B0A1 - R0004 - Home Base - M - (63.77 SQM) - Teaching Space: 1	● Student Space (29)	
B0A1 - R001A - Breakout Area - (11.87 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R001B - Withdrawal - M - (8.58 SQM)	● Student Space (3)	
B0A1 - R002A - Breakout Area - (11.8 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R002B - Withdrawal - M - (8.61 SQM)	● Student Space (3)	
B0A1 - R003A - Breakout Area - (11.77 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R003B - Withdrawal - M - (8.58 SQM)	● Student Space (3)	
B0A1 - R004A - Breakout Area - (12.63 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R004B - Withdrawal - M - (10.15 SQM)	● Student Space (4)	
B0B1 - R0005 - Home Base - M - (56.57 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0006 - Home Base - M - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0007 - Home Base - M - (56.91 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0008 - Home Base - M - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0009 - Home Base - M - (57 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0010 - Home Base - M - (57.55 SQM) - Teaching Space: 1	● Student Space (26)	
B0B1 - R0011 - Isolation Space - (41.13 SQM)	● Office (10)	
B0B1 - R005A - Breakout Area - (11.81 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R005B - Withdrawal - M - (8.58 SQM)	● Student Space (3)	
B0B1 - R006A - Breakout Area - (11.81 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R006B - Withdrawal - M - (8.64 SQM)	● Student Space (4)	
B0B1 - R007A - Breakout Area - (11.8 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R007B - Withdrawal - M - (8.64 SQM)	● Student Space (4)	
B0B1 - R008A - Breakout Area - (11.93 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R008B - Withdrawal - M - (8.58 SQM)	● Student Space (3)	
B0B1 - R009A - Breakout Area - (11.67 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R009B - Withdrawal - M - (8.61 SQM)	● Student Space (3)	
B0B1 - R010A - Breakout Area - (11.95 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R010B - Withdrawal - M - (8.58 SQM)	● Student Space (3)	
BOC1 - R0023 - Entry Vestibule - (8.05 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0024 - Clerical Office - (19.47 SQM)	● Office (4)	
BOC1 - R0025 - Sick Bay - (7.47 SQM)	● Student Space (3)	
BOC1 - R0026 - Movement - (20.5 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0030 - Interview - (10.28 SQM)	● Office (2)	
BOC1 - R0031 - Principal - (21.87 SQM)	● Office (5)	
BOC1 - R0032 - Deputy Principal - Type 2 - (19.29 SQM)	● Office (4)	
BOC1 - R0033 - Staff Room - (26.44 SQM)	● Office (6)	
BOC1 - R0034 - Staff Room Annexe - (23.37 SQM)	● Office (5)	
BOC1 - R0043 - Communal Space - (119.93 SQM)	● Student Space (55)	
BOC1 - R0044 - Reading Area - (89.25 SQM)	● Student Space (41)	
BOC1 - R0048 - Special Programs Room - (72.4 SQM)	● Student Space (33)	
BOC1 - R0049 - Canteen - (16.23 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0054 - Special Programs Room - (7.89 SQM)	● Student Space (3)	
BOC1 - R0057 - Special Programs Room - (42.74 SQM)	● Student Space (19)	
BOC1 - R0059 - Special Programs Room - (42.68 SQM)	● Student Space (19)	
BOC1 - R0060 - Special Programs Room - (48.32 SQM)	● Student Space (22)	