

VENTILATION AUDIT REPORT

SCHOOL:	Royal Far West School (5504)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Manly
LOCAL GOVERNMENT AREA:	Northern Beaches

5504 - Royal Far West School
Site Plan (15731)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1002 - Home Base/Practical Activities - M - (45.13 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R1005 - Outdoor Learning Area - (74.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Interview - (10.37 SQM)	● Office (2)	
B00B - R1007 - Deputy Principal - Type 1 - (11.83 SQM)	● Office (2)	
B00B - R1017 - Movement - (212.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R2001 - Home Base - M - (41.27 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R2002 - Home Base/Practical Activities - M - (27.8 SQM) - Teaching Space: 1	● Student Space (12)	
B00B - R2006 - Home Base/Practical Activities - M - (25.68 SQM) - Teaching Space: 1	● Student Space (11)	
B00B - R2007 - Withdrawal - M - (10.33 SQM)	● Student Space (4)	
B00B - R2008 - Principal - (11.95 SQM)	● Office (2)	
B00B - R2011 - Interview - (14.19 SQM)	● Office (3)	
B00B - R2016 - Movement - (175.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R2018 - Home Base - (69.39 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R3001 - Outdoor Learning Area - (197.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R3002 - Staff Kitchen - (19.15 SQM)	● Office (4)	
B00B - R3004 - Movement - (65.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R3005 - Movement - (9.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R3006 - Movement - (38.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R3008 - Home Base - M - (40.85 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R3009 - Home Base/Practical Activities - M - (28.25 SQM) - Teaching Space: 1	● Student Space (13)	
B00B - R3011 - Interview - (72.99 SQM)	● Office (18)	
B00B - R3014 - Interview - (9.18 SQM)	● Office (2)	