

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Rozelle Public School (7435)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Balmain</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Inner West</b>

7435 - Rozelle Public School  
Site Plan (13158)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (23.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Practical Activities - 1hb - (20.54 SQM)	● Student Space (9)	
B00A - R0003 - Home Base - (47.6 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0004 - Home Base - (48.4 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0005 - Practical Activities - 1hb - (17.94 SQM)	● Student Space (8)	
B00A - R0006 - Staff Room - (87.54 SQM)	○ Office (21)	
B00A - R0007 - Movement - (9.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (31.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Interview - (14.88 SQM)	○ Office (3)	
B00A - R0014 - Interview - (20.26 SQM)	○ Office (5)	
B00A - R0015 - Sick Bay - (10.57 SQM)	● Student Space (4)	
B00A - R0016 - Principal - (18.77 SQM)	○ Office (4)	
B00A - R0018 - Movement - (38.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Practical Activities - 1hb - (14.44 SQM)	● Student Space (6)	
B00A - R0022 - Home Base - (55.48 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0023 - Movement - (35.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Home Base - (62.1 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0025 - Practical Activities - 1hb - (14.07 SQM)	● Student Space (6)	
B00A - R0027 - Movement - (22.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (11.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Movement - (55.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Clerical Office - (13.73 SQM)	○ Office (3)	
B00A - R0035 - Deputy Principal - Type 1 - (10.29 SQM)	○ Office (2)	
B00A - R0040 - Special Programs Room - (22.94 SQM)	● Student Space (10)	
B00A - R1001 - Practical Activities - 1hb - (18.01 SQM)	● Student Space (8)	
B00A - R1002 - Home Base - (48.33 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1003 - Home Base - (50.45 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1004 - Practical Activities - 1hb - (16.5 SQM)	● Student Space (7)	
B00A - R1005 - Practical Activities - 1hb - (18.18 SQM)	● Student Space (8)	
B00A - R1006 - Home Base - (70.14 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1007 - Movement - (26.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Practical Activities - 1hb - (18.21 SQM)	● Student Space (8)	
B00A - R1011 - Home Base - (45.45 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1012 - Home Base - (62.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1013 - Practical Activities - 1hb - (18.14 SQM)	● Student Space (8)	
B00A - R1015 - Movement - (31.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Home Base - (74.62 SQM) - Teaching Space: 1	● Student Space (34)	
B00A - R1017 - Home Base - (74.31 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0002 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Duplicating Workroom - (32.05 SQM)	○ Office (8)	
B00B - R0007 - Movement - (45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (19.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (67.74 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0016 - Movement - (14.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Special Programs Room - (64.53 SQM)	● Student Space (29)	
B00B - R0019 - Home Base - (71.62 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R1010 - Movement - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Reading Area - (142.97 SQM) - Teaching Space: 2	● Student Space (66)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1015 - Practical Activities - (37.33 SQM)	Student Space (17)	
B00B - R1016 - Movement - (31.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Home Base - (90.68 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0008 - Home Base - (58.48 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0011 - Home Base - (82.38 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0013 - Movement - (66.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Home Base - (43.45 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R1002 - Movement - (56.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1005 - Practical Activities - 1hb - (46.07 SQM)	Student Space (21)	
B00D - R0005 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Staff Kitchen - (6.82 SQM)	Office (1)	
B00E - R0023 - Home Base - (70.23 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R0024 - Home Base - (71.58 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0029 - Home Base - (88.15 SQM)	Student Space (40)	
B00E - R0030 - Communal Space - (62.78 SQM)	Student Space (29)	
B00E - R0031 - Practical Activities - (35.59 SQM)	Student Space (16)	
B00E - R0037 - Seminar/Study - (11.55 SQM)	Office (2)	
B00E - R0038 - Reading Area - (154.12 SQM)	Student Space (71)	
B00E - R0042 - Raised Platform - (13.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0043 - Movement - (47.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Withdrawal Space - 1hb - (12.47 SQM)	Student Space (5)	
B00E - R1008 - Practical Activities - 1hb - (7.36 SQM)	Student Space (3)	
B00E - R1009 - Home Base - (62.5 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R1010 - Home Base - (72.19 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R1012 - Movement - (54.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R1013 - Movement - (19.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R9007 - Home Base - Pre - (61.52 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R9008 - Practical Activities - Pre - (29.13 SQM)	Student Space (13)	
B00E - R9011 - Movement - (47.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Movement - (44.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0027 - Canteen - (39.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0034 - Movement - (21.94 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Movement - (23.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R1008 - Darkroom Space - (31.92 SQM)	Office (7)	
B00F - R9003 - Communal Space - (402.27 SQM)	Student Space (186)	
B00F - R9005 - Special Programs Room - (34.12 SQM)	Student Space (15)	
B00F - R9010 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.