


VENTILATION AUDIT REPORT

SCHOOL:	Ruse Public School (4489)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Campbelltown
LOCAL GOVERNMENT AREA:	Campbelltown

4489 - Ruse Public School
Site Plan (10701)



1:1,186

Printed: 17-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (14.2 SQM)	Office (3)	
B00A - R0003 - Sick Bay - (8.02 SQM)	Student Space (3)	
B00A - R0004 - Duplicating Workroom - (21.8 SQM)	Office (5)	
B00A - R0016 - Interview - (9.89 SQM)	Office (2)	
B00A - R0018 - Deputy Principal - (13.97 SQM)	Office (3)	
B00A - R0019 - Principal - (21.82 SQM)	Office (5)	
B00A - R0020 - Deputy Principal - (11.58 SQM)	Office (2)	
B00A - R0021 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (23.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (96.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (26.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Staff Kitchen - (11.76 SQM)	Office (2)	
B00A - R0027 - Movement - (23.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Entry Vestibule - (8.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Staff Room - (79.97 SQM)	Office (19)	
B00B - M0001 - Movement - (21.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (49.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (16.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (16.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (262.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Communal Space - (263.99 SQM)	Student Space (122)	
B00B - R0022 - Raised Platform - (59.49 SQM)	Not Applicable	Circulation or storage space.
B00C - M0001 - Withdrawal Space - 1hb - (35.2 SQM)	Student Space (16)	
B00C - R0001 - Home Base - (42.27 SQM) - Teaching Space: 1	Student Space (19)	
B00C - R0002 - Practical Activities - 1hb - (16.28 SQM)	Student Space (7)	
B00C - R0003 - Withdrawal Space - 1hb - (7.92 SQM)	Student Space (3)	
B00C - R0004 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Withdrawal Space - 1hb - (7.39 SQM)	Student Space (3)	
B00C - R0016 - Special Programs Room - (43.33 SQM)	Student Space (20)	
B00C - R0017 - Practical Activities - 1hb - (11.69 SQM)	Student Space (5)	
B00C - R0019 - Home Base - (37.83 SQM) - Teaching Space: 1	Student Space (17)	
B00C - R0020 - Practical Activities - 1hb - (13.7 SQM)	Student Space (6)	
B00C - R0022 - Withdrawal Space - 1hb - (12.65 SQM)	Student Space (5)	
B00C - R0024 - Movement - (38.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (257.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (9.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Home Base - (50.08 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0028 - Practical Activities - 1hb - (10.62 SQM)	Student Space (4)	
B00C - R0029 - Withdrawal Space - 1hb - (6.81 SQM)	Student Space (3)	
B00C - R0035 - Practical Activities - 1hb - (13.76 SQM)	Student Space (6)	
B00C - R0036 - Home Base - (45.99 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0037 - Withdrawal Space - 1hb - (8.15 SQM)	Student Space (3)	
B00C - R0038 - Home Base - (46.14 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0039 - Withdrawal Space - 1hb - (9.41 SQM)	Student Space (4)	
B00C - R0040 - Practical Activities - 1hb - (24.3 SQM)	Student Space (11)	
B00C - R0041 - Withdrawal Space - 1hb - (9.65 SQM)	Student Space (4)	
B00C - R0042 - Home Base - (45.74 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0045 - Movement - (45.58 SQM)	Not Applicable	Circulation or storage space.
B00D - M0001 - Withdrawal Space - 1hb - (39.11 SQM)	Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - M0002 - Withdrawal Space - 1hb - (38.74 SQM)	● Student Space (17)	
B00D - R0001 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Withdrawal Space - 1hb - (5.89 SQM)	● Student Space (2)	
B00D - R0007 - Practical Activities - 1hb - (17.79 SQM)	● Student Space (8)	
B00D - R0009 - Home Base - (46.05 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0010 - Withdrawal Space - 1hb - (8.9 SQM)	● Student Space (4)	
B00D - R0011 - Practical Activities - 1hb - (26.01 SQM)	● Student Space (12)	
B00D - R0013 - Withdrawal Space - 1hb - (8.03 SQM)	● Student Space (3)	
B00D - R0014 - Home Base - (46.41 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0016 - Withdrawal Space - 1hb - (7.93 SQM)	● Student Space (3)	
B00D - R0018 - Movement - (92.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (175.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Movement - (96.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Movement - (8.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Withdrawal Space - 1hb - (8.21 SQM)	● Student Space (3)	
B00D - R0039 - Home Base - (46.11 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0040 - Withdrawal Space - 1hb - (9.21 SQM)	● Student Space (4)	
B00D - R0041 - Practical Activities - 1hb - (24.2 SQM)	● Student Space (11)	
B00D - R0044 - Withdrawal Space - 1hb - (9.3 SQM)	● Student Space (4)	
B00D - R0045 - Home Base - (46.26 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0047 - Practical Activities - 1hb - (17.77 SQM)	● Student Space (8)	
B00D - R0048 - Withdrawal Space - 1hb - (6.4 SQM)	● Student Space (2)	
B00D - R0049 - Movement - (91.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0052 - Clerical/Printing - (38.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0054 - Home Base - (39.77 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0056 - Home Base - (40.62 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0057 - Practical Activities/Movement - 1hb - (14.28 SQM)	● Student Space (6)	
B00D - R0059 - Home Base - (40.62 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0060 - Practical Activities/Movement - 1hb - (14.16 SQM)	● Student Space (6)	
B00E - R0001 - Reading Area - (235.95 SQM)	● Student Space (109)	
B00E - R0004 - Movement - (8.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (117.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Practical Activities - 1hb - (23.71 SQM)	● Student Space (11)	
B00G - R0024 - Communal Space - (91.08 SQM)	● Student Space (42)	
B00G - R0025 - Movement - (143.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Home Base - (57.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0027 - Practical Activities/Movement - 1hb - (13.09 SQM)	● Student Space (6)	
B00G - R0031 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0032 - Practical Activities/Movement - 1hb - (13.4 SQM)	● Student Space (6)	
B00G - R0034 - Home Base - (60.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0035 - Home Base - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0009 - Practical Activities - 1hb - (23.66 SQM)	● Student Space (10)	
B00H - R0018 - Movement - (141.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Withdrawal Space - 1hb - (13.14 SQM)	● Student Space (6)	
B00H - R0020 - Withdrawal Space - 1hb - (12.77 SQM)	● Student Space (5)	
B00H - R0021 - Communal Space - (91.14 SQM)	● Student Space (42)	
B00H - R0026 - Special Programs Room - (59.31 SQM)	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0028 - Home Base - (59.42 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0030 - Home Base - (57.37 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0031 - Practical Activities/Movement - 1hb - (13.17 SQM)	● Student Space (6)	
B00H - R0033 - Home Base - (57.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0034 - Practical Activities/Movement - 1hb - (13.05 SQM)	● Student Space (6)	