

VENTILATION AUDIT REPORT

SCHOOL:	Russell Vale Public School (3973)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

3973 - Russell Vale Public School
Site Plan (11250)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Home Base - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0007 - Movement - (34.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (14.17 SQM)	● Student Space (6)	
B00B - R0004 - Home Base - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0005 - Home Base - (53.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0006 - Movement - (32.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (9.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Deputy Principal - (12.58 SQM)	● Office (3)	
B00B - R0010 - Movement - (33.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0012 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0014 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Staff Room - (29.89 SQM)	● Office (7)	
B00B - R0022 - Staff Kitchen - (9.82 SQM)	● Office (2)	
B00C - R0003 - Movement - (23.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Deputy Principal - (28.25 SQM)	● Office (7)	
B00C - R0008 - Practical Activities - 1hb - (10.61 SQM)	● Student Space (4)	
B00C - R0009 - Home Base - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - Home Base - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0002 - Special Programs Room - (64.26 SQM)	● Student Space (29)	
B00G - R0001 - Communal Space - (145.26 SQM)	● Student Space (67)	
B00G - R0002 - Raised Platform - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
OS 502 13680 - OS 502 13680 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 534 13682 - OS 534 13682 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 13458 - OS 601 13458 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14416 - OS 601 14416 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 18324 - OS 602 18324 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 18205 - OS 606 18205 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 801 13681 - OS 801 13681 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.