

VENTILATION AUDIT REPORT

SCHOOL:	Rutherford Technology High School (8572)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Maitland
LOCAL GOVERNMENT AREA:	Maitland

8572 - Rutherford Technology High School
Site Plan (11251)



1:2,105

Printed: 15-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (37.66 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0004 - General Learning Space - (48.3 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - General Learning Space - (48.88 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0007 - Staff Study - (26.7 SQM)	Office (6)	
B00A - R0008 - General Learning Space - (48.87 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0012 - General Learning Space - (48.39 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0013 - General Learning Space - (47.98 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0014 - General Learning Space - (48.32 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0018 - General Learning Space - (48.8 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0023 - General Learning Space - (48.46 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0024 - General Learning Space - (43.64 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0025 - Staff Study - (41.47 SQM)	Office (10)	
B00A - R0026 - Movement - (395.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (17.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (14.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Study - (37.66 SQM)	Office (9)	
B00A - R1004 - General Learning Space - (47.97 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - General Learning Space - (47.61 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - Staff Study - (26.71 SQM)	Office (6)	
B00A - R1008 - General Learning Space - (48.32 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1018 - Computer Learning Space - (47.97 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1021 - Interview/Office - Type 1 - (12.79 SQM)	Office (3)	
B00A - R1023 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1024 - General Learning Space - (43.35 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R1025 - Staff Study - (41.37 SQM)	Office (10)	
B00A - R1026 - Movement - (17.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1030 - Staff Study - (39.48 SQM)	Office (9)	
B00A - R1033 - Staff Lounge - (132.87 SQM)	Office (33)	
B00A - R1034 - Staff Kitchen - (12.69 SQM)	Office (3)	
B00A - R1035 - Movement - (349.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R1036 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (16.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Seminar - (10.96 SQM)	Office (2)	
B00B - R0003 - Seminar - (10.81 SQM)	Office (2)	
B00B - R0004 - Audio Visual Workroom - (42.35 SQM)	Student Space (19)	
B00B - R0006 - Workroom - (47.71 SQM)	Office (11)	
B00B - R0007 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Main Area - (376.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (134.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (36.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Interview/Meeting - (18.87 SQM)	Office (4)	
B00B - R1001 - Seminar - (15.2 SQM)	Office (3)	
B00B - R1002 - Seminar - (15.1 SQM)	Office (3)	
B00B - R1003 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Senior Study - (73.67 SQM)	Office (18)	
B00B - R1005 - Movement - (22.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Movement - (84.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Practice/Seminar - (27.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Practice/Seminar - (27.01 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0006 - Music Learning Space - (62.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0007 - Movement - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Staff Study - (15.56 SQM)	● Office (3)	
B00C - R0010 - Music Learning Space - (74.74 SQM) - Teaching Space: 1	● Student Space (34)	
B00C - R1001 - Interview/Office - Type 1 - (14.21 SQM)	● Office (3)	
B00C - R1004 - Commonroom - (104.77 SQM)	● Office (26)	
B00C - R1006 - Movement - (108.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Laboratory L.S. - (82.38 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0013 - Laboratory L.S. - (81.05 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0015 - Laboratory L.S. - (81.3 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0016 - Laboratory L.S. - (81.58 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0017 - Preparation - (33.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Laboratory L.S. - (81.48 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0019 - Laboratory L.S. - (81.58 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0020 - Preparation - (36.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Preparation - Science - (28.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Movement - (113.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Staff Study - (51.66 SQM)	● Office (12)	
B00D - R1001 - Food Technology L.S. - (107.1 SQM) - Teaching Space: 1	● Student Space (49)	
B00D - R1008 - Materials Technology L.S. - (70.28 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R1012 - Movement - (63.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - General Learning Space - Type 6 - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1017 - Staff Study - (46.39 SQM)	● Office (11)	
B00D - R1019 - Movement - (48.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Kitchen - Type 1 - (139.9 SQM)	● Student Space (64)	
B00D - R1026 - Preparation - Materials - (21.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Stage - (102.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (7.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Multi-Purpose Space - (485.72 SQM)	● Student Space (225)	
B00E - R0020 - Staff Study - (50.46 SQM)	● Office (12)	
B00E - R0021 - Staff Kitchen - (5.01 SQM)	● Office (1)	
B00E - R9005 - Movement - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R9011 - Movement - (15.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Principal Office - (21.8 SQM)	● Office (5)	
B00F - R0011 - Ancillary Staff - (23.88 SQM)	● Office (5)	
B00F - R0016 - Student Canteen - (60.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0032 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0035 - Movement - (22.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0039 - Movement - (52.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0042 - Clinic - Girls - (12.55 SQM)	● Office (3)	
B00F - R0043 - Clinic - Boys - (13.21 SQM)	● Office (3)	
B00F - R0044 - Deputy Principal Office - (13.08 SQM)	● Office (3)	
B00F - R0045 - Deputy Principal Office - (13.09 SQM)	● Office (3)	
B00F - R0046 - Administration - Clerical - (51.28 SQM)	● Office (12)	
B00F - R0047 - Public Reception - (15.92 SQM)	Not Applicable	Circulation or storage space.
B00F - R0048 - Movement - (21.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0049 - Interview/Office - Type 2 - (13.58 SQM)	● Office (3)	
B00F - R0050 - Interview/Meeting - (13.66 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0051 - Interview/Meeting - (13.66 SQM)	Office (3)	
B00F - R0052 - Deputy Principal Office - (13.47 SQM)	Office (3)	
B00F - R0053 - Movement - (23.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0057 - Administration - Clerical - (16.93 SQM)	Office (4)	
B00F - R0058 - Interview/Meeting - (18.83 SQM)	Office (4)	
B00G - R0001 - Materials Technology L.S. - (92.02 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0002 - Metal Technology Bay - (31.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Materials Technology L.S. - (88.89 SQM) - Teaching Space: 1	Student Space (41)	
B00G - R0004 - Metal Technology Bay - (59.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Materials Technology L.S. - (92.48 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0009 - Wood Technology Bay - (28.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Materials Technology L.S. - (92.72 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0011 - Workshop Area - (28.02 SQM)	Student Space (13)	
B00G - R0012 - Design L.S. - (56.85 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0013 - Design L.S. - (56.85 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0014 - Staff Study - (28.02 SQM)	Office (7)	
B00G - R0015 - Darkroom Space - (25.75 SQM)	Office (6)	
B00G - R0018 - Movement - (50.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (80.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Welding Area - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (26.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Art Learning Space - (59.48 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0006 - Movement - (117.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Art Learning Space - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0008 - Workshop - (58.62 SQM)	Student Space (27)	
B00H - R0009 - Art Learning Space - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0011 - Art Learning Space - (52.37 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0015 - Staff Study - (25.92 SQM)	Office (6)	
B00H - R0019 - Interview/Office - Type 1 - (12.65 SQM)	Office (3)	
B00H - R0020 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (19.06 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - General Assistants - (61.15 SQM)	Office (15)	
B00K - R0001 - General Learning Space - Type 1 - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0002 - General Learning Space - Type 1 - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0003 - Seminar - Type 1 - (24.39 SQM)	Office (6)	
B00K - R0004 - Movement - (280.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - General Learning Space - Type 1 - (59.63 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0006 - General Learning Space - Type 1 - (58.7 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0007 - General Learning Space - Type 1 - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0008 - Shared Learning Space - (37.04 SQM)	Student Space (17)	
B00K - R0009 - Special Learning Space - (61.52 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0010 - Practical Activities Area - 4 G.L.S. - (46.63 SQM)	Student Space (21)	
B00K - R0011 - Special Learning Space - (61.49 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0013 - Staff Study - (39.92 SQM)	Office (9)	
B00K - R0014 - Special Learning Space - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0018 - Special Learning Space - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0019 - Practical Activities Area - 2 G.L.S. - (12.75 SQM)	Student Space (5)	
B00K - R0022 - General Learning Space - Type 1 - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0023 - General Learning Space - Type 1 - (58.44 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0024 - General Learning Space - Type 1 - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0027 - Seminar - Type 1 - (29.56 SQM)	Office (7)	
B00K - R0028 - General Learning Space - Type 1 - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1001 - General Learning Space - Type 2 - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1002 - Seminar - Type 1 - (29.67 SQM)	Office (7)	
B00K - R1003 - Practical Activity Area - (18.81 SQM)	Student Space (8)	
B00K - R1005 - Shared Learning Space - (68.69 SQM)	Student Space (31)	
B00K - R1006 - General Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1007 - General Learning Space - (58.56 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1008 - General Learning Space - Type 1 - (59.42 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1010 - Shared Learning Space - (45.6 SQM)	Student Space (21)	
B00K - R1011 - General Learning Space - Type 1 - (63.58 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R1012 - General Learning Space - Type 1 - (62.59 SQM) - Teaching Space: 1	Student Space (29)	
B00K - R1014 - Interview/Meeting - (19.83 SQM)	Office (4)	
B00K - R1015 - Interview/Meeting - (19.64 SQM)	Office (4)	
B00K - R1023 - Staff Study - (148.33 SQM)	Office (37)	
B00K - R1027 - General Learning Space - (57.71 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R1028 - General Learning Space - (58.49 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R1029 - General Learning Space - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R1030 - Movement - (255.9 SQM)	Not Applicable	Circulation or storage space.
B00K - R1032 - Seminar - Type 1 - (29.42 SQM)	Office (7)	
B00K - R1033 - General Learning Space - Type 1 - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R1035 - Practical Activity Area - (12.6 SQM)	Student Space (5)	
B00L - R0002 - Staff Study - (35.52 SQM)	Office (8)	
B00L - R0003 - Interview/Meeting - (13.16 SQM)	Office (3)	
B00L - R0004 - Movement - (10.34 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Sick Bay - (7.75 SQM)	Student Space (3)	
B00L - R0010 - Multipurpose Space - Type 3 - (43.42 SQM) - Teaching Space: 1	Student Space (20)	
B00M - R0001 - General Learning Space - Bd/Cd/Ed - (58.71 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0005 - General Learning Space - Bd/Cd/Ed - (57.61 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0006 - General Learning Space - Bd/Cd/Ed - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0009 - General Learning Space - Bd/Cd/Ed - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
NS 220 13130 - NS 220 13130 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
NS 270 13126 - NS 270 13126 - Metal Technics/Heat Area/Storage - (95 SQM)	Student Space (44)	
OS 601 10017 - OS 601 10017 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11303 - OS 601 11303 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12631 - OS 601 12631 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12860 - OS 601 12860 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 710 16498 - OS 710 16498 - Home Science/Pantry/Laundry - (95 SQM)	Office (23)	