

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Rydalmere East Public School (4123)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Parramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

4123 - Rydalmere East Public School  
Site Plan (11252)



1:1,041

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (53.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Special Programs Room - (53.51 SQM)	● Student Space (24)	
B00A - R0009 - Canteen - (16.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (32.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (86.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Reading Area - (108.41 SQM)	● Student Space (50)	
B00B - R0002 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0003 - Home Base - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Home Base - (53.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0005 - Home Base - (53.36 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0006 - Withdrawal Space - 1hb - (22.37 SQM)	● Student Space (10)	
B00B - R0008 - Movement - (75.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (96.36 SQM) - Teaching Space: 1	● Student Space (44)	
B00D - R0006 - Home Base - (66.35 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0009 - Movement - (19.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (66.08 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0013 - Home Base - (66.36 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0015 - Movement - (14.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Withdrawal Space - 1hb - (18.13 SQM)	● Student Space (8)	
B00E - R0008 - Home Base - (38.04 SQM) - Teaching Space: 1	● Student Space (17)	
B00E - R0009 - Practical Activities - (27.98 SQM)	● Student Space (12)	
B00E - R0012 - Movement - (8.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Practical Activities - (28.42 SQM)	● Student Space (13)	
B00E - R0017 - Home Base - (38 SQM) - Teaching Space: 1	● Student Space (17)	
B00E - R0018 - Withdrawal Space - 1hb - (5.04 SQM)	● Student Space (2)	
B00F - R0002 - Movement - (42.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Withdrawal Space - 1hb - (11.57 SQM)	● Student Space (5)	
B00F - R0009 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Home Base/Practical Activities - E - (42.98 SQM) - Teaching Space: 1	● Student Space (19)	
B00F - R0015 - Home Base - Pre - (74.96 SQM) - Teaching Space: 1	● Student Space (34)	
B00K - R0001 - Communal Space - (139.92 SQM)	● Student Space (64)	
B00K - R0002 - Raised Platform - (53.78 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Canteen - (21.05 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Movement - (25.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Entry Vestibule - (15.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Interview - (12.93 SQM)	● Office (3)	
B00L - R0003 - Principal - (12.67 SQM)	● Office (3)	
B00L - R0009 - Movement - (42.97 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Staff Room Annexe - (16.14 SQM)	● Office (4)	
B00L - R0011 - Staff Room - (23.23 SQM)	● Office (5)	
B00L - R0013 - Sick Bay - (9.06 SQM)	● Student Space (4)	
B00L - R0014 - Clerical/Printing - (22.75 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Staff Kitchen - (7.81 SQM)	● Office (1)	