

VENTILATION AUDIT REPORT

SCHOOL:	Rydalmere Public School (3020)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Parramatta
LOCAL GOVERNMENT AREA:	Parramatta

3020 - Rydalmere Public School
Site Plan (11542)



1:1,166

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (22.05 SQM)	Office (5)	
B00A - R0002 - Sick Bay - (10.16 SQM)	Student Space (4)	
B00A - R0003 - Movement - (40.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Entry Vestibule - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (22.75 SQM)	Office (5)	
B00A - R0012 - Interview - (13.77 SQM)	Office (3)	
B00A - R0014 - Staff Room - (21.5 SQM)	Office (5)	
B00A - R0017 - Duplicating Workroom - (14.37 SQM)	Office (3)	
B00A - R0018 - Clerical Office - (14.11 SQM)	Office (3)	
B00B - R0001 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (46.99 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0005 - Communal Space - (114.36 SQM)	Student Space (53)	
B00C - R0009 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (22.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0004 - Home Base - (53.81 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0001 - Movement - (12.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (92.36 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0007 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Deputy Principal - (17.28 SQM)	Office (4)	
B00E - R0015 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (11.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Staff Room - (20.6 SQM)	Office (5)	
B00E - R0019 - Home Base - (53.66 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0020 - Practical Activities - 1hb - (13.21 SQM)	Student Space (6)	
B00E - R0024 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0025 - Practical Activities - 1hb - (13.16 SQM)	Student Space (6)	
B00E - R0026 - Withdrawal Space - 1hb - (6.52 SQM)	Student Space (3)	
B00F - R0007 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (5.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Home Base - (54.09 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0011 - Practical Activities - 1hb - (13.63 SQM)	Student Space (6)	
B00F - R0012 - Withdrawal Space - 2hb - (7.84 SQM)	Student Space (3)	
B00F - R0014 - Practical Activities - 1hb - (13.5 SQM)	Student Space (6)	
B00F - R0015 - Home Base - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0016 - Practical Activities - 1hb - (13.3 SQM)	Student Space (6)	
B00F - R0017 - Home Base - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0018 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Withdrawal Space - 2hb - (8.9 SQM)	Student Space (4)	
B00F - R0021 - Practical Activities - 1hb - (13.8 SQM)	Student Space (6)	
B00F - R0022 - Home Base - (53.94 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R9002 - Movement - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R9003 - Canteen - (27.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Reading Area - (53.72 SQM)	Student Space (24)	
B00G - R0003 - Reading Area - (53.73 SQM)	Student Space (24)	
B00G - R0009 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0011 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (47.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Home Base - Pre - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0010 - Movement - (14.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Home Base - Pre - (53.95 SQM) - Teaching Space: 1	● Student Space (25)	
B00M - R0003 - Movement - (41.95 SQM)	Not Applicable	Circulation or storage space.