


VENTILATION AUDIT REPORT

SCHOOL:	Ryde East Public School (4257)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Ryde












4257 - Ryde East Public School
Site Plan (10554)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Home Base - (46.89 SQM) - Teaching Space: 1	● Student Space (21)	
B002 - R0002 - Entry Vestibule - (57.32 SQM)	Not Applicable	Circulation or storage space.
B002 - R0004 - Clerical Office - (13.22 SQM)	● Office (3)	
B002 - R0005 - Clerical Office - (14.44 SQM)	● Office (3)	
B002 - R0006 - Principal - (21.31 SQM)	● Office (5)	
B002 - R0007 - Staff Room Annexe - (14.48 SQM)	● Office (3)	
B002 - R0008 - Deputy Principal - (14.44 SQM)	● Office (3)	
B002 - R0009 - Staff Room Annexe - (14.48 SQM)	● Office (3)	
B002 - R0013 - Staff Room - (77.72 SQM)	● Office (19)	
B002 - R0017 - Duplicating Workroom - (16.93 SQM)	● Office (4)	
B002 - R0018 - Sick Bay - (10.23 SQM)	● Student Space (4)	
B002 - R0024 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B002 - R1001 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B002 - R1003 - Entry Vestibule - (6.37 SQM)	Not Applicable	Circulation or storage space.
B002 - R1010 - Seminar/Study - (16.05 SQM)	● Office (4)	
B002 - R1011 - Seminar/Study - (16.35 SQM)	● Office (4)	
B002 - R1012 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B002 - R1013 - Reading Area - (49.29 SQM)	● Student Space (22)	
B002 - R1018 - Home Base - (71.19 SQM) - Teaching Space: 1	● Student Space (33)	
B002 - R1019 - Home Base - (65.25 SQM) - Teaching Space: 1	● Student Space (30)	
B002 - R1022 - Movement - (38.85 SQM)	Not Applicable	Circulation or storage space.
B002 - R1023 - Movement - (16.15 SQM)	Not Applicable	Circulation or storage space.
B002 - R1024 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Interview - (14.45 SQM)	● Office (3)	
B00A - R0015 - Home Base - (56.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0016 - Home Base - (56.7 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0002 - Special Programs Room - (22.58 SQM)	● Student Space (10)	
B00B - R0006 - Home Base - (74 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0007 - Practical Activities - 1hb - (5.6 SQM)	● Student Space (2)	
B00B - R0008 - Withdrawal Space - 1hb - (57.06 SQM)	● Student Space (26)	
B00B - R0010 - Movement - (14.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Teachers Aide Special Ed - (17.23 SQM)	● Office (4)	
B00B - R0016 - Home Base - (52.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0017 - Home Base - (56.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0023 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (57.47 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Home Base - (85.85 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0031 - Home Base - (56.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0004 - Home Base - (55.64 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0008 - Movement - (6.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Home Base - (55.64 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0010 - Home Base - (56.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R1001 - Movement - (10.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Home Base - (55.8 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R1003 - Home Base - (56.04 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1005 - Home Base - (55.65 SQM) - Teaching Space: 1	 Student Space (25)	
B00F - R1007 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R1010 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Canteen - (45.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Movement - (28.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Raised Platform - (36.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Communal Space - (239.66 SQM)	 Student Space (111)	
B00G - R0017 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (231.26 SQM)	 Student Space (107)	
B00J - R1001 - Home Base - (58.16 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R1002 - Home Base - (60.95 SQM) - Teaching Space: 1	 Student Space (28)	
B00J - R1003 - Home Base - (60.37 SQM) - Teaching Space: 1	 Student Space (28)	
B00J - R1005 - Practical Activities - 1hb - (19.06 SQM)	 Student Space (8)	
B00J - R1006 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (5)	
B00J - R1007 - Practical Activities - 1hb - (18.87 SQM)	 Student Space (8)	
B00J - R1010 - Withdrawal Space - 1hb - (9.2 SQM)	 Student Space (4)	
B00J - R1011 - Practical Activities - 1hb - (20.64 SQM)	 Student Space (9)	