

VENTILATION AUDIT REPORT

SCHOOL:	Ryde Secondary College (8415)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Ryde

8415 - Ryde Secondary College
Site Plan (10560)



1:1,121

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0019 - Music Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0021 - Performance Workshop - (85.46 SQM)	Student Space (39)	
B00A - R0041 - Music Learning Space - (46.29 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0052 - Tea Room - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Principal Office - (26.11 SQM)	Office (6)	
B00A - R0054 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Deputy Principal Office - (11.77 SQM)	Office (2)	
B00A - R0056 - Public Reception - (19.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Administration - Clerical - (46.57 SQM)	Office (11)	
B00A - R0059 - Administration - Clerical - (11.55 SQM)	Office (2)	
B00A - R0060 - Deputy Principal Office - (11.52 SQM)	Office (2)	
B00A - R0062 - Student Reception - (15.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Clinic - (11.2 SQM)	Office (2)	
B00A - R0067 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0068 - Interview/Office - Type 1 - (9.35 SQM)	Office (2)	
B00A - R0072 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0073 - Interview/Office - Type 1 - (12.57 SQM)	Office (3)	
B00A - R0074 - Interview/Office - Type 1 - (12.61 SQM)	Office (3)	
B00A - R0075 - General Learning Space - (62.42 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0082 - Movement - (14.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1006 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (58.74 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1009 - General Learning Space - (65.15 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1012 - Computer Learning Space - (58.96 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1018 - General Learning Space - (58.65 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1025 - Leading Teacher - (13.07 SQM)	Office (3)	
B00A - R1026 - Leading Teacher - (12.18 SQM)	Office (3)	
B00A - R1031 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1032 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Design/Technology L.S. - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0011 - General Learning Space - (58.66 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Food Technology L.S. - (71.37 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0015 - Preparation - Science - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Food Technology L.S. - (65.62 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0026 - Food/Research Space - (39.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - General Learning Space - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0040 - Materials Learning Space - Type 1 - (119.23 SQM) - Teaching Space: 1	Student Space (55)	
B00B - R1003 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - Materials Learning Space - Type 1 - (86.05 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R1011 - Design L.S. - (65.6 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1014 - General Learning Space - (58.26 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1025 - General Learning Space - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1030 - Welding Area - (8.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R1031 - Materials Learning Space - Type 1 - (93.69 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R1035 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1036 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0001 - Multi-Purpose Space - (359.07 SQM)	● Student Space (166)	
B00C - R0009 - Interview/Office - Type 1 - (8.96 SQM)	○ Office (2)	
B00C - R0022 - Student Canteen - (50.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R9004 - General Assistants - (39.02 SQM)	○ Office (9)	
B00C - R9016 - Movement - (8.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R9017 - Workshop - (34.63 SQM)	● Student Space (16)	
B00C - R9019 - Art Learning Space - (36.35 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R9023 - General Assistants - (31.85 SQM)	○ Office (7)	
B00D - R0004 - Special Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0005 - Laboratory L.S. - (92.42 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0008 - Laboratory L.S. - (91.57 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0009 - General Learning Space - (65.22 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0029 - Preparation - Science - (25.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Special Learning Space - (65.83 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1002 - Seminar - (25.24 SQM)	○ Office (6)	
B00D - R1003 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - Art Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - General Learning Space - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1016 - General Learning Space - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1025 - Art Learning Space - (79.6 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R1029 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1030 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1037 - Dark Room - (31.77 SQM)	○ Office (7)	
B00E - R0003 - Staff Study - (52 SQM)	○ Office (13)	
B00E - R0005 - General Learning Space - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0006 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0010 - Special Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0015 - Laboratory L.S. - (91.92 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0018 - Laboratory L.S. - (91.8 SQM) - Teaching Space: 1	● Student Space (42)	
B00E - R0028 - Fitness Laboratory - (98.57 SQM)	● Student Space (45)	
B00E - R0032 - Preparation - Science - (25.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Staff Study - (52.08 SQM)	○ Office (13)	
B00E - R1015 - Interview/Office - Type 1 - (12.82 SQM)	○ Office (3)	
B00E - R1017 - Computer Learning Space - (108.41 SQM) - Teaching Space: 1	● Student Space (50)	
B00E - R1025 - Audio Visual Workroom - (19.5 SQM)	● Student Space (9)	
B00E - R1027 - Computer Room - (12.06 SQM)	● Student Space (5)	
B00E - R1031 - Staff Study - (78.44 SQM)	○ Office (19)	
B00E - R1032 - Staff Study - (138.77 SQM)	○ Office (34)	
B00E - R1039 - Commonroom - (70.76 SQM)	○ Office (17)	
B00E - R1040 - Staff Kitchen - (14.12 SQM)	○ Office (3)	
B00F - R0009 - Senior Study - (32.08 SQM)	○ Office (8)	
B00F - R0010 - Study Space - (147.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Main Area - (251.25 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Movement - (145.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (43.08 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0006 - Multi-Purpose Space - (476.43 SQM)	● Student Space (221)	
B00G - R0013 - Staff Kitchen - (11.59 SQM)	● Office (2)	
B00G - R0015 - Stage - (101.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Movement - (9.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
B00G - R0034 - Staff Study - (38 SQM)	● Office (9)	
B00G - R9001 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - Movement - (7.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Performance Workspace - (160.7 SQM) - Teaching Space: 1	● Student Space (74)	
B00I - R1002 - Multi Media Workshop - (64.91 SQM)	Not Applicable	Circulation or storage space.
B00I - R1004 - Tea Room - (7.45 SQM)	Not Applicable	Circulation or storage space.
B00I - R1006 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
OS 523 14995 - OS 523 14995 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 600 10503 - OS 600 10503 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11327 - OS 600 11327 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 13841 - OS 600 13841 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15204 - OS 600 15204 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19625 - OS 600 19625 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19748 - OS 600 19748 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19756 - OS 600 19756 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19842 - OS 600 19842 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19843 - OS 600 19843 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19845 - OS 600 19845 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 13308 - OS 601 13308 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14384 - OS 601 14384 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14559 - OS 601 14559 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15768 - OS 601 15768 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 15018 - OS 720 15018 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 750 13058 - OS 750 13058 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	