


VENTILATION AUDIT REPORT

SCHOOL:	Sadleir Public School (4319)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

4319 - Sadleir Public School
Site Plan (11272)



1:972

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (21.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Sick Bay - (8.45 SQM)	● Student Space (3)	
B00A - R0004 - Duplicating Workroom - (10.62 SQM)	● Office (2)	
B00A - R0008 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Clerical Office - (13.05 SQM)	● Office (3)	
B00A - R0010 - Deputy Principal - (14.16 SQM)	● Office (3)	
B00A - R0012 - Principal - (18.18 SQM)	● Office (4)	
B00A - R0015 - Movement - (10.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0025 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0037 - Special Programs Room - (56.27 SQM)	● Student Space (26)	
B00A - R0038 - Staff Room Annexe - (56.34 SQM)	● Office (14)	
B00B - R0001 - Movement - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (10.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (56.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (56.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0016 - Home Base - (56.41 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0020 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Home Base - (56.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0001 - Movement - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (56.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Practical Activities - 1hb - (6.96 SQM)	● Student Space (3)	
B00C - R0011 - Movement - (6.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (56.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0016 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0020 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (56.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0010 - Home Base - (56.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0014 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0019 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Canteen - (17.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0007 - Home Base - (57.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0013 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Staff Kitchen - (9.26 SQM)	● Office (2)	
B00E - R0020 - Home Base - Pre - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0022 - Movement - (15.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Withdrawal - Pre - (11.89 SQM)	● Student Space (5)	
B00E - R0028 - Withdrawal - Pre - (6.43 SQM)	● Student Space (2)	
B00E - R0029 - Practical Activities - Pre - (24.37 SQM)	● Student Space (11)	
B00F - R0001 - Movement - (68.26 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0006 - Home Base - (84.43 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0007 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - (56.26 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0015 - Home Base - (84.89 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0019 - Movement - (68.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0024 - Staff Room - (57.77 SQM)	● Office (14)	
B00G - R0002 - Movement - (26.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Interview - (19.14 SQM)	● Office (4)	
B00G - R0004 - Deputy Principal - (17.18 SQM)	● Office (4)	
B00G - R0010 - Interview - (32.62 SQM)	● Office (8)	
B00G - R0016 - Home Base - (57.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0019 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Home Base - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0024 - Home Base - (57.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0027 - Movement - (5.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0030 - Entry Vestibule - (8.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (115.15 SQM)	● Student Space (53)	
B00H - R0003 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Communal Space - (145.08 SQM)	● Student Space (67)	
B00N - R0002 - Raised Platform - (59.86 SQM)	Not Applicable	Circulation or storage space.
B00N - R0016 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (11.69 SQM)	Not Applicable	Circulation or storage space.
B00N - R0018 - Movement - (11.46 SQM)	Not Applicable	Circulation or storage space.
B00N - R0020 - Canteen - (26.39 SQM)	Not Applicable	Circulation or storage space.