


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Samuel Gilbert Public School (4574)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Castle Hill</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

4574 - Samuel Gilbert Public School  
Site Plan (10682)



1:1,874

Printed: 17-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (88.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (13.8 SQM)	Office (3)	
B00A - R0004 - Principal - (17.07 SQM)	Office (4)	
B00A - R0005 - Deputy Principal - (12.77 SQM)	Office (3)	
B00A - R0006 - Deputy Principal - (12.82 SQM)	Office (3)	
B00A - R0007 - Movement - (37.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Staff Room - (60.85 SQM)	Office (15)	
B00A - R0009 - Movement - (9.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room Annexe - (26.61 SQM)	Office (6)	
B00A - R0016 - Sick Bay - (8.88 SQM)	Student Space (4)	
B00A - R0017 - Duplicating Workroom - (32.83 SQM)	Office (8)	
B00A - R0018 - Interview - (12.61 SQM)	Office (3)	
B00B - R0001 - Movement - (202.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Canteen - (47.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (9.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (5.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Raised Platform - (37.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Communal Space - (213.81 SQM)	Student Space (99)	
B00C - R0001 - Movement - (49.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0003 - Movement - (23.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Withdrawal Space - 1hb - (11.8 SQM)	Student Space (5)	
B00C - R0005 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (35.75 SQM)	Student Space (16)	
B00D - R0001 - Movement - (62.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (31.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Withdrawal Space - 1hb - (11.73 SQM)	Student Space (5)	
B00D - R0012 - Practical Activities - 1hb - (35.73 SQM)	Student Space (16)	
B00D - R0013 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0014 - Home Base - (60.58 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0001 - Movement - (166.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Reading Area - (225.47 SQM)	Student Space (104)	
B00E - R0006 - Special Programs Room - (42.1 SQM)	Student Space (19)	
B00F - R0001 - Movement - (30.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Withdrawal Space - 1hb - (12.23 SQM)	Student Space (5)	
B00F - R0003 - Home Base - (60.45 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0010 - Movement - (98.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Practical Activities - 1hb - (35.67 SQM)	Student Space (16)	
B00F - R0013 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0001 - Movement - (33.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Withdrawal Space - 1hb - (11.73 SQM)	Student Space (5)	
B00G - R0003 - Home Base - (60.66 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0008 - Practical Activities - 1hb - (35.54 SQM)	Student Space (16)	
B00G - R0009 - Movement - (55.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Home Base - (60.58 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0001 - Movement - (30.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Withdrawal Space - 1hb - (11.78 SQM)	Student Space (5)	
B00H - R0003 - Home Base - (60.71 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0008 - Practical Activities - 1hb - (35.75 SQM)	Student Space (16)	
B00H - R0009 - Movement - (40.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Home Base - (60.66 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0001 - Practical Activities - 1hb - (16.88 SQM)	Student Space (7)	
B00I - R0002 - Movement - (32.6 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Practical Activities - 1hb - (16.87 SQM)	Student Space (7)	
B00I - R0006 - Home Base - (63.77 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R0007 - Withdrawal Space - 1hb - (11.8 SQM)	Student Space (5)	
B00I - R0008 - Home Base - (63.79 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R0009 - Practical Activities - 1hb - (16.97 SQM)	Student Space (7)	
B00I - R0010 - Home Base - (63.77 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R0011 - Movement - (32.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - Withdrawal Space - 1hb - (11.83 SQM)	Student Space (5)	
B00I - R0014 - Movement - (87.7 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Practical Activities - 1hb - (16.65 SQM)	Student Space (7)	
B00I - R0016 - Home Base - (63.72 SQM) - Teaching Space: 1	Student Space (29)	
B00J - R0001 - Movement - (17.63 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Staff Kitchen - (9.42 SQM)	Office (2)	
B00K - R0001 - Movement - (15.43 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Entry Vestibule - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Interview - (9.9 SQM)	Office (2)	
B00L - R0005 - Withdrawal Space - 1hb - (14.01 SQM)	Student Space (6)	
B00L - R0006 - Special Programs Room - (71.76 SQM)	Student Space (33)	
B00L - R0007 - Withdrawal Space - 1hb - (19.98 SQM)	Student Space (9)	
B00L - R0008 - Special Programs Room - (55.24 SQM)	Student Space (25)	
B00M - R0002 - Practical Activities - (19.06 SQM)	Student Space (8)	
B00M - R0003 - Withdrawal Space - 2hb - (11.68 SQM)	Student Space (5)	
B00M - R0006 - Home Base - (60.23 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0007 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0009 - Practical Activities - (19.03 SQM)	Student Space (8)	
B00M - R0010 - Practical Activities - (18.84 SQM)	Student Space (8)	
B00M - R0011 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B00M - R0013 - Home Base - (60.13 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0014 - Home Base - (60.19 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0017 - Practical Activities - (19.1 SQM)	Student Space (8)	
OS 602 12755 - OS 602 12755 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13617 - OS 602 13617 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14884 - OS 602 14884 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15836 - OS 602 15836 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 11773 - OS 603 11773 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 10405 - OS 606 10405 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19664 - OS 606 19664 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19665 - OS 606 19665 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19667 - OS 606 19667 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19669 - OS 606 19669 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19670 - OS 606 19670 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19671 - OS 606 19671 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	