

VENTILATION AUDIT REPORT

SCHOOL:	Samuel Terry Public School (4560)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

4560 - Samuel Terry Public School
Site Plan (11277)

















1:1,033

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview - (13.52 SQM)	Office (3)	
B00A - R0002 - Principal - (14.87 SQM)	Office (3)	
B00A - R0003 - Sick Bay - (9.04 SQM)	Student Space (4)	
B00A - R0004 - Clerical Office/Workroom - (12.12 SQM)	Office (3)	
B00A - R0005 - Interview - (12.18 SQM)	Office (3)	
B00A - R0006 - Staff Room Annexe - (24.3 SQM)	Office (6)	
B00A - R0007 - Staff Room - (49.06 SQM)	Office (12)	
B00A - R0008 - Staff Kitchen - (11.73 SQM)	Office (2)	
B00A - R0015 - Duplicating Workroom - (32.35 SQM)	Office (8)	
B00A - R0016 - Clerical Office - (13.24 SQM)	Office (3)	
B00A - R0017 - Entry Vestibule - (17.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (35.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (41.78 SQM)	Student Space (19)	
B00B - R0005 - Home Base - (59.27 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Withdrawal Space - 1hb - (12.05 SQM)	Student Space (5)	
B00B - R0008 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0012 - Home Base - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Withdrawal Space - 1hb - (11.95 SQM)	Student Space (5)	
B00B - R0016 - Practical Activities - 1hb - (41.79 SQM)	Student Space (19)	
B00B - R0017 - Home Base - (59.64 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0020 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0022 - Withdrawal Space - 1hb - (11.95 SQM)	Student Space (5)	
B00B - R0023 - Practical Activities - 1hb - (41.78 SQM)	Student Space (19)	
B00B - R0025 - Home Base - (59.78 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0028 - Home Base - (59.73 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0030 - Practical Activities - 1hb - (41.78 SQM)	Student Space (19)	
B00B - R0032 - Withdrawal Space - 1hb - (11.96 SQM)	Student Space (5)	
B00B - R0033 - Home Base - (59.52 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0038 - Interview - (11.73 SQM)	Office (2)	
B00C - R0005 - Interview - (15.68 SQM)	Office (3)	
B00C - R0008 - Canteen - (42.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Communal Space - (212.89 SQM)	Student Space (98)	
B00C - R0015 - Raised Platform - (43.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (41.77 SQM)	Student Space (19)	
B00D - R0009 - Home Base - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - Withdrawal Space - 1hb - (12.01 SQM)	Student Space (5)	
B00D - R0011 - Home Base - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0014 - Home Base - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0017 - Practical Activities - 1hb - (41.78 SQM)	Student Space (19)	
B00D - R0019 - Withdrawal Space - 1hb - (12.03 SQM)	Student Space (5)	
B00D - R0020 - Home Base - (59.61 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0023 - Home Base - (59.62 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0025 - Withdrawal Space - 1hb - (12.03 SQM)	Student Space (5)	
B00D - R0026 - Practical Activities - 1hb - (41.77 SQM)	Student Space (19)	
B00D - R0029 - Home Base - (59.73 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0001 - Special Programs Room - (40.76 SQM)	Student Space (18)	
B00E - R0006 - Reading Area - (231.05 SQM)	Student Space (107)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
B00G - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	 Student Space (4)	
B00G - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
B00H - R0002 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
B00H - R0004 - Home Base - (58.79 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	 Student Space (4)	
B00H - R0006 - Home Base - (58.69 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.37 SQM)	 Student Space (8)	
OS 602 11346 - OS 602 11346 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14013 - OS 602 14013 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16087 - OS 602 16087 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16242 - OS 602 16242 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	